

Consultation Reply

From: <redacted_name> <redacted_email> Sent: <redacted_date> 10:07:19 UTC+00:00 To: <redacted_name> <redacted_email> Subject: Re: 91.48267.FUL- Erection of storage barn. Morning <redacted_name>, We have tracked a 7.5 tonne vehicle and unfortunately it isn't able to turn in the turning head provided without clipping the side of the building and overhanging onto the boundary. If the turning head is widened by 2m this should prevent this from happening- see below If this could please be shown on a scaled plan I will provide my final comments. Kind Regards <redacted_name> From: <redacted_name> <redacted_email> Sent: Wednesday, October 29, <redacted_date> 08:48 To: <redacted_name> <redacted_email> Subject: FW: 91.48267.FUL- Erection of storage barn. Hi <redacted_name>, Response below from the Agent re maximum size of vehicles , Kr, <redacted_name> From: <redacted_name> <redacted_email> Sent: <redacted_date> 14:40 To: <redacted_name> <redacted_email> Subject: Re: 91.48267.FUL- Erection of storage barn. Hi <redacted_name> - thank you. 7.5 tonne. Many thanks <redacted_name> <redacted_name> BA(Hons) BTP MRTPI Director <redacted_name> <redacted_name> Services Ltd & <redacted_name> Vardo Intelligent <redacted_name> Services Ltd Registe Caution! This message was sent from outside your organization. Allow sender sophospSMARTBannerend Hi <redacted_name> - thank you. 7.5 tonne. Many thanks <redacted_name> <redacted_name> BA(Hons) BTP MRTPI Director <redacted_name> <redacted_name> Services Ltd & <redacted_name> Vardo Intelligent <redacted_name> Services Ltd Registered Office: Mercury House Willoughton Drive <redacted_name> Gainsborough DN21 1DY Tel: <redacted_phone> Mobile: <redacted_phone> www.marksimmondsplanningservices.co.uk & <http://www.trinitytownplanning.co.uk> ***** Email confidentiality notice ***** This message is private and confidential. If you have received this message in error, please notify us and remove it from your system. From: <redacted_name> <redacted_email> Sent: Tuesday, October 28, <redacted_date> 2:33:40 PM To: <redacted_name> <redacted_email> Subject: FW: 91.48267.FUL- Erection of storage barn. <redacted_name>, Can you please confirm the largest vehicle accessing the site please as per highways request below. It seems straight forward enough to resolve quickly rather than wait for the consultation expiry and send amendments letter. Also, the email address on the file is – <redacted_email> is this still valid? Many thanks, <redacted_name> From: <redacted_name> <redacted_email> Sent: <redacted_date> 08:59 To: <redacted_name> <redacted_email> Subject: 91.48267.FUL- Erection of storage barn. Good Morning <redacted_name>, Thank you for consulting Highways Development Control on this application - 91.48267.FUL■Erection of storage barn. Location of application is - Roseacre House, Barnby Dun, Doncaster, ZZ38 5BX. The site plan shows an access that measures in excess of 4.8m wide for the first 10m, the proposed driveway is of bound material for the first 10m to ensure no stones are deposited onto the highway. I would like confirmation of the largest vehicle that shall be using this storage barn please. Kind Regards <redacted_name> <redacted_name> Highway Development Control Officer Working Days- Monday, Tuesday & Thursday City of Doncaster Council Directorate of Place Civic Office, Waterdale, Doncaster DN1 3BU Please treat the content of this e-mail as confidential. If you have received this e-mail and it is not addressed to you please accept my apologies and inform me as soon as possible.