

Consultation Reply Environmental Health

From: <redacted_name> <redacted_email> Sent: <redacted_date> 13:50:06 UTC+00:00 To: <redacted_name> <redacted_email> Cc: <redacted_name> <redacted_email> Subject: 91.48267.FUL EH Ref: <redacted_date>/25 Dear <redacted_name> Thank you for consulting with the Environmental Health Team regarding this proposal. I have no objection to the development in principal and consider that the development is sufficiently removed from the existing residential properties that little noise nuisance will be caused by construction activities. For your information: I note that there was or may still be an agricultural building on this site that was going to be demolished as part of a previous application number <redacted_reference>, which was refused. This old building, if still present, had cement bound asbestos roofing, that will require careful dismantling and correct disposal. I would therefore recommend that a construction method statement with particular attention to the removal and disposal of that material is requested as part of the conditions. Construction Method Statement No development shall take place, including any works of demolition, until a Construction Method Statement has been submitted to and approved in writing by the local planning authority. The approved statement shall be adhered to throughout the construction period. The statement shall provide for:

i) the parking of vehicles of site operatives and visitors ii) loading and unloading of plant and materials iii) storage of plant and materials used in constructing the development iv) the erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate v) wheel washing facilities vi) measures to control noise and the emission of dust and dirt during construction vii) a scheme for recycling/disposing of waste resulting from demolition and construction works REASON: To safeguard the living conditions of neighbouring residents and in the interests of highway safety.

Before any construction works are started on the application site, a Construction Impact Management Plan, indicating measures to be taken to mitigate the effects of the construction activity and associated vehicle movements upon the living conditions of neighbouring residents and highway safety shall be submitted to and approved by the Local Planning Authority. The mitigation measures shall include provision for the following: the limitation of noise, the means of enclosure of the construction sites, and any proposed external security lighting installation; the control of dust emissions; the control of deposition of mud or debris on the highway, and the routing of contractors' vehicles. The mitigation measures so approved shall be carried out at all times during the construction of the development hereby approved. REASON: To safeguard the living conditions of neighbouring residents. Yours sincerely <redacted_name>, BSc (Hons), MCIEH Senior Environmental Health Practitioner Directorate of Place City of Doncaster Council Phone <redacted_phone> Address Floor 2, Civic Office, Waterdale, Doncaster DN1 3BU Email <redacted_email> Website www.doncaster.gov.uk Follow MyDoncaster on Twitter and Facebook for the latest news. Please treat the content of this email as confidential. If you have received this email and it is not addressed to you please accept my apologies and inform me as soon as possible.