

Consultation Reply Planning Policy Flood Risk

PLANNING CONSULTATION RESPONSE Application No 91.48267.FUL Proposal Erection of storage barn Address Roseacre House, Barnby Dun, Doncaster, ZZ38 5BX Consultee Planning Policy and Environment Team (Food Risk Management) Thank you for consulting us on the above proposal. According to the Gov.uk maps, the site lies within Flood Zone 3, a high probability of flooding from rivers and/or the sea. Therefore Policy 57 of the Doncaster Local Plan (adopted <redacted_date>) is relevant. The policy states that "all development proposals will be considered against the NPPF, including application of the sequential test and, if necessary, the exception test". The application is for a 'like for like' storage building in connection with an existing farm, which is a 'less vulnerable' land use in Annex 3 of the NPPF. It is therefore necessary for the application to pass the Sequential Test and to be supported by a site-specific flood risk assessment (FRA), which can demonstrate that the 'development will be safe for its lifetime taking account of the vulnerability of its users, without increasing flood risk elsewhere, and, where possible, will reduce flood risk overall'. Please note, this type of development in this location, an exception test is not required (see Table 2: Flood risk vulnerability and flood zone 'incompatibility' of the NPPG). I note in the EA response they state they ".....have not objected to the application on flood risk grounds, but this does not remove the need for you to apply the sequential test and to consider whether it has been satisfied." The Council's Flood Risk SPD states that no sequential test is required for development within CDC administrative boundary if "Minor non – residential extensions where they are not in excess of 250m2 or Alterations which do not increase the size of buildings.." although this is a replacement building and not an extension or alteration, it is operationally linked and 'like to like' under the 250m2 remit for requiring a sequential test. Therefore, in this case, the proposal for a new barn/storage building connected to an existing farm/rural location, if the LLFA and EA have no objections to the flood management of the new building (albeit by condition) and the applicants have demonstrated that the development can be made safe throughout its lifetime without increasing risk elsewhere although there's still a limited risk, if you agree, in this case, a 'like for like' storage barn with flood risk betterment would not require a sequential test. As a side note – the FRA is incorrect; Page 7 "Application of Sequential Test and Exception Test" uses a previous version of Table 2: Flood Risk Vulnerability and Flood Zone Compatibility and also references an outdated Councils SPD (<redacted_date>). If this is standard FRA template the Engineer is using then it will be incorrect data for many other scenarios. Many Thanks <redacted_name> Senior Planning Officer Planning Policy and Environment Team