

Consultation Reply Environmental Health

From: <redacted_name> <redacted_email> Sent: <redacted_date> 16:21:32 UTC+01:00 To: <redacted_name> <redacted_email> Cc: <redacted_name> <redacted_email> Subject: 97.61549.FUL: 68 Brookfield Lane, Hexthorpe, Doncaster, ZZ54 0FT Good Afternoon, I have reviewed the application for the conversion of a C3 dwelling to a C4, 5 bed HMO. The location is a residential terraced street with rear yards, which is where waste bins are stored ready for them to be presented in the rear alleyway on collection day. There is nothing in the immediate area that gives cause for concern in terms of impact on the development. With regard to the proposed development, my comments are as follows: The room sizes, layout, kitchen and bathroom facilities appear adequate from the plan and would be acceptable in terms of HMO Licensing. The rear garden is large enough to contain the additional waste storage containers for the development, and there is easy access to the garden and rear alley for waste collection. In terms of increase in number of individual households that would occupy the development, this is an increase on the existing, single family property and there is some potential for increased noise generation which may either affect the adjoining residential occupiers or due to living spaces being converted to bedrooms, may experience noise from the adjoining residential occupiers. Therefore, we would recommend the developer implement a scheme of enhanced sound insulation ('soundbloc' plasterboard added) to the party walls of the bedrooms to ensure no loss of quality of life in this situation, as an advisory. Kind Regards, <redacted_name>

Trainee Environmental Health Practitioner Regulation & Enforcement Directorate of Place Civic Office | Enforcement | Floor 2 | Waterdale | Doncaster | DN1 3BU