

Consultation Reply South Yorkshire Police

Charles MacDonald-Jones <redacted_name> Doncaster Metropolitan Borough Council Civic Office Waterdale Doncaster DN1 3BU <redacted_date> <redacted_name> CONSULTATION RESPONSE Application No 97.61549.FUL Proposal Conversion of C3 dwelling to C4 5 bed HMO Address 9, 68 Brookfield Lane, Hexthorpe, Doncaster, ZZ54 0FT, Hexthorpe, Doncaster, ZZ54 0FT Thank you for giving South Yorkshire Police 'Designing Out Crime Officers' the opportunity to view this <redacted_name> application. It is now widely accepted that resistance to both crime and disorder has a positive effect on community cohesion and sustainability. In today's consumer society, the provision of a safe and secure home environment is often a major factor in deciding on a particular property for many people. The open-source sites, <redacted_url> and ONS websites together with South Yorkshire Police information systems have been used to obtain details of local crimes and incidents. These details have been used to ascertain the possible type and number of crimes, which may affect the development and its residents or users. Information from both open sources are fully audited Government controlled sites and provide the most reliable sources of information in respect of this area. There have been no recent incidents of criminality at the premises however the surrounding area does suffer from higher-than-average Anti Social Behaviour and criminality in relation to vehicle crime and Burglary related offences. Due to their being no mention of security prevention measures on the design and access statement I make the following recommendations. Officer <redacted_name> The following security recommendations are requested to ensure the physical security of the building and are subject to the below recommendations already being in situ and fit for purpose. In a building containing multiple dwellings there may be a requirement for a doorset to be both smoke, fire and security rated. It is the responsibility of the developer or the developer's agent to ensure compliance with all applicable Building Regulations. • Communal doors must comply with LPS1175: issue 7 SR1, individual apartment/room doors must comply with PAS24; <redacted_date>. This is to include the locking system. The main entry doors to comply with LPS <redacted_date>; Issue 7 SR2 • Accessed controlled communal entry/exit doors using magnetic locks should have a minimum of 2x magnetic locks, with a minimum of 1,200lbs of holding force. Shearlocks and strikelocks are preferable over magnetic locks as they are more resistant to forced attack. Consideration should also be given to the design of the doors to prevent unlawful/casual entry and tailgating. • Windows are to comply with the PAS 24 specification (where the PAS specification is a draft British Standard). • The glazing units in easily accessible windows to consist of a minimum of one pane of glass that achieves compliance under the BS EN356 P1A attack resistance standard (Laminated exterior pane with tempered/toughened interior pane). A suitable alternative to laminated glass is a security film that meets BS EN 356:<redacted_date> class P1A standard or higher, installed to the edge of the glass, under the window beading. • Dusk to dawn lighting should be installed within the communal entrances to provide illumination for residents and visitors. Each outer wall containing an entrance door must also have a dusk to dawn light fitted above the door. • Lightweight framed walls installed either side of a secure doorset (600mm for the full height of the doorset to restrict access to door hardware) or walls providing a partition between two dwellings, or a dwelling and shared communal space, shall meet the requirements below: • LPS <redacted_date> Issue 7.2:<redacted_date> Security Rating 1; or • LPS <redacted_date> Issue 8:<redacted_date> Security Rating 1/A1; or • STS 202 Issue 7:<redacted_date> Burglary Rating 1. This is to protect against attack from one apartment/room through to the adjacent or via a wall from the communal area. • It is recommended that a door entry system is installed. This is a visitor system that can call a dwelling, whether individual or served from a communal entrance. It shall allow a visitor to contact the requested dwelling within the system and/or building and hold a two-way simultaneous conversation between the visitor and occupant of the dwelling. It will allow the occupant to see and identify the visitor and their location and will enable the occupant of the dwelling to remotely operate the electric locking device from their room terminal, thereby unlocking the communal entrance door(s) associated with the action and allowing the visitor access. • Communal entrance doorsets that serve 4 dwellings or less in buildings that are no more than two storeys in height are not required to be connected to a visitor door entry system and access control system and can be controlled by non■electronic keys only i.e. requiring residents to meet and greet visitors at the communal door. However, there may be exceptions to this, such as sheltered accommodation, care provision, etc. • Tradesperson or timed-release mechanisms are not recommended as they have been proven to be the cause of anti-social behaviour and unlawful access to communal developments. • Mail delivery systems should be designed to allow the secure delivery of mail. Further information these systems can be found at the Secured by Design website. <redacted_url> <redacted_name> The National <redacted_name> <redacted_name> Framework (<redacted_date>) Section 8. Promoting healthy and safe communities Para 8. Achieving sustainable development means that the <redacted_name> system has three overarching objectives, which are interdependent and need to be pursued in mutually supportive ways: (b) a social objective – to support strong, vibrant, and healthy communities, by ensuring that a sufficient number and range of homes can be provided to meet the needs of present and future generations;

and by fostering well-designed, beautiful, and safe places, with accessible services and open spaces that reflect current and future needs and support communities' health, social and cultural well-being.

Para 92. <redacted_name> policies and decisions should aim to achieve healthy, inclusive, and safe places which: b) are safe and accessible, so that crime and disorder, and the fear of crime, do not undermine the quality of life or community cohesion – for example using attractive, well-designed, clear, and legible pedestrian and cycle routes, and high-quality public space, which encourage the active and continual use of public areas.

Para 97. <redacted_name> policies and decisions should promote public safety and take into account wider security and defence requirements by:

a) anticipating and addressing possible malicious threats and natural hazards, especially in locations where large numbers of people are expected to congregate. Policies for relevant areas (such as town centre and regeneration frameworks), and the layout and design of developments, should be informed by the most up-to-date information available from the police and other agencies about the nature of potential threats and their implications. This includes appropriate and proportionate steps that can be taken to reduce vulnerability, increase resilience and ensure public safety and security; and

Para 112. Within this context, applications for development should: c) create places that are safe, secure, and attractive – which minimise the scope for conflicts between pedestrians, cyclists, and vehicles, avoid unnecessary street clutter, and respond to local character and design standards. Section 12. Achieving well-designed places

Para 130. <redacted_name> policies and decisions should ensure that developments:

f) create places that are safe, inclusive, and accessible and which promote health and well-being, with a high standard of amenity for existing and future users; and where crime and disorder, and the fear of crime, do not undermine the quality of life or community cohesion and resilience. Crime and Disorder Act, <redacted_date> This report is submitted in the interests of crime prevention and addresses our collective responsibilities under: Section 17 - Duty to consider crime and disorder implications. (1) Without prejudice to any other obligation imposed on it, it shall be the duty of each authority to which this section applies to exercise its various functions with due regard to the likely effect of the exercise of those functions on, and the need to do all that it reasonably can to prevent, a) crime and disorder in its area (including anti-social and other behaviour adversely affecting the local environment); and b) the misuse of drugs, alcohol, and other substances in its area; and c) re-offending in its area. Summary South Yorkshire Police feel that the above recommendations would be beneficial to the security and safety of the site users. Therefore, it is advised that the points raised in this document should be implemented and any re-submitted plans from the applicant <redacted_name> decision and or discharge of conditions. Should you wish to discuss these recommendations or require further details on any of the points mentioned in this report please contact me on the details below. Regards <redacted_name> Designing out Crime Officer South Yorkshire Police Doncaster South Yorkshire DN1 3HX E-mail: <redacted_email>