



Consultation Response - Tree Officer

APPLICATION REFERENCE	FAKE/2026/1371/FUL
SITE	4 Foundry Court, Bessmere, South Donshire, ZZ31 4LX
DOCUMENT TYPE	Consultation response

CONSULTATION RESPONSE

Consultee: Tree Officer. Application reference: FAKE/2026/1371/FUL. Site: 4 Foundry Court, Bessmere, South Donshire, ZZ31 4LX.

This response is fictional and does not represent the view of any real statutory consultee, parish council, service area, drainage body or public authority.

COMMENTS

The submitted drawings show the car-port post positions, surfacing and roof overhang close to protected trees, but no arboricultural impact assessment or method statement has been provided.

The indicative root-protection zones overlap the works area. Excavation for posts, changes to surfacing and construction storage could affect roots and soil conditions unless a detailed no-dig and supervision strategy is supplied.

The tree officer cannot support the proposal on the current information because likely effects on nearby protected trees have not been adequately assessed.

OUTSTANDING MATTERS

The matters above would require materially revised drawings or additional technical evidence before the consultee position could change.

This is a fictional consultation response for assessment use only.