

Consultation Reply Yorkshire Water

Registered Office Yorkshire Water Services Limited Western House Halifax Road Bradford BD6 2SZ
Registered in England and Wales No. 2366682 www.yorkshirewater.com Registered Office Yorkshire Water
Services Limited Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No.
2366682 www.yorkshirewater.com Director of Development and Planning Doncaster Metropolitan Borough
Council Colonnades House Duke Street Doncaster DN1 1ER Your Ref: 94.62735.OUT Our Ref: A/03182
Yorkshire Water Services Developer Services Sewerage Technical Team PO BOX 52 Bradford BD3 7AY Tel:
<redacted_phone> Email: <redacted_email> <redacted_date> Dear Sir/Madam, 74 Market Lane, Bessacarr,
Doncaster, ZZ63 7KS - (DON) - Outline application for the erection of a detached dormer bungalow on approx
0.06ha of land with all matters reserved Thank you for consulting Yorkshire Water regarding the above
proposed development. We have the following comments: <redacted_name> If planning permission is to be
granted, the following conditions should be attached in order to protect the local aquatic environment and
Yorkshire Water infrastructure: The site shall be developed with separate systems of drainage for foul and
surface water on and off site. The separate systems should extend to the points of discharge to be agreed. (In
the interest of satisfactory and sustainable drainage) Registered Office Yorkshire Water Services Limited
Western House Halifax Road Bradford BD6 2SZ Registered in England and Wales No. 2366682
www.yorkshirewater.com Registered Office Yorkshire Water Services Limited Western House Halifax Road
Bradford BD6 2SZ Registered in England and Wales No. 2366682 www.yorkshirewater.com There shall be no
piped discharge of surface water from the development prior to the completion of surface water drainage
works, details of which will have been submitted to and approved by the sewerage undertaker. If discharge to
public sewer is proposed, the information shall include, but not be exclusive to: i) evidence that other means of
surface water drainage have been properly considered and why they have been discounted; and ii) the means
of discharging to the public sewer network at a rate not to exceed 3.5 litres per second. (To ensure that no
surface water discharges take place until proper provision has been made for its disposal) 1.) Submitted
drawings shows a proposal to connect foul water into the drainage run on adjacent curtilages to the east - this
is acceptable. 2.) The developer is proposing to discharge surface water to public sewer however, sustainable
development requires appropriate surface water disposal. a.) Yorkshire Water promote the surface water
disposal hierarchy and the developer must provide evidence to demonstrate that surface water disposal via
infiltration or watercourse are not reasonably practical before considering disposal to public sewer. b.) The
developer and LPA are strongly advised to seek comments on surface water disposal from other drainage
bodies as further restrictions may be imposed. c.) As the proposal site is currently undeveloped, no positive
surface water is known to have previously discharged to the public sewer network. Surface water discharge to
the existing public sewer network must only be as a last resort and the developer is required to eliminate other
means of surface water disposal. d.) As a last resort, and upon receipt of satisfactory evidence to confirm the
reasons for rejection of other methods of surface water disposal, curtilage surface water may discharge to
public surface water sewer at a restricted rate not to exceed 3.5 litres per second. Yours faithfully
<redacted_name> Town Planning Team