


SECTION 1 — MODEL DESCRIPTION

BUILDING DESCRIPTION

Sector	Commercial-Institutional
Building type	Education
Building subtype	Primary school, no mechanical ventilation - Small
Vintage	After 2012

3D MODEL



Three-dimensional geometric representation of the building model used for energy simulation and performance analysis.

BUILDING CHARACTERISTICS

Floor Area [m²]	1640
Climate zone	
HVAC SYSTEM	
Cooling system	/
Heating system	Electric Boiler with hydronic baseboard heaters
Ventilation system	/
Typical COP cooling	/

INSULATION & AIR TIGHTNESS

Exterior walls [W/m²/K]	0.28
Interior walls [W/m²/K]	0
Roof [W/m²/K]	0.18
Slabs [W/m²/K]	0.38
Infiltration (I_design) [m³/h/m²]	2.05

GLAZING

Glazing [W/m²/K]	2.77
SHGC	0.41


WINDOW-TO-WALL RATIO

Average [%]	27.7
-------------	------

ANNUAL END USES — ELECTRICITY [kWh]



END USE	[kWh/year]
Heating	63398
Interior Lighting	31975
Interior Equipment	13745
Fans	453
Pumps	1333
Water Systems	8061
Total End Uses	118962

MONTHLY CONSUMPTION BY END USE



Monthly energy consumption breakdown by end use, showing the contribution of heating, cooling, lighting, domestic hot water, plug loads, and auxiliary systems throughout the year.

AVERAGE DAILY PROFILE BY USAGE



Average daily consumption profile for winter and summer, showing the contribution of cooling, lighting, domestic hot water, plug loads, and auxiliary systems throughout an average winter and summer day.

ENERGY USE INTENSITY

73

kWh/m²/yr

TOTAL CONSUMPTION

118961

kWh/yr

ELECTRICITY

118962

kWh/yr

NATURAL GAS

0

kWh/yr