


SECTION 1 — MODEL DESCRIPTION

BUILDING DESCRIPTION

Sector	Commercial-Institutional
Building type	Education
Building subtype	Primary or secondary school, no mechanical ventilation - Mid-size
Vintage	Before 1970

3D MODEL



Three-dimensional geometric representation of the building model used for energy simulation and performance analysis.

BUILDING CHARACTERISTICS

Floor Area [m²]	3050
Climate zone	
HVAC SYSTEM	
Cooling system	/
Heating system	Electric Boiler with hydronic baseboard heaters
Ventilation system	/
Typical COP cooling	/

INSULATION & AIR TIGHTNESS

Exterior walls [W/m²/K]	0.72
Interior walls [W/m²/K]	0
Roof [W/m²/K]	0.28
Slabs [W/m²/K]	1.91
Infiltration (I_design) [m³/h/m²]	2.05

GLAZING

Glazing [W/m²/K]	3.52
SHGC	0.41


WINDOW-TO-WALL RATIO

Average [%]	33.5
-------------	------

ANNUAL END USES — ELECTRICITY [kWh]

END USE	[kWh/year]
Heating	246827
Interior Lighting	59464
Interior Equipment	23322
Fans	1786
Pumps	4872
Water Systems	9522
Total End Uses	345794

MONTHLY CONSUMPTION BY END USE



Monthly energy consumption breakdown by end use, showing the contribution of heating, cooling, lighting, domestic hot water, plug loads, and auxiliary systems throughout the year.

AVERAGE DAILY PROFILE BY USAGE



Average daily consumption profile for winter and summer, showing the contribution of cooling, lighting, domestic hot water, plug loads, and auxiliary systems throughout an average winter and summer day.

ENERGY USE INTENSITY

113

kWh/m²/yr

TOTAL CONSUMPTION

345792

kWh/yr

ELECTRICITY

345794

kWh/yr

NATURAL GAS

0

kWh/yr