


SECTION 1 — MODEL DESCRIPTION

BUILDING DESCRIPTION

Sector	Commercial-Institutional
Building type	Education
Building subtype	Secondary school, no cooling - Large
Vintage	Before 1970

3D MODEL



Three-dimensional geometric representation of the building model used for energy simulation and performance analysis.

BUILDING CHARACTERISTICS

Floor Area [m²]	17204
Climate zone	
HVAC SYSTEM	
Cooling system	/
Heating system	Electric Boiler with hydronic baseboard heaters for perimeter
Ventilation system	Constant air volume with recirculation and terminal reheat
Typical COP cooling	/

INSULATION & AIR TIGHTNESS

Exterior walls [W/m²/K]	0.72
Interior walls [W/m²/K]	0
Roof [W/m²/K]	0.28
Slabs [W/m²/K]	1.91
Infiltration (I_design) [m³/h/m²]	2.05

GLAZING

Glazing [W/m²/K]	3.52
SHGC	0.41


WINDOW-TO-WALL RATIO

Average [%]	19.7
-------------	------

ANNUAL END USES — ELECTRICITY [kWh]

END USE	[kWh/year]
Heating	2913993
Interior Lighting	335414
Interior Equipment	132576
Fans	312691
Pumps	67120
Water Systems	44967
Total End Uses	3806758

MONTHLY CONSUMPTION BY END USE



Monthly energy consumption breakdown by end use, showing the contribution of heating, cooling, lighting, domestic hot water, plug loads, and auxiliary systems throughout the year.

AVERAGE DAILY PROFILE BY USAGE



Average daily consumption profile for winter and summer, showing the contribution of cooling, lighting, domestic hot water, plug loads, and auxiliary systems throughout an average winter and summer day.

ENERGY USE INTENSITY

221

kWh/m²/yr

TOTAL CONSUMPTION

3806731

kWh/yr

ELECTRICITY

3806758

kWh/yr

NATURAL GAS

0

kWh/yr