


SECTION 2 — MODEL DESCRIPTION

MODEL DESCRIPTION

[illegible]

3D MODEL



Geometric visualization of the model

BUILDING CHARACTERISTICS

Floor Area	1325.0 m²
Stories	5
Climate Zone	6A
Weather	outdoor_temperature_no_year

WINDOW-TO-WALL RATIO (WWR)

FAÇADE	WWR
North	0.3
South	0.3
East	0.3
West	0.3

ENVELOPE — INSULATION & AIR TIGHTNESS

Walls Ext [W/m ² -K]	1.13
Walls Int [W/m ² -K]	2.51
Roof [W/m ² -K]	2.49
Slabs [W/m ² -K]	1.14
Glazing [W/m ² -K]	3.32
SHGC	0.66
Infiltration [m ³ /h-m ²]	13.5

ANNUAL END USES — ELECTRICITY [KWH]

END USE	KWH/YR
Heating	169148.6
Cooling	14250.1
Interior Lighting	7086.2
Exterior Lighting	3183.4
Interior Equipment	110975.9
Fans	17069.6
Total End Uses	321713.7

MONTHLY CONSUMPTION BY END USE




Figure — Disaggregated monthly profile by end use

MONTHLY CONSUMPTION BY END USE (OPE)




Figure — Disaggregated monthly profile by end use (OPE)

ENERGY USE INTENSITY

242.8

kWh/m²/yr

TOTAL CONSUMPTION

321711.0

kWh/vr

ELECTRICITY

321714.0

kWh/vr

NATURAL GAS

0

kWh/vr

SUMMARY TABLE — [TO BE DEFINED]

Placeholder — table content to be defined.
Add columns and rows as needed.

SECTION 4 — COMPARISON WITH REFERENCE DATA

PRISM CURVE






Figure — PRISM Curve · Model vs. measured data

TYPICAL DAY — SUMMER



Hourly consumption profile — summer day

TYPICAL DAY — WINTER



Hourly consumption profile — winter day