



BUSBAR- 1250A FP AL.
PHASE- 1X125X10MM AL. OR EQ.
NEUTRAL- 1X125X10MM AL. OR EQ.
EARTH- 1X50X6MM AL. OR EQ.

NOTES:
* CABLE ENTRY:
INCOMING- BOTTOM/TOP
OUTGOING- BOTTOM/TOP

	COMMENTS:		COMMENTS:	DRAWN BY :	Akash Chaturvedi	ENERGY SOLUTION 201/SHIVA PURAM PANIYALA ROAD ROORKEE HARIDWAR- 249403	TITLE :	GA DRAWING_MAIN LT PCC CUM APFC, PANEL	QTY.
				CHK BY :	Santosh Gputa		1 NOS		
				SCALE :	N.T.S.		DWG. NO		
R1		R1		DATE :	07/10/2024		ES/435/		
REV. NO.		REV. NO.		ALL DIMENSSION IN MM			SHEET NO.		
							1 OF 2		