



Tulsa Metropolitan Area Planning Commission

Project Anthem

Hearing Date: August 7, 2024

Prepared by: Austin Chapman

achapman@cityoftulsa.org

918-596-7597

Owner and Applicant Information

Applicant: Olsson, Inc. – John Flaxbeard


Property Owner: Atmoss LLC

Property Location

West of the Creek Turnpike between East 11th Street
South and East 21st Street South

Location within the City of Tulsa

(shown with City Council districts)



Elected Representatives

City Council: District 6, Christian Bengel

County Commission: District 1, Stan Sallee

Public Notice Required

Mailed Notice to adjacent property owners a
minimum of 10 days in advance

Staff Recommendation

Staff recommends approval subject to conditions.

Request Summary

Preliminary plat approval for Project Anthem.

Tract Size: ±339.11 acres

Zoning

Existing Zoning: IL

Existing Overlays: None

Use

Current Use: Vacant

Proposed Use: Data Center campus with supporting ancillary
buildings.

Comprehensive Plan Considerations

Land Use

Land Use Plan: Employment

Small Area Plans: East Tulsa

Development Era: Future Growth

Transportation

Major Street & Highway Plan: East 11th St. S. and E. 21st St
are both secondary arterial streets. The Creek Turnpike is
classified as a Freeway.

planitulsa Street Type: N/A

Transit: Not available.

Existing Bike/Ped Facilities: None.

Planned Bike/Ped Facilities: None.

Traffic on Nearest Arterials (per lane)

North: E. 11th St. S. : Very Low

East: N/A

South: E. 21st St. S. : Very Low

West: S. 193rd E. Ave. : Low

Environment

Flood Area: City of Tulsa Regulatory Flood Plain is present
on site.

Detailed Staff Recommendation

The plat consists of 1 lot, 1 block, ±339.11 acres. Staff recommends **approval** of the preliminary subdivision plat subject to the following conditions provided by the Technical Advisory Committee (TAC) and all other requirements of the Subdivisions Regulations. A City of Tulsa release letter is required prior to final plat approval. TAC Conditions:

Zoning:

- The proposed subdivision meets the standards of IL zoning district.

Engineering Graphics

- Submit subdivision control data sheet with the final plat.
- Remove contours on final plat submittal.
- In the plat subtitle add "State of" before Oklahoma.
- Provide the mailing address under the Owner information.
- Provide an engineer and surveyor heading/section that has the name of the business, mailing address, name of the engineer/surveyor, CA number with expiration date, phone number, and email address.
- Provide the individual lot addresses on the face of the plat.
- Consider having a Subdivision section that list out acreage, square feet, zoning, number of lots, number of blocks, reserve areas, etc.
- In the Location Map show the Creek Turnpike and label the section line streets on the perimeter of the section. Those being E 11th St S, E 21st St S, S 193rd E Ave, and S 225th E Ave. Label all other land in the section as "unplatted".
- Provide graphically on the face of the plat the address disclaimer/caveat.
- Provide the date of preparation on the face of the plat. Typically this is shown at the lower right-hand corner of the page.
- Under the Basis of Bearings information include the coordinate system used. Provide a bearing angle preferably shown on the face of the plat. See example below.

BASIS OF BEARINGS

Horizontal Datum based upon NAD 83 (1993)
Oklahoma State Plane Coordinate System North
Zone 3501 Vertical Datum based upon NAVD 88
using N. 88°42'00" E. as the North line of the
Northwest Quarter of Section 28, Township 19
North, Range 14 East of the Indian Base and
Meridian was used as the bearing for this survey.

- Add signature block for officials to sign to the face of the plat.
- Provide on the face of the plat the last date of survey site visit. If this was a range of dates provide those.
- There are several hatch patterns used on the north end of the plat. Add to the legend.

Addressing

- Add the following address to the plat pdf: Lot 1: 21304 E 11TH ST S

Article 5: Design and Improvements

Required Infrastructure and Public Improvements (5-020)

- Site will require infrastructure improvements for sanitary sewer and water main extensions, roads, driveways, and sidewalks, and storm water runoff mitigation through detention facilities or other means. A pre-development meeting for the first phase covering initial utility extensions and road was held on 07/08/2024.
- This preliminary plat does not reflect a separate lot or reserve for the AEP facility that is planned to be installed on the south side of the property. If multiple lots are proposed, public infrastructure requirements for all lots must be met. Reserve language will determine how reserves are handled with respect to utilities.

Streets (transportation) (5-060)

- E. 11th St. and E. 21st St. are both secondary arterial streets which require a total ROW of 100' or 50' from the section line/centerline of the street.

Streets (fire) (5-060)

- Please ensure the proposed bridge meets Title 14 T Fire Prevention Code of being able to withstand 88,000 pounds.

Sidewalks (5-070)

- Sidewalks are required along all City of Tulsa streets and should be either 2' behind the curb or 18" from the property line.

Protection From Flooding and Other Natural Hazards (Floodplain) (5-090)

- Site includes no federal flood plains per FEMA FIRM Panel 40145C0040J. The City of Tulsa regulatory floodplains are present per City of Tulsa atlas panel 172 and are to be appropriately bounded by easements shown.

Stormwater Management (5-100)

- Future development will require detention, other mitigation runoff, or approved recommendation for Fee-in-lieu-of detention. Multiple proposed detention easements appear to be shown on the face of plat without callouts or labelling. The outlet structures from the ponds should not be in the detention easements, as those outlet pipe structures will be privately held.

Sewage Disposal (5-130)

- Site is not adjacent to public sanitary sewer or 250' from a sewer line. This project is to be served for sanitary sewer by a capital project. The capital project being complete, and functioning is a condition attached to this plat.

Water (5-140) lines

- The extension of public water main line across property frontage abutting public roadways are required before the plat is approved.

Easements (5-150)

- No Comments.

Streets and Stormwater

- I do not see any perimeter easements displayed on the plat, those will need to be referenced if dedicated by separate instrument.
- Per NFIP CRS requirements, plot boundary of floodplain on face of plat to show it is contained within the OD/E.

- Southeast corner – Clarify “Find” or “Found” for the described aluminum monumentation.
- Any offsite easements to cover public infrastructure extensions required by this project will need to be filed and the recording information shown on the face of the plat prior to filing the plat.
- Recording information for all easements “By Separate Instrument” that contain public infrastructure will need to be included on the final plat.
- Many easements that do not specify what kind of easement. Please clarify.
- Easements that are created via this plat need to have dimensions.
- Provide metes and bounds for ROW dedication where it is not parallel to existing ROW and can be described with a simple dimension.
- It appears that ROW is to be dedicated on the south side, along E. 21st Street. Clearly dimension the proposed ROW dedication.
- Statutory ROW call outs should be based on section line, not total ROW.

Deed of Dedication:

-Legal to comment after submittal of Final Plat.

Comprehensive Plan Considerations

Land Use Plan

The subject property is designated as Employment by the Tulsa Comprehensive Plan. Employment The employment designation is intended to accommodate offices, warehousing and storage, manufacturing and assembly, and industrial processes. The “Industrial Site Suitability” map corresponds to the Employment land use designation and indicates where uses that are potentially incompatible with sensitive land uses are best suited to locate. This directs industrial uses to particular areas of the city while discouraging industrial in close proximity to Neighborhood areas.

Surrounding Properties:

<i><u>Location</u></i>	<i><u>Existing Zoning/Overlay</u></i>	<i><u>Existing Land Use Designation</u></i>	<i><u>Existing Use</u></i>
North	AG	Neighborhood/ Regional center (Partially Unincorporated Wagoner County)	Residential/ Agricultural
East	AG	Regional Center	Undeveloped Agricultural
South	AG	Employment	Undeveloped Agricultural
West	AG	Neighborhood/ Employment	Summer Camp/ Agricultural

Small Area Plans

The subject properties are not located within a small area plan.

Development Era

The subject property is located is undeveloped and defined as a Future Growth Area. These areas of the city have yet to develop beyond agricultural uses and present opportunities to ensure the pattern of development is efficient and fiscally responsible. The two primary regions that have yet to develop are the northwest corner of the city, which is all located within Osage County and where the Gilcrease Expressway will connect, and the far east area of the city from roughly 145th E Ave. to beyond the Creek Turnpike.

Transportation

Comprehensive Plan Street Designation: Not Classified.

Arterial Traffic per Lane:

Arterial Traffic - North (E Admiral Pl - 2,518 Vehicles per Lane)

Arterial Traffic - East (N/A)

Arterial Traffic - South (E 11th St S - 395 Vehicles per Lane)

Arterial Traffic - West (S 193rd East Ave - 5,216 Vehicles per Lane)


Exhibits

Case map

Aerial

Tulsa Comprehensive Plan Land Use Map

Date: _____



OWNER'S OF RECORD
Fair Oaks Ranch, L.L.C.
Wagoner, OK 74467

FEMA 100-YEAR FLOODPLAIN:
The proposed development is in the Zone X of firm map 40145C0040J, area determined to be outside the 500-year flood and protected by levee from 100-year flood, with an effective date of 09.30.2016

ZONING: IL
Industrial, Document # 25211

LEGEND

	SECTION CORNER
	MONUMENT W/ LABELED DESCRIPTION
	PROPERTY LINE
	LOT LINES
	STATUTORY R/W LINE
	EASEMENT LINES
	SECTION LINE
	QUARTER LINE
	PROPOSED R/W LINE
	TURNPIKE R/W LINE
	RIGHT-OF-WAY EASEMENT BY STATUTE
	STAT. R/W

CONTROL POINT TABLE - BASED ON GROUND DISTANCES, OKLAHOMA STATE PLANE COORDINATES NORTH ZONE				
POINT NUMBER	NORTHING(ft)	EASTING(ft)	ELEVATION(ft)	DESCRIPTION
2	420483.0035	2639901.0096	696.35	1/2" REBAR
15	420436.6829	2637681.9409	706.64	1/2" REBAR
24	425641.3053	425641.3093	679.50	1/2" REBAR
100000	425278.3964	263768.4893	675.13	"X" IN TOP OF CONCRETE
101000	425022.8033	2637396.0511	692.26	"X" IN TOP OF CONCRETE

A TRACT OF LAND LOCATED IN SECTION 8, TOWNSHIP 19 NORTH, RANGE 15 EAST OF THE INDIAN BASE AND MERIDIAN, WAGONER COUNTY, STATE OF OKLAHOMA, ACCORDING TO THE UNITED STATES GOVERNMENT SURVEY THEREOF, SAID TRACT OF LAND BEING MORE PARTICULARLY DESCRIBED AS FOLLOWS:

[illegible]

1. This Survey meets the requirements of the Oklahoma Minimum Standards for the Practice of Land Surveying which was adopted by the Board of Registration for Professional Engineers and Land Surveyors November 1, 2020.
2. **BASIS OF BEARINGS:** Measured N 01°35'51" W along the west line of said SW/4 8-T19N-R15E: Oklahoma Coordinate System of 1983 North Zone as established by use of ODOT continuously operating GNSS RTK Network.
3. All distances shown hereon are based on Ground Distances measured in U.S. Survey Feet.
4. Field work was completed on April 10, 2024.

I, Darrel Ray Mason, a registered Land Surveyor, do hereby certify that a careful survey has been made under my supervision on the above described property as shown hereto and there are no encroachments except if shown hereon. This survey was made for the above stated purpose only and no other responsibility is hereby assumed. Dated in the County of Wagoner, Oklahoma on this day of 6/27/2024




Darrel Ray Mason
OK PLS NO. 1690 - Expires August 31, 2024
OK CA NO. 2483 - Expires June 30, 2025



LEGEND

	JURISDICTIONAL WATER
	NON JURISDICTIONAL WATER
	REGULATORY AVOIDANCE AREA
	AVOIDANCE AREA
	PROPOSED FENCE
	PROPOSED RIGHT-OF-WAY DEDICATION
	PROPOSED STATUTORY RIGHT-OF-WAY AREA
	PROPERTY BOUNDARY
	TRANSMISSION EASEMENT TO ON-SITE SUBSTATION
	STORMWATER BASIN
	SECURITY PATH
	CONSTRUCTION LOGISTICS AREA


BUILDING 1 PARKING TABLE	
TOTAL STALLS REQUIRED	62
TOTAL NUMBER OF PARKING STALL PROVIDED	74
NUMBER OF STANDARD STALLS	58
ADA SPACES	4
EV SPACES	8
FEV SPACES	4
EXPECTING MOTHERS	0
GOLF CART SPACES	4
BUILDING 2 PARKING TABLE	
TOTAL STALLS REQUIRED	42
TOTAL NUMBER OF PARKING STALL PROVIDED	82
NUMBER OF STANDARD STALLS	66
ADA SPACES	4
EV SPACES	8
FEV SPACES	4
EXPECTING MOTHERS	0
GOLF CART SPACES	4
BUILDING 3 PARKING TABLE	
TOTAL STALLS REQUIRED	10
TOTAL NUMBER OF PARKING STALL PROVIDED	10
NUMBER OF STANDARD STALLS	9
ADA SPACES	1
EV SPACES	0
FEV SPACES	0
EXPECTING MOTHERS	0
GOLF CART SPACES	0
BUILDING 4 PARKING TABLE	
TOTAL STALLS REQUIRED	22
TOTAL NUMBER OF PARKING STALL PROVIDED	95
NUMBER OF STANDARD STALLS	59
ADA SPACES	4
EV SPACES	10
FEV SPACES	10
VISITOR PARKING SPACES	10
EXPECTING MOTHERS	2
GOLF CART SPACES	6
GUARDHOUSE PARKING TABLE	
TOTAL STALLS REQUIRED	1
TOTAL NUMBER OF PARKING STALL PROVIDED	4
NUMBER OF STANDARD STALLS	3
ADA SPACES	1
EV SPACES	0
FEV SPACES	0
EXPECTING MOTHERS	0
GOLF CART SPACES	0
PARKING REQUIREMENTS	
REQUIRED:	129 STALLS
PROVIDED:	265 STALLS
ACCESSIBLE PARKING	
REQUIRED:	7
PROVIDED:	14



F:\2022\20201-02500\022-02495-3-01-Design\AutoCAD Preliminary Plans\Sheets\SDMC_UTL01_02202495.dwg
DATE: 06/27/2024 10:39am USER: jbarry



LEGEND




SITE NOTES

- PROVISIONS FOR TEMPORARY UTILITIES ARE NOT PROVIDED AT THIS TIME. CONSTRUCTION LOGISTICS PLANS REQUIRED FOR COORDINATION AND NOT AVAILABLE AT THIS TIME.
- UTILITY CAPACITY:
SANITARY SEWER
TREATMENT CAPACITY 103 MGD WITH 1,960 MILES OF UNDERGROUND TRUNK AND COLLECTION SYSTEM, 25 LIFT STATIONS, AND 4 MAJOR WWTFS.

WATER
RAW WATER SOURCE: SPAVINAWIEUCHA AND OOLAGAH LAKES, LAKE HUDSON. RAW WATER IS STORED IN YAHOLA LAKE (2.0 BILLION GALLON CAPACITY) NEAR MOHAWK WATER TREATMENT PLANT AND UNRUH RESERVOIR (1.2 BILLION GALLON CAPACITY) NEAR A.B. JEWELL WATER TREATMENT PLANT.
TREATED WATER: THE MOHAWK WATER TREATMENT PLANT HAS A 100-MGD CAPACITY. A.B. JEWELL WATER TREATMENT PLANT HAS 120 MGD CAPACITY. SYSTEM HAS 105 MGD STORAGE CAPACITY.
DISTRIBUTION SYSTEM PUMPAGE IS SET AT 210 MGD BETWEEN THE TWO TREATMENT PLANTS.

POWER
2-138 KV LINES ALONG THE WEST SIDE OF THE PROJECT SITE.
2-161 KV LINES TOWARDS NORTH FROM THE SITE.



olsson

7301 West 133rd Street
Suite 200
Overland Park, KS 66213
olsson.com
TEL 913.381.1170
FAX 913.381.1174

BY

DATE

NO.

DESCRIPTION

REVISIONS

UTILITY PLAN

PROJECT ANTHEM

30% ON-SITE IMPROVEMENTS

TULSA, OK

drawn by: JLC

designed by: JLC



project no: 022-02495A

date: 06/27/2024

SHEET

3 of 3

139




Subject
Tract


Project Anthem

Note: Graphic overlays may not precisely align with physical features on the ground.

Aerial Photo Date: 2021



13.10



0 200 400
Feet




Subject
Tract


Project Anthem

Note: Graphic overlays may not precisely align with physical features on the ground.

Aerial Photo Date: 2021



13.11



Feet
0 200 400

Project Anthem

13.12

