

SUMAS Water Treatment — Daily Logbook

Print one page per shift · Kamloops, BC

DATE

OPERATOR

TIME IN

TIME OUT

⚠ Before you start (one-time, until done)

☐ Carbon vessel cleaned out (old sludge/carbon removed)

Checks During the Shift

Time	Where	pH	Clear / Cloudy	Chemicals Added	Notes

"Where" = C Can, outdoor weir tank, indoor weir tank/settling bins, bag filter, carbon vessel, or storage tank. pH only really matters at the C Can (below 8 → add lime).

Starting the Pump (each cycle)

☐ Ozone turned ON first
☐ Intake pipe valve opened
☐ Storage tank valve opened

Sludge Removal (end of cycle)

☐ Outdoor weir tank pumped out
☐ Indoor settling bins pumped out
☐ Filter press run — bins filled: ____

Notes / Issues / What the Next Operator Should Know

SIGNATURE