

Daily Logbook — Print This Page Each Shift

Starting Monday. Fill in by hand, on paper, every shift. One copy of this page per shift.



One-time, before you log anything else

- ☐ **Carbon vessel (SRS-CV-15) cleaned out** — sludge/old carbon removed. Don't start treating water until this is checked off. (Section 6.5)
-

Shift Info

Date	Operator	Time in	Time out

Process Checks (fill in a new row each time you check something — usually a few times per shift)

Time	Where (C Can / Outdoor weir tank / Indoor weir tank– settling bins / Bag filter / Carbon vessel / Storage tank)	pH	Clear/cloudy? (or NTU if you have the meter)	Lime added? (Y/N + # bags)	PACl added? (amount/setting)	Flocculant added? (amount/setting)	Notes

Before starting the intake pump (do this every time you start a

pumping cycle)

Ozone turned ON first? (Y/N)	AERQUS flow meter ball moving / SCFH reading	Intake pipe valve opened? (Y/N)	Storage tank valve opened? (Y/N)

End-of-cycle sludge removal (AODD pump)

Pumped sludge from outdoor weir tank? (Y/N)	Pumped sludge from indoor weir tank/settling bins? (Y/N)	Ran filter press? (Y/N)	# of cake bins filled

Notes / Issues / Action Taken

Sign-off

Signature: _____

Why these fields — see Section J (Logbook and Testing) and Section 1.6a in the full manual (`sections/00_orientation.md` , `sections/01_daily_operations.md`) for the full explanation.