

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022 as amended
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE

FT/EIC

1259900001393

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended
(IET Wiring Regulations 18th Edition)



Client Details

Client	Oliver Yerbury-Hodgson	Installation	Oliver Yerbury-Hodgson
Address	55 Avon Street WARWICK	Address	55 Avon Street WARWICK
Postcode	CV34 4PX	Postcode	CV34 4PX

Details of the Installation

Description of premises Residential or Similar ☒ Commercial ☐ Industrial ☐ Date of original installation 1995

Installation is New ☐ Addition ☒ Alteration ☐ Records Available Yes ☐ No ☒ RCD Risk assessment attached ☐

Description of the installation
Garden office electrical supply and final circuits of sockets radial circuit and lighting circuit

Extent of the installation covered by this certificate
Garden office distribution circuit and garden office final circuits

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
n/a

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
n/a

Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2024 except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	Sam Ward Electrical Ltd	Position	Director
Inspector Name	Samuel Ward	Date	22/04/2025
Address	39 Kings Road , Kings Heath Warwickshire B14 6TU	Scheme No.	63406
		Branch No.	
		Signature	
Reviewed By	Samuel Ward	Reviewed By	
Reviewed By Date	22/04/2025	Signature	

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 5 years

ELECTRICAL INSTALLATION CERTIFICATE

FT/EIC 1259900001393

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended
(IET Wiring Regulations 18th Edition)



Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S ☒ TN-C-S ☐ TT ☐ Other ☐ If Other please specify

Number & Type of live conductors AC ☒ DC ☐ No. of phases No. of wires

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ V Nominal frequency, f⁽¹⁾ Hz Confirmation of polarity ☒

Prospective fault current, I_{pf} ⁽²⁾ kA External loop impedance, Z_e ⁽²⁾ Ω

Supply Protective Device BS (EN) Type Rated Current A

No. of Additional Supplies

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Distributors facility ☒ Installation Earth Electrode ☐

Location Electrode resistance to earth Ω Maximum Demand (load) Amps ☒ KVA ☐

Main Protective Conductors Material csa (✓) or Value (✓) or Value

Earthling Conductor Copper 16 mm² Continuity Verified ☒ Ω Connection Verified ☒ Ω

Protective Bonding Conductor Copper 10 mm² Continuity Verified ☒ Ω Connection Verified ☒ Ω

Main Supply Conductor Material csa (connection / continuity) (✓) or Value (✓) or Value

Copper 25 mm² Water installation ☒ Ω To structural steel Ω

Main Switch Location Gas installation pipes ☒ Ω To lightning protection Ω

Oil installation pipes Ω Other Ω

Fuse/device rating or setting Switch A Voltage rating V BS(EN) No. of Poles Current Rating A

If RCD main switch: Rated residual operating current I Δn mA Rated time delay ms Measured operating trip time ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

satisfactory for continued use

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory			Indicates the inspection is not applicable to a particular item		
1.0	Condition of consumer's intake equipment (visual inspection only)	✓	8.0	Circuits (Distribution and Final)	✓
2.0	Parallel or switched alternative sources of supply	NA	9.0	Isolation and switching	✓
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	✓	10.0	Current-using equipment (permanently connected)	✓
4.0	Basic Protection	✓	11.0	Identification and notices	✓
5.0	Protective measure other than ADS	✓	12.0	Location(s) containing a bath or shower	NA
6.0	Additional protection	✓	13.0	Other special installations or locations	NA
7.0	Distribution equipment	✓	14.0	Prosumer's low voltage electrical installation(s)	NA

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name: Signature

Date:

FT/EIC 1259900001393

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended (IET Wiring Regulations 18th Edition)



<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Client Name</td> <td>Oliver Yerbury-Hodgson</td> </tr> <tr> <td>Client Address</td> <td>55 Avon Street WARWICK</td> </tr> <tr> <td>Client Postcode</td> <td>CV34 4PX</td> </tr> </table>	Client Name	Oliver Yerbury-Hodgson	Client Address	55 Avon Street WARWICK	Client Postcode	CV34 4PX	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Installation Address</td> <td>Oliver Yerbury-Hodgson, 55 Avon Street, WARWICK</td> </tr> <tr> <td>Postcode</td> <td>CV34 4PX</td> </tr> </table>	Installation Address	Oliver Yerbury-Hodgson, 55 Avon Street, WARWICK	Postcode	CV34 4PX
Client Name	Oliver Yerbury-Hodgson										
Client Address	55 Avon Street WARWICK										
Client Postcode	CV34 4PX										
Installation Address	Oliver Yerbury-Hodgson, 55 Avon Street, WARWICK										
Postcode	CV34 4PX										
Distribution board details - Complete in every case SPD Details: Type(s)* T1 ☐ T2 ☐ T3† ☐ N/A ☒ Location Basement Designation DB2 No. of ways 2	Complete only if the distribution board is not connected directly to the origin of the installation Overcurrent protective device Supply to distribution board is from for the distribution circuit: No. of phases 1 BS(EN) Type Rating A Nominal voltage V RCD BS(EN) Type Rating IΔn mA										

[illegible]

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the chance to Schedule of Test Results

FT/EIC 1259900001393

Requirements for Electrical Installations
BS7671 :2018+A2:2022 as amended (IET Wiring Regulations 18th Edition)



Client Name	Oliver Yerbury-Hodgson	Installation Address	Oliver Yerbury-Hodgson, 55 Avon Street, WARWICK
Client Address	55 Avon Street WARWICK	Postcode	CV34 4PX
Client Postcode	CV34 4PX		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details: Type(s)*	T1 ☐ T2 ☒ T3† ☐ N/A ☐	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from Sub Mains(DB2, 1/S)
Location	Garden office	No. of phases	1 BS(EN) 60898 MCB Type B Type B Rating 32 A
Designation	DB3	Nominal voltage	230 V RCD BS(EN) N/A Type n/a Rating N/A IΔn mA
No. of ways	2		

[illegible]

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
j: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the chance to Schedule of Test Results

