Inverted MAML Card 1: Round 14 Thermal Bit-Slicing Report

Hardware: Card 1 (T120+T20, 1k/2.2k) | **FW:** v2.2-MAML (0x20261030) | **Params:** 40% PWM, K=1, LR=0.055, L2=1920, Mom=0.85, Clamp=±85 LSB

1. Round 14 Summary & Cumulative Comparison (R1–R13)


• **Cold Verification:** Phase 1 ON = **9.45 b**, Phase 2 OFF = **9.45 b** (W8=0 strictly).

• **Round 14 Detrended Trend Metrics:** Lift vs E_base = **+1.12 b**, Loss Ratio = **1.78x**, Climb = **+1.06 b**, Jitter = **0.43 b**, Recovery = **0.50**, Score = **+2.645**.

Rnd	LR	L2	Mom	Clamp	Lift	LossR	Climb	Jitt	Recov	Score
R6dc_fix	0.055	1792	0.8	±90	+0.99b	1.72x	+1.02b	0.40b	0.00	+1.770
R7dc_fix*	0.055	2048	0.85	±75	+1.04b	1.74x	+1.17b	0.40b	0.50	+2.665
R8dc_fix	0.055	2048	0.85	±75	+1.16b	1.85x	+0.68b	0.42b	0.00	+1.855
R9dc_fix	0.055	1920	0.85	±75	+0.81b	1.59x	+0.66b	0.38b	0.50	+1.756
R10dc_fix	0.055	1920	0.85	±78	+0.96b	1.67x	+1.13b	0.40b	0.00	+1.898
R11dc_fix	0.055	1920	0.85	±80	+0.95b	1.70x	+0.98b	0.42b	0.00	+1.810
R12dc_fix	0.055	1920	0.85	±82	+1.04b	1.75x	+0.83b	0.42b	0.00	+1.721
R13dc_fix	0.055	1920	0.85	±85	+1.12b	1.78x	+1.06b	0.43b	0.50	+2.645

2. Phase-by-Phase Telemetry (3,921 Pairs)

Phase	Regime	N	Start->Late (Mean)	Δ vs E_base	Loss Start->Late	W8 Pk [M,L]	W3 Pk	W8 nz
P1	Cold / Regler ON	314	7.65->8.14 (8.10b)	-	38104->26114	[85,85]	22	314
P2	Cold / Regler OFF	299	7.93->7.93 (7.90b)	-	32245->44391	[0,0]	0	0
P3	Warm / Regler ON	1048	8.21->7.88 (8.08b)	+1.00 b	24480->32744	[85,85]	25	1048
P4	Warm / Regler OFF	936	6.70->6.21 (6.40b)	+0.03 b	61322->79126	[0,0]	0	0
P5	Warm / Regler ON	844	6.43->6.99 (7.04b)	+1.20 b	73277->54033	[85,85]	28	844
P6	Warm / Regler OFF	480	5.72->5.55 (5.63b)	+0.02 b	99142->110679	[0,0]	0	0



3. All W(8) (7x6 MSB+LSB) & W(3) (8x6 MSB+LSB) Weight Dynamics — Round 14

• **Full 180-Synapse Per-Pair Capture:** Every individual weight in **Matrix 8 MSB (42 weights)**, **Matrix 8 LSB (42 weights)**, **Matrix 3 MSB (36 active + 12 clock)**, and **Matrix 3 LSB (36 active + 12 clock)** is plotted below across all columns `Col 0..5`. W(8) enforces anti-windup clamping at ±85 LSB, while W(3) rows 0–5 stay within ±28 LSB so rows 6–7 clock staircases remain locked at ±40 LSB.

Round 14 Full Hardware Weight Telemetry: ALL 84 W(8) [7x6 MSB+LSB] & ALL 96 W(3) [8x6 MSB+LSB] Synapses

