

Accessibility review: Natural History Museum

****Observer:**** Tasnimah Uddin

****Date:**** 2026-05-11

****Overall compliance:**** 43% of rated items met (6 met, 2 not met, 6 partial, 3 N/A)

Audio/visual & interactives

-  All videos and audio programs are captioned or have printed scripts — ****Partial****
 - > No captions on videos
-  Silent audiovisuals labelled to confirm no audio is being missed — ****N/A****
-  Audio description available for image-based content — ****Not met****
-  Interactive controls reachable from a wheelchair (max. 48 in. height) — ****Partial****
 - > There are no controls but there were a few headphones for listening to audios
-  Controls usable one-handed — no tight grip or twisting required — ****N/A****
 - > no controls displayed for audio visuals
-  Touch targets at least 3 in. in diameter — ****N/A****
-  Instructions provided in both print and audio formats — ****Partial****
-  No furniture or objects blocking access to interactives — ****Met****
-  Assistive listening system available in programming spaces — ****Not met****

Seating & furniture

-  Seating provided in every gallery (or immediately adjacent) — ****Met****
 - > seats were in every floor, and exhibit. along with benches
-  At least 50% of seats are accessible — ****Met****
-  Seats have both back and arm support; seat height 17–19 in. — ****Partial****
 - > no arm support
-  Space for wheelchair users beside fixed seating — ****Partial****
-  Seats clearly visible — contrast with floors and walls — ****Met****
-  Seats do not block pathways or interactive controls — ****Met****
-  Display cases have cane-detectable lower edges (at or below 27 in.) — ****Met****