

SCHEDULE B4 RECEIPT GAS SPECIFICATION

Gas will be deemed to conform to the Receipt Gas Specification at the Receipt Point if it meets, when tendered at the Receipt Point, in all respects, the following specifications:

1. Composition

	Minimum	Maximum
a. Hydrocarbon dew point (Note 1) -		10 °C (50 °F) @ 41 bar (600 psig)
b. Water content (Note 2) -		7 lbs per MMscf
c. Methane	85	95 % by volume
d. Ethane	-	10 % by volume
e. Propane	-	8 % by volume
f. Butane + paraffin (C4+)	-	5 % by volume
g. H ₂ S	-	4 ppm by volume
h. Total sulfur	-	28 ppm by volume
i. CO ₂	-	4 % by volume
j. N ₂	-	3 % by volume
k. O ₂	-	10 ppm by volume
l. Total inert (CO ₂ + N ₂)	-	7 % by volume

2. Heating value and Wobbe

a. Higher Heating Value	1000	1150 Btu per scf
b. Wobbe index (HHV basis)	47	52 megajoules per m ³

3. Receipt temperature

Temperature	10 °C (50 °F)	49 °C (120 °F)
-------------	---------------	----------------

4. Solids and liquids

- a. Free by normal commercial standards of objectionable odours, dusts, solid or liquid matter, waxes, gums and gum forming constituents, or aromatic hydrocarbons which might cause injury to or interfere with proper operation of all equipment through which it flows.

- b. Free of water and hydrocarbons in liquid form upon receipt in to the WAGP, and at the normal operating temperature and pressure in the WAGP. In addition, the Gas shall not contain any hydrocarbons which might condense to free liquids under normal WAGP operating conditions.

Note 1. A standard gas analysis of C6+ is not acceptable for dew point calculation unless it is known that heavier hydrocarbons (C7, C8, etc) are not present.

Note 2. The water content of Gas shall be determined in lbs per MMscf on a daily basis. If an in-line electronic moisture analyzer is utilized the testing must conform with ASTM International standard D5454, Standard Test Method for Water Vapor Content of Gaseous Fuels Using Electronic Moisture Analyzers. If manual samples are utilized the testing must conform to the latest versions of ASTM International standard D1142, Standard Test Method for Water Vapor Content of Gaseous Fuels by Measurement of Dew-Point Temperature, and ASTM International standard D4888, Standard Test Method for Water Vapor In Natural Gas Using Length-of-Stain Detector Tubes. All measurement standards referred to in this **Schedule B4** shall initially be the version in existence as at the date this Access Code. Transporter shall notify WAGP Authority and Shippers prior to adopting any change or revision to any listed measurement standard in this **Schedule B4**.

SCHEDULE B5 DELIVERED GAS SPECIFICATION

Gas will be deemed to conform to the Delivered Gas Specification at the Delivery Point if it meets the following specification, or such other specification as may be agreed pursuant to a Gas Transportation Agreement.

1. Composition

	Minimum	Maximum
a. Water content	-	7 lbs per MMscf
b. Methane	85	100 % by volume
c. Ethane	-	10 % by volume
d. Propane	-	8 % by volume
e. Butane + paraffin (C4+)	-	5 % by volume
f. H ₂ S	-	4 ppm by volume
g. Total sulfur	-	28 ppm by volume
h. CO ₂	-	8 % by volume
i. N ₂	-	6 % by volume
j. O ₂	-	10 ppm by volume
k. Total inert (CO ₂ + N ₂)	-	12 % by volume

2. Heating value and Wobbe

a. Higher Heating Value	950	1150 Btu per scf
b. Wobbe index (HHV basis)	47	52 megajoules per m ³

3. Delivery temperature

Temperature	5 °C (41 °F)	49 °C (120 °F)
-------------	--------------	----------------

4. Solids

Free by normal commercial standards of objectionable odours, dusts, solid or liquid matter, waxes, gums and gum forming constituents, or aromatic hydrocarbons which might cause injury to or interfere with proper operation of all equipment through which it flows.