

#	Getter (EHSMonitor)	Message ID (hex)	Canonical name (meaning)	Unit	Indoor / Outdoor	Confidence
1	getVAR_out_sensor_top1	0x8280	Compressor top temperature	°C (×0.1 in raw)	Outdoor	HIGH
2	getVAR_out_sensor_discharge1	0x820A	Discharge (disch) line temperature	°C (×0.1)	Outdoor	HIGH
3	getVAR_out_sensor_suction	0x821A	Suction (refrigerant) temperature	°C (×0.1)	Outdoor	HIGH
4	getVAR_out_sensor_airout	0x821C	Ambient / air-out temperature	°C (×0.1)	Outdoor	HIGH
5	getVAR_out_sensor_condout	0x821E	Condenser outlet temperature	°C (×0.1)	Outdoor	HIGH
6	getVAR_out_sensor_eviout	0x8220	Evaporator outlet temperature (or EVI out)	°C (×0.1)	Outdoor	MED

7	getVAR_out_sensor_ct1	0x8217 (or 0x82??)	Compressor current (or CT sensor 1)	A (×0.1)	Outdoor	MED
8	getVAR_out_sensor_highpress	0x8206	High-side pressure	bar (×0.1)	Outdoor	MED
9	getVAR_out_sensor_lowpress	0x8208	Low-side pressure	bar (×0.1)	Outdoor	MED
10	getVAR_out_sensor_IPM1	0x8254	IPM (inverter power module) temperature	°C (×0.1)	Outdoor	MED
11	getVAR_out_sensor_dclink_voltage	0x82?? (likely 0x82??)	DC-link voltage	V	Outdoor	LOW
12	getVAR_out_sensor_doubletube	0x82A? (unknown)	Possibly dual-tube sensor reading	°C	Outdoor	LOW
13	getVAR_out_sensor_suction2_1sec	0x82??	Fast suction sensor read	°C	Outdoor	LOW
14	getVAR_out_sensor_top1	0x8280	(duplicate): compressor top temp	°C	Outdoor	HIGH

15	getVAR_out_load_comp1 (or getENUM_out_load_comp1)	0x8237 / 0x8236	Compressor electrical power or current	W or A	Outdoor	MED
16	getVAR_out_load_fanrpm1	0x82E3 (fan rpm)	Fan speed (RPM)	rpm	Outdoor	MED
17	getVAR_out_sensor_airout	0x821C	Ambient / outdoor temp (duplicate)	°C	Outdoor	HIGH
18	getVAR_out_sensor_top1 (again)	0x8280	Compressor top temp	°C	Outdoor	HIGH
19	getVAR_out_power	0x8413 (observed in logs)	Outdoor instantaneous power	W	Outdoor	MED
20	getVAR_out_energy_accumulated	0x8414 / 0x8416	Accumulated energy (wattmeter)	kWh (scaling varies)	Outdoor	HIGH (message id needs checking 8414/8416)
21	getVAR_out_phase_current	0x82DB	Phase current	A	Outdoor	HIGH
22	getVAR_out_phase_voltage	0x82DE	Phase voltage	V	Outdoor	HIGH
23	getVAR_out_phase_power	0x82DF	Phase power	W	Outdoor	HIGH

24	getVAR_out_power_factor	0x82E8	Power factor (×0.01)	pf	Outdoor	HIGH
25	getVAR_out_efficiency	0x82ED	Instantaneous COP / efficiency (×0.1)	COP	Outdoor	HIGH
26	getVAR_out_capacity	0x82F6	Delivered capacity (kW ×0.1)	kW	Outdoor	HIGH
27	getVAR_out_compressor_freq / getFreq	0x8244 (or other)	Compressor frequency / inverter frequency	Hz	Outdoor	MED
28	getVAR_out_fan_current	0x8225 (or 0x8238)	Fan electrical current	A	Outdoor	MED
29	getVAR_out_fan_power	0x8227 (or 0x8239)	Fan electrical power	W	Outdoor	MED
30	getVAR_out_total_power / getVAR_out_total_power?	0x823D	Unit total electrical power	W	Outdoor	MED
31	getVAR_out_power_status / getENUM_out_operation_odu_mode	0x8248 / 0x8001	Operation mode enum / status	enum	Outdoor	MED

32	getENUM_out_defrost_mode / getENUM_out_operation_odu_mode	0x8031 / 0x8075	Defrost mode (enum)	enum	Outdoor	MED
33	getVAR_in_temp_room_f / getRoomTemperature	0x4203	Indoor room temperature	°C (×0.1 raw → ÷10)	Indoor	HIGH
34	getVAR_in_temp_target_f / getTargetTemperature	0x4201	Setpoint / target temperature	°C (×0.1)	Indoor (controller)	HIGH
35	getVAR_in_temp_eva_in_f	0x4205	Indoor evaporator inlet (evaporator) temp	°C (×0.1)	Indoor	HIGH
36	getVAR_in_temp_eva_out_f	0x4206	Indoor evaporator outlet temp	°C (×0.1)	Indoor	HIGH
37	getVAR_in_pipe_temp / getFlowTemperature	0x4204	Pipe temperature	°C	Indoor (hydronic)	MED
38	getVAR_in_water_temp / getDHWTemperature	0x4236 (water loop) or 0x4239 (DHW)	Water loop temperature / DHW tank temp	°C (×0.1)	Indoor / Hydro	HIGH (one of two, check index)

39	getVAR_in_temp_water_outlet_target_f	0x4247	Water outlet target temp (setpoint)	°C (×0.1)	Indoor	HIGH
40	getVAR_in_temp_water_heater_target_f	0x4235	DHW setpoint	°C (×0.1)	Indoor (DHW)	HIGH
41	getVAR_in_circulation_pump_speed	0x40C4	Circulation pump speed	%	Indoor (DHW loop)	HIGH
42	getVAR_in_water_flow	0x42E9	Water flow rate (L/min ×0.1)	L/min	Indoor (DHW/loop)	HIGH
43	getENUM_IN_3WAY_VALVE	0x4067	3-way valve position (enum/bitfield)	% or enum	Indoor (DHW)	HIGH
44	getENUM_IN_WATERPUMP_PWM_VALUE	0x40C4 or 0x40C5	Water pump PWM (speed)	%	Indoor	MED
45	getVAR_in_operation_state	0x4217	Indoor operation state	enum / bitfield	Indoor	MED
46	getVAR_in_water_valve	0x423E	Water valve state	enum / %	Indoor	MED
47	getVAR_in_power_consumption	0x427F	Indoor loop power consumption	W	Indoor	LOW

48	getVAR_in_water_level	0x428C	Tank water level	% or level	Indoor (DHW)	LOW
49	getVAR_in_water_quality	0x42D4	Water quality reading	index	Indoor (DHW)	LOW
50	getVAR_in_water_filter	0x42D8	Water filter status	enum	Indoor (DHW)	LOW
51	getVAR_in_water_pump	0x42D9	Water pump status	boolean / enum	Indoor	LOW
52	getENUM_in_operation_power	0x4000	Indoor power (on/off)	boolean	Indoor	HIGH