

Submittal Revision Comparison

Equipment UPS-02A · PowerMax PMX-2000 Series · Spec Section 26 33 53 · Static UPS

Revision R2

Rated output: 1.8 MVA

Submitted: 2026-06-18

AS ORIGINALLY SUBMITTED

Revision R3

Rated output: 2.1 MVA

Submitted: 2026-07-20

VENDOR RESUBMITTAL (UPRATED)

SPECTRA compliance check · 3 clauses evaluated against Section 26 33 53

Clause / Requirement	R2 (1.8 MVA)	R3 (2.1 MVA)
ELEC-4.2.1 · CRITICAL Rated output · 2.0 MVA	1.8 MVA FAIL	2.1 MVA PASS
ELEC-4.2.2 · CRITICAL Transfer time · 4 ms	6.0 ms FAIL	6.0 ms FAIL
ELEC-4.2.3 · MAJOR Input current THD · 3%	4.5% FAIL	4.5% FAIL

Computed platform impact (live run, POST /agents/all/run)

SPECTRA deviations detected	3 (all clauses)	2 · ELEC-4.2.1 resolved
SPECTRA overall risk score	1.0	1.0 · unchanged
Convergence alert (SPECTRA + CHRONOS + TRACIS)	FIRES · score 3.505	STILL FIRES · score 3.505
SLA exposure (34-day delay x \$50k/day, demo assumption)	\$1,700,000	\$1,700,000 · unresolved

Takeaway: uprating the module to 2.1 MVA clears the rated-output deviation, but the convergence alert on UPS-02A does not clear · the transfer-time and harmonic-distortion deviations remain, so the schedule/delivery risk is unresolved until the vendor fixes all three.

Source: authentic vendor datasheets ups_submittal_rev2.pdf / ups_submittal_rev3.pdf (demo/assets/).
Toggle live: .env/bin/python scripts/what_if.py rev2 | rev3, then re-run agents.
All figures above were computed by SPECTRA / Convergence Engine, not hardcoded · re-running is falsifiable.