



---

# SIEMENS OPEN LIBRARY

---

1 - Library Overview and Architecture

OCTOBER 11, 2016

---

## 1. Contents

1. Purpose .....	5
2. Intended Use.....	5
3. Revision History.....	5
4. Open Library License.....	5
5. Hardware and Software Compatibility .....	5
6. Background .....	6
7. Target Platforms .....	6
7.1. PLC Target.....	6
7.2. HMI Target.....	6
8. Testing.....	6
8.1. PLC Testing.....	6
8.2. HMI Testing .....	6
9. Support Resources.....	7
9.1. Technical Support .....	7
9.2. Documentation .....	7
10. Library Overview .....	8
10.1. Motor Control.....	8
10.1.1. G Series VFD Control – fbVFD_GSeries.....	8
10.1.2. Analog VFD Control – fbVFD_Analog.....	8
10.1.3. Digital Single Speed Motor – fbMotor_Reversing .....	8
10.2. Valve Control.....	8
10.2.1. Two State Solenoid Valve – fbValve_Solenoid.....	8
10.2.2. Analog Valve – fbValve_Analog.....	8
10.3. Inputs/Outputs .....	8
10.3.1. Analog Input with Scaling and Alarms – fbIO_AnalogInput.....	8
10.3.2. Analog Output with Scaling – fbIO_AnalogOutput.....	8
10.4. General.....	8
10.4.1. System Control.....	8
10.4.2. Interlock Function Block - fbInterlock.....	9
10.4.3. PID Interface – fbPID_CompactInterface .....	9

10.4.4. Standard Alarm Interface - fbAlarmWarning .....	9
10.5. Supplementary Blocks .....	10
11. Library Standards .....	11
11.1. Naming Conventions .....	11
11.1.1. Variable Prefix .....	11
11.1.2. Data Flow Prefix .....	11
11.2. Using Constants .....	12
11.2.1. Constant Categories .....	12
11.3. Data and Function Block Numbering .....	12
12. Program Architecture .....	14
12.1. Modes and System Control .....	14
12.1.1. Overview .....	14
12.1.2. Mode Definitions .....	14
12.1.3. Using Mode for a Small System .....	14
12.1.4. Using Mode for a Medium or Large System .....	15
12.1.5. Changing Global Mode .....	15
12.1.6. Disable Modes .....	15
12.2. Memory Management .....	15
12.2.1. Function Block Memory .....	15
12.2.2. Using Instance Memory .....	15
12.2.3. Multi-instance Memory Model .....	16
12.2.4. Single Instance Memory Model .....	16
12.3. HMI Display Status and Errors .....	16
12.3.1. Status .....	16
12.3.2. Error Codes .....	16
13. Alarm Usage .....	17
13.1. General Alarms .....	17
13.2. Excel Macro .....	17
13.3. Alarm Special Considerations .....	17
14. Custom Modifications .....	18
15. Contributing to the Library .....	19



---

## 1. Purpose

The purpose of this document is to provide a general overview of the library and to discuss decisions in program architecture that make best use of the library. Additionally, this document will discuss system compatibility, testing, and how to contribute to growing the Open Library.

---

## 2. Intended Use

This document is intended to be the starting point by anyone utilizing the Open Library for PLC and HMI Development.

---

## 3. Revision History

Version	Date	Author	Comments
1.0	2016-05-23	DMC	Initial Release
1.1	2016-06-20	DMC	No Changes
1.2	2016-08-23	DMC	Added information on Supplementary Blocks
1.3	2016-10-11	DMC	No Changes

---

## 4. Open Library License

Copyright (c) 2016 DMC, Inc.

Permission is hereby granted, free of charge, to any person obtaining a copy of this software and associated documentation files (the "Software"), to deal in the Software without restriction, including without limitation the rights to use, copy, modify, merge, publish, distribute, sublicense, and/or sell copies of the Software, and to permit persons to whom the Software is furnished to do so, subject to the following conditions:

The above copyright notice and this permission notice shall be included in all copies or substantial portions of the Software.

THE SOFTWARE IS PROVIDED "AS IS", WITHOUT WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND NONINFRINGEMENT. IN NO EVENT SHALL THE AUTHORS OR COPYRIGHT HOLDERS BE LIABLE FOR ANY CLAIM, DAMAGES OR OTHER LIABILITY, WHETHER IN AN ACTION OF CONTRACT, TORT OR OTHERWISE, ARISING FROM, OUT OF OR IN CONNECTION WITH THE SOFTWARE OR THE USE OR OTHER DEALINGS IN THE SOFTWARE.

---

## 5. Hardware and Software Compatibility

This library was developed in TIA Portal V13 SP1. It has been tested on the S7-1200 and S7-1500 platforms, and untested modifications have been made for compatibility with S7-300 and S7-400. The PLC objects can be used with any HMI, however, the configuration of the faceplates is only available using a Comfort Panel or WinCC Advanced, and have been tested on a 7" Comfort Panel.

---

## 6. Background

The Siemens Open Library was developed by DMC Inc. over many years. Through a joint collaboration with Siemens Industry, DMC documented the library and released it as an Open Source Library open for anyone to use and distribute. The Library is Open Source and will allow for users to contribute content to help enhance the overall availability of functionality to the greater Siemens User Community.

---

## 7. Target Platforms

This section covers the target platforms that apply to the library.

### 7.1. PLC Target

This library is targeted at S7-1200 and S7-1500 applications. Due to improvements made with the newer processors, TIA portal allows symbolic use of UDTs on the HMI for S7-1200 and S7-1500, which is not available on older PLC platforms. The PLC blocks will still compile and function on S7-300 and S7-400 applications, but the HMI mapping will not be available.

### 7.2. HMI Target

The HMI used for this library will be a Siemens Comfort Panel or WinCC Advanced RT. Due to the limitations of a Basic Panel, the HMI pop-up structures and symbolic addressing will not work on a Basic Panel. The HMI pop-ups can be modified to be used, but will require individual mapping of each point by the end user.

---

## 8. Testing

This section covers the testing that was completed for use of the project.

### 8.1. PLC Testing

The Siemens Open Library was tested on an S7-1500 using TIA Portal V13 SP1 Update 8. Most blocks were tested using simulation, however, some of the blocks, such as G-Series VFD and PID interface, were tested with actual hardware. DMC makes no guarantee of functionality for any Siemens Open Library objects on a given platform.

### 8.2. HMI Testing

The Siemens Open Library was tested on a 7" WinCC Comfort Panel. Faceplates were tested on actual hardware and in simulation mode to verify functionality.

---

## 9. Support Resources

This section covers available support resources for use of the Siemens Open Library.

### 9.1. Technical Support

Since this library was not developed by Siemens, it is not supported by Siemens Technical Support. For questions or complicated implementations, DMC is willing to provide support, however this support is not free. Questions can be directed to the following email address or phone number:

[siemens.library@dmcinfo.com](mailto:siemens.library@dmcinfo.com)

312-255-8757

### 9.2. Documentation

The following documents have been created to help users implement, customize, and maintain the Siemens Open Library

1. Library Overview and Architecture (This Document)  
Overview of the Library and design considerations.
2. Initial Setup  
Provides information on how to do the initial configuration required for all library objects.
3. Example Object Configuration  
Walks through how to use and configure a single object and uses fbValve\_Solenoid as an example.
4. Detailed Library Block Description  
Provides detailed information for the functionality, inputs, outputs, UDTs, and Faceplates for each object.
5. Siemens HMI Alarm Generation  
Provides information for how to generate alarms for use in WinCC Comfort or WinCC RT Advanced using the automated tools.
6. PID Block Configuration  
Walks through how to use and configure the PID Object, as it has special instructions.
7. Customizing Library Objects  
Discusses how to modify the library to change functionality or appearance.

---

## 10. Library Overview

This section outlines all objects that the library currently contains.

### 10.1. Motor Control

#### 10.1.1. G Series VFD Control – fbVFD\_GSeries

The G Series VFD Control Function Block is utilized for use of Siemens G Series VFD or Micromaster VFDs using Standard Telegram 1. This block does not use a technology object. This allows for a lower CPU requirement for each drive. It utilizes Standard Telegram 1 and has been tested on a G120, however, it will function with any drive using Standard Telegram 1 on either Profibus or Profinet.

#### 10.1.2. Analog VFD Control – fbVFD\_Analog

The fbVFD\_Analog Motor Control Function Block is utilized for use of a VFD controlled with digital and analog signals. The error UDT is kept identical to the GSeries error UDT, however, some error outputs are not utilized by this block.

#### 10.1.3. Digital Single Speed Motor – fbMotor\_Reversing

The Reversing Motor Control Function Block is utilized for motors started and stopped using digital outputs. This block functions with single direction or reversing motors.

### 10.2. Valve Control

#### 10.2.1. Two State Solenoid Valve – fbValve\_Solenoid

This library item is to be utilized with two state solenoid valve applications. It can be used for spring close, spring open, or double acting solenoids.

#### 10.2.2. Analog Valve – fbValve\_Analog

This library item is to be utilized with a valve controlled using an analog output. This block will work with any valve that is controlled through an analog output from the PLC.

### 10.3. Inputs/Outputs

#### 10.3.1. Analog Input with Scaling and Alarms – fbIO\_AnalogInput

This library object scales analog inputs and provides setups for alarms.

#### 10.3.2. Analog Output with Scaling – fbIO\_AnalogOutput

This library object scales process values to be used for Analog Outputs.

### 10.4. General

#### 10.4.1. System Control

This library object is a User Defined Type only that is used to provide mode information to other Library Objects, and is controlled by HMI Faceplates.



#### 10.4.2. Interlock Function Block - fbInterlock

This library object is used to provide operator information for multiple values that are interlocking a process. It has inputs for items that may be interlocking a process, and informs the operator of what interlocks are preventing operation via an HMI faceplate.

#### 10.4.3. PID Interface – fbPID\_CompactInterface

The S7-1200 and S7-1500 provide PID Technology objects that are best practices for use, therefore this would not replace those blocks, but would provide an interface to the technology object on the HMI.

The interface will allow for modification of the PID loop and for manual override of the output from the HMI.

Unlike other library objects that are fully encapsulated, many of the outputs of this block will need to be mapped to the PID\_Compact block.

#### 10.4.4. Standard Alarm Interface - fbAlarmWarning

The Standard Alarm Interface provides an easy way to setup additional alarms.

## 10.5. Supplementary Blocks

Included in the library is a section for both S7-300 and S7-1500 labelled "Supplementary". These blocks are included in library for use in auxiliary applications, but are provided as-is and without documentation. As documentation is added for these blocks, they will be merged into the appropriate library location. These blocks will include any user submitted blocks that are submitted without documentation.

---

## 11. Library Standards

This section discusses standards that are used in the library.

### 11.1. Naming Conventions

The Siemens Open Library uses a specific set of variable naming prefixes. These prefixes increase readability and speed up the coding process once they are understood. Each item will contain two prefixes and then a meaningful name. The first prefix is variable type. The second prefix corresponds to the data flow (input, output, local variable) and can sometimes be blank. The standard for Siemens S7 PLC and HMI programs is as follows:

#### 11.1.1. Variable Prefix

TYPE	PREFIX	EXAMPLE
BOOL	b	bInAuto
BYTE	by	byOutStatus
INT	i	iInMode
REAL	r	rActualWeight
WORD	w	wInModbusAddress
DWORD	dw	dwInFlow
TIME	t	tInUpdateTimeout
STRING	s	sTitle
USER DEFINED TYPE	None	HMI_VFD_Control
MULTI INSTANCE FUNCTION BLOCK	None	ParameterReadWrite

#### 11.1.2. Data Flow Prefix

TYPE	PREFIX	EXAMPLE
FB/FC Input	In	bInAuto
FB/FC Output	Out	byOutStatus
Internal Static Variable	<blank>	rActualWeight
Internal Temporary Variable	Temp	tTempElapsedTime

## 11.2. Using Constants

The Siemens Open Library takes advantage of the User Constants feature of PLC tag tables. These constants should be used wherever possible instead of hardcoding values in function blocks. The Library constants are located in the 'Open Library' tag table in the Master Copies section.


Organization of the constants is done using dot (period) notation. The leftmost parts of constant names are general categories; categories or names get more specific toward the end. Below is a short description of the larger categories.

### 11.2.1. Constant Categories

CATEGORY NAME	DESCRIPTION
Modes	Top level system modes. See Section 12.1.2 for definitions.
Modes.PID	PID_Compact modes used in fbPID_CompactInterface block.
HMI	Any constants used for HMI display or logic.
HMI.Status	Controls color animations for HMI objects.
IoScaling	Used to scale any value read in from IO.
IoScaling.S7Analog	Contains constants for all S7 series AI cards and all sensor types.
Estop	Defines the action taken for an output when an E-Stop occurs.
DataTypes	Contains minimum and maximum limits for data types.

## 11.3. Data and Function Block Numbering

Each data and function block requires a unique identifying number. This number is typically set automatically by Portal, but it can also be manually modified. In order to avoid conflicts with this numbering system, it is suggested that the Siemens Open Library be imported before any custom data or function blocks are created. This insures that each block has a unique identifying number. If two or more blocks are using the same number, it is possible to resolve the conflict by changing the assigned number. This can be done by right clicking the block and selecting properties. Under the general tab, select a unique identifying number for that block.



---

## 12. Program Architecture

This section covers overall architecture and general design decisions. While these design outlines do not need to be adhered to for the blocks to function, they demonstrate why some design decisions were made with the blocks.

### 12.1. Modes and System Control

Mode is an integer that will be an input into all library objects that allow for HMI control. This section describes how to best use Modes inside your project.

#### 12.1.1. Overview

The Library Utilizes a Mode architecture that is used to control a given block in Off, Auto, or Manual modes. A single global mode is typically used for small systems, and multiple system modes are typically used for larger systems. For example, if the system is a standalone skid, then a single mode can apply to all objects. If the system is an entire manufacturing line with multiple sections, then it is often best to create a mode for each subsystem, however, this is not required.

#### 12.1.2. Mode Definitions

A typical project will have a mode for each major subsystem, so that all equipment in a given area carries an identical mode. The library blocks will have the following modes:

Mode	Value	Description
Stop	0	All Outputs disabled. Nothing in the system can run.
Auto	1	All blocks are in Auto. Each block will use the PLC configured values and logic for control.
Manual	2	All blocks are in Manual. Each block will use the HMI for control.
Independent	10	Each block mode will be set via the HMI. This allows for some devices to be in automatic and other to be in manual based on HMI mode selection.  Most current industry systems maintain a global mode of Independent, which allows for switching of devices to an individual mode independent of the mode of other devices.

#### 12.1.3. Using Mode for a Small System

For a small system a single global mode will need to be created. This mode will be passed into each Library Object that is created, and will be controlled by the HMI. There is no Function Block for controlling the mode, as that will be done from the HMI Pop-up faceplate.

#### 12.1.4. Using Mode for a Medium or Large System

For a medium or large system, there will usually be multiple modes configured, where each mode corresponds to a subsystem of the application. This mode will be passed into each Library Object that is part of that subsystem, and will be controlled by the HMI. There is no Function Block for controlling the mode, as that will be done from the HMI Pop-up faceplate, which will need to be added to the HMI for each subsystem.

The values for Mode should be passed into the function block that corresponds to that subsystem and controlled from the customer created function block.

#### 12.1.5. Changing Global Mode

If Global Mode Changes To:	Then Function Block Mode Changes To:
Auto	All function blocks change to Auto mode
Manual	All function blocks change to Manual mode
Independent	All function blocks maintain their previous mode, however, each block mode can now be changed independently via the HMI interface.
Stop	All function blocks change to Stop mode

#### 12.1.6. Disable Modes

For some systems, the HMI should always be in control of the mode for each object. This can be accomplished by using the constant 'Modes.Independent' as the input for each library block, which will allow the HMI pop-up to control the mode for a given object.

### 12.2. Memory Management

This Section will cover information pertaining to standard storage of memory required for the Library Objects.

#### 12.2.1. Function Block Memory

All Function Blocks require instance memory in order to be utilized, as they contain many variables that need to be retained across multiple scans. Function Block memory can be allocated as Multi-instance or Single Instance, however, Siemens best practices would recommend the use of a Multi-instance. The library will utilize a single instance for the PID interface, which is done to preserve all of the built in functionality for PID\_Compact.

#### 12.2.2. Using Instance Memory

The Siemens Open Library was designed to provide all required information as part of the HMI or Error UDTs or outputs from the Function Block. No memory contained inside of the instance memory of the Function Block should be used. This is to ensure proper operation of the block.

### 12.2.3. Multi-instance Memory Model

All documentation will utilize Multi-instance usage of Function Blocks. This is done to reduce overall number of instance data blocks that will need to be created, and to improve overall layout of the project structure.

### 12.2.4. Single Instance Memory Model

All blocks can be utilized as part of a single instance call of the block. This increases the overall number of instance data blocks, but will not impair the functionality of any of the Library Blocks.

## 12.3. HMI Display Status and Errors

Most Library function blocks take advantage of standard HMI display dynamics. The two commonly used in the Library are for actuator status and error displays.

### 12.3.1. Status

Status is indicated on the HMI by changing the color of the actuator or device. HMI indication is done through an integer in the HMI control structure named 'iStatus'. Status is not used for device control popups. The 'iStatus' integer is meant for HMI indication only and is therefore not recommended to be used in PLC logic.

### 12.3.2. Error Codes

Error codes are used to display dynamic text error messages in the device popup faceplates. The Library function blocks utilize 'fbErrorScroller' to scan through active alarms. Scrolling is accomplished using the 'iErrorCode' integer in the HMI structure. Because this value is scrolling, 'iErrorCode' is for HMI display only and should not be used in PLC logic. Boolean status bits should be used for logic instead.



---

## 13. Alarm Usage

Siemens Comfort Panels and WinCC Advanced Runtime use bits out of words to trigger alarms, and there are no methods to configure Boolean alarms. This library, however, utilizes bits for all alarms. To automate this process, the Siemens Open Library includes a Microsoft Excel macro that takes a data block of Booleans and generates alarms in the WinCC format. For detailed information, please see '5- Siemens Open Library- Siemens Alarm Generation.'

### 13.1. General Alarms

Section 10, as well as other supporting documents, contains instructions on adding error structures to error data blocks for each device. This same process should be used for creating individual alarms that are not covered within the scope of a device (e.g. high temperature, path blocked, door open, etc.). Single error bits should be placed within 'dbErrors' data blocks and given descriptive comments. These error bits may be placed inside structures for organization or just within the data block top level. Individual error bits may be alarms or warnings. These bits should then be written to in system-level logic using fbAlarmWarning. It is important to note that all auto-generating alarm tools will mark any error bit as an 'Error' in the HMI. Any warning bits will need to be manually changed to 'Warning' after import.

### 13.2. Excel Macro

The Excel macro uses the Data Block definition from TIA Portal to automatically generate alarms. All of the source code is included as part of the Excel macro and can be edited in VBA for custom applications. The Excel macro will work with any non-optimized data block containing Booleans. The Booleans can be placed directly in the Data Block, nested in User Defined Types, or nested in Structs.

### 13.3. Alarm Special Considerations

The included Excel macro has the following special considerations in order for the system to function:

1. The Data Block must be non-optimized (applies to 1200/1500 only and is accessible via the properties of the Data Block).
2. The User Defined Type, Struct, and/or individual Boolean comments will be utilized for the alarm text, so it is important to put in meaningful comments on each alarm.
3. The Excel macro will work with nested User Defined Types and Structs.
4. The Excel macro works only with data blocks containing only Booleans, so all automatically generated alarms will need to be Boolean alarms, and should be concentrated in Data Blocks.

---

## 14. Custom Modifications

Once blocks are pulled into the Project Library they can be modified to add or remove functionality or change appearance on the HMI. Additionally, it is possible to create a new global library, or add to the Siemens Open Library any block modifications that need to be used across multiple projects. There are special considerations for modifying UDTs that are used with S7-300 or S7-400 processors, and details for how to modify the library can be found in 'Siemens Open Library – Custom Modifications' document.

---

## 15. Contributing to the Library

The Siemens Open Library is an open source library, and contributions, improvements, and changes are welcome from anyone who has improved or added to the library. Please submit any custom objects to DMC by emailing them to [Contribute@OpenPLCLibrary.com](mailto:Contribute@OpenPLCLibrary.com).

Library objects may not be added immediately, but will be added as additional versions of the library are released.