

GENERAL ARRANGEMENT DRAWING - HEXANE FEED PUMP (GA-1201A)


Type: Centrifugal Pump (API 610 OH2) | Area 1200 - FEED PREPARATION & PURIFICATION

NOZZLE / CONNECTION SCHEDULE

MARK	SERVICE	SIZE-RATING	FACE	REMARKS
N1	SUCTION	3"-150#	RF	n-Hexane in
N2	DISCHARGE	2"-300#	RF	n-Hexane out
N3	SEAL FLUSH	1/2"	SW	Plan 11 flush
N4	CASING DRAIN	3/4"	SW	Drain
N5	CASING VENT	1/2"	SW	Vent

BILL OF MATERIAL

No	PART NAME	MATERIAL	QTY
1	CASING	ASTM A351 CF8M	1
2	IMPELLER	ASTM A351 CF8M	1
3	SHAFT	AISI 4140	1
4	SHAFT SLEEVE	SS316	1
5	MECHANICAL SEAL	JC T2100	1
6	BEARING (DE)	7310 BECBM	1
7	BEARING (NDE)	6310 C3	1
8	BEARING HOUSING	CAST IRON	1
9	WEAR RING	SS316	2
10	COUPLING SPACER	AISI 4140	1
11	BASEPLATE	CARBON STEEL	1
12	OIL SEAL	NBR	2



NOTES:

- MATERIAL OF CONSTRUCTION PER WPN-MAT-001.
- SURFACE PREP & PAINTING PER WPN-PAINT-001.
- ALL DIMENSIONS IN mm UNLESS NOTED.
- WEIGHTS ARE ESTIMATED (DRY / ERECTION).
- FOR NOZZLE LOADS REFER TO VENDOR DRAWING.
- ASSOC DOCS: P&ID TJC-LLD-PID-1201, INTERLOCK SEQ-1201.

REVISION HISTORY

REV	DESCRIPTION	BY	DATE
A	ISSUED FOR REVIEW	RS	15-05-2026
B	ISSUED FOR APPROVAL	RS	27-05-2026
0	ISSUED FOR CONSTRUCTION	RS	05-06-2026

This is sample data provided for CALIBER purposes only

TITLE:
GENERAL ARRANGEMENT DRAWING

DWG No.
TJC-LLD-GA-GA-1201A

HEXANE FEED PUMP - Centrifugal Pump (API 610 OH2)

REV: 0
SHEET 1 OF 1