

High Loading Filter Media using Novel Electrospinning Method

Seong Chan Kim, H. Young Chung, and David Y. H. Pui

*Particle Technology Laboratory
University of Minnesota*

CFR 52nd Review Meeting, Mechanical Engineering
Donaldson Company, Inc.
October 6th, 2017



Center for Filtration Research



Background



- Electrospinning has been a well-known simple method to fabricate nanofiber.
- Nanofiber filters exhibit high filtration efficiency and relatively low pressure drop across the filters, however low particle loading capacity is one of the main concerns due to its surface loading mechanism.
- This project is an initiative work to develop high loading nanofiber filter media using electrospinning method.



Center for Filtration Research



Electrospinning



SEM image from Donaldson.com



Center for Filtration Research

 UNIVERSITY OF MINNESOTA

Transparent Filter (Stanford University)



Center for Filtration Research




Transparent filter (Stanford University)

ARTICLE
Received 1 Sep 2014 | Accepted 6 Jan 2015 | Published 16 Feb 2015
DOI: 10.1038/ncomms7205

Transparent air filter for high-efficiency PM_{2.5} capture

Chong Liu^{1,*}, Po-Chun Hsu^{1,*}, Hyun-Wook Lee¹, Meng Ye², Guangyuan Zheng³, Nian Liu⁴, Weiyang Li¹ & Yi Cui^{1,5}






<http://news.stanford.edu/2015/02/18/filter-air-pollution-021815/>



Center for Filtration Research

 UNIVERSITY OF MINNESOTA

PM removal efficiency result (Stanford U.)



Pressure drop result (Stanford University)




Table 1 | Performance summary of transparent air filters compared with commercial air filters.

Sample	T (%)	E (%)	ΔP (Pa)	QF (Pa ⁻¹)
PAN-85	85	96.12	133	0.024
PAN-75	75	98.11	206	0.019
Commercial-1	15	16.93	299	0.00062
Commercial-2	6.2	99.58	809	0.0068

E, PM removal efficiency; ΔP, pressure drop; PAN, polyacrylonitrile; QF, quality factor; T, transmittance.
 $QF = -\ln(1 - E\%) / \Delta P$.





levels of transmittance. Figure 3e shows the schematic of the pressure drop measurement. The pressure difference across the air filter was measured. It is shown in Table 1 that at a face velocity of 0.21 m s^{-1} , the pressure drops of 85% and 75% transmittance air filters are only 133 and 206 Pa, respectively. This pressure drop is only $<0.2\%$ of atmosphere pressure, which is negligible. These levels of pressure drop are similar to that of a blank window screen without nanofibres (131 Pa). The ΔP



Center for Filtration Research



Lab-made transparent filter (U. of MN)



Center for Filtration Research

 UNIVERSITY OF MINNESOTA

Conclusions (Transparent filter)

- Transparent filter can be manufactured by depositing nanofiber layer on metal wire mesh.
- Nanofiber layer alone can be damaged easily, so hard to be used a traditional way of filtration.
- It is not clear in the literature but we can “suspect” that
 1. The filtration efficiency will decrease dramatically as increasing air flow, especially high transparency filter.
 2. Low transparency filter can be easily damaged by air flow due to its high pressure drop.
 3. With severe air contamination, the transparent filter would be dirty and lose its transparency so easily.



Center for Filtration Research



UNIVERSITY OF MINNESOTA


High Loading Filter Media



Center for Filtration Research




Nanofiber with beads



S4700 2.0kV 12.1mm x5.00k SE(U) 7/10/17 22:21

10.0μm




S4700 2.0kV 12.1mm x20.0k SE(U) 7/10/17 22:14

2.00μm

- PEO (MW=1,000,000 g/mol) 4g + DI water 100 ml
- Syringe needle: Blunt tip, I.D. 1.651 mm, Length 3.8 cm
- Solution feeding rate = 0.3 ml/hr, V = 7 kV, D = 10 cm

Bead forming




Center for Filtration Research



UNIVERSITY OF MINNESOTA

Beaded nanofiber filter media

w/o beads





SEM image from Donaldson.com



Center for Filtration Research

with beads



- 3D structure
- Depth loading
- Low ΔP
- High loading cap.

- 2D structure
- Surface loading
- High ΔP
- Low loading cap.

Publication about nanofiber filters with beads









Fig. 5. SEM images of PLA fibers electrosprayed from 5 wt% PLA solutions with different weight ratios of DCM/DMAC: (a) 6/1, (c) 8/1, and (e) 12/1. Highly magnified images corresponding to the membranes are shown in (b), (d), and (f), respectively.



Center for Filtration Research




Cellulose filter media for NF deposition (Substrate)




SU8230 0.8kV 8.8mm x30 LM(UL) 09/20/2017 10:36



SU8230 0.8kV 9.0mm x500 SE(UL) 09/20/2017 10:39



SU8230 0.8kV 25.2mm x100 SE(UL) 09/20/2017 10:44



Center for Filtration Research





UNIVERSITY OF MINNESOTA

Nanofiber filter samples (NF vs. Beaded NF)




High viscosity polymer solution

- PEO 5 g + DI water 100 ml
- 4 hours drying in oven
- ~ half of water evaporated



Low viscosity polymer solution




- PEO 4 g + DI water 100 ml



Center for Filtration Research

 UNIVERSITY OF MINNESOTA


Nanofiber filter efficiency & loading test



Center for Filtration Research

 UNIVERSITY OF MINNESOTA

Nanofiber filter loading test result (ΔP)






Center for Filtration Research



UNIVERSITY OF MINNESOTA

Nanofiber filter loading test result (η & QF)



Center for Filtration Research



UNIVERSITY OF MINNESOTA

Conclusions (High loading filter media)

- Polymer beads on nanofibers can be generated during electrospinning with low viscosity and high surface tension of polymer solution.
- These polymer beads can be used as spacers to improve particle loading capacity of nanofiber filters.
- Particle loading test result shows
 1. NF and Beaded NF filters show slower ΔP increase than substrate only, even though they have higher initial ΔP .
 2. Beaded NF filter shows about 30% higher Quality Factor (QF) than Nanofiber filter, and the optimum beaded NF design needs to be investigated.



Center for Filtration Research

