
Pole Num:	64978473_P.F406	Pole Length /	Class:	45 / 3	Code:	NESC	Structure Type:		Junction
Aux Data 1	Unset	Species:	SOU	THERN PINE	NESC Rule:	Rule 250B	Status G	uy Wir	es Adequate
Aux Data 2	Unset	Setting Depth	n (ft):	6.50	Construction Grade:	C	Pole Strength Facto	r:	0.85
Aux Data 3	Unset	G/L Circumfe	rence (in):	37.31	Loading District:	Light	Transverse Wind LF	:	1.75
Aux Data 4	Unset	G/L Fiber Str	ess (psi):	8,000	Ice Thickness (in):	0.00	Wire Tension LF:		1.30
Aux Data 5	Unset	Allowable Str	ess (psi):	6,800	Wind Speed (mph):	59.29	Vertical LF:		1.90
Aux Data 6	Unset	Fiber Stress I	Ht. Reduc:	No	Wind Pressure (psf):	9.00			
Latitude:		0.00000	<b>00 Deg</b> Longit	ude:		0.000000 Deg	Elevation:		0 Feet





Pole Capacity Uti	lization (%)	Height (ft)	Wind Angle (deg)
Maximum	44.7	0.0	270.0
Groundline	44.7	0.0	270.0
Vertical	1.9	23.9	0.0

Pole Moments (ft-	b)	Load Angle (deg)	Wind Angle (deg)
Max Cap Util	41,180	267.9	270.0
Groundline	41,180	267.9	270.0
GL Allowable	93,217		

Guy System Component Summary				Load From Angle o		Individual Ma	ximum Load
Description	Lead Length (ft)	Lead Angle (deg)	Height (ft)	Nominal Capacity (%)	Wind Angle (deg)	Max Load Capacity (%)	Wind Angle (deg)
Single Helix Anchor	23.0	180.0		0.5	270.0	5.2	0.0
EHS 3/8 (Down)			30.0	0.7	270.0	8.2	0.0
	ity Summary:	Aded	<sub>l</sub> uate	Adec	<sub>l</sub> uate		

Groundline Load Summary	y - Reporting A	Angle Mode: L	oad - Reportii	ng Angle: 267	.9°					
	Shear Load* (lbs)	Applied Load (%)	Bending Moment (ft-lb)	Applied Moment (%)	Pole Capacity (%)	Bending Stress (+/- psi)	Vertical Load (lbs)	Vertical Stress (psi)	Total Stress (psi)	Pole Capacity (%)
Powers	619	40.7	21,839	53.0	23.4	1,593	590	5	1,598	23.5
Comms	278	18.3	5,511	13.4	5.9	402	342	3	405	6.0
GuyBraces	12	0.8	347	0.8	0.4	25	128	1	26	0.4
PowerEquipments	82	5.4	3,496	8.5	3.8	255	636	6	261	3.8
Pole	485	31.9	8,593	20.9	9.2	627	2,247	20	647	9.5
Crossarms	6	0.4	199	0.5	0.2	15	190	2	16	0.2
Insulators	39	2.6	1,195	2.9	1.3	87	137	1	88	1.3
Pole Load	1,520	100.0	41,180	100.0	44.2	3,004	4,270	39	3,043	44.7
Pole Reserve Capacity			52,037		55.8	3,796			3,757	55.3

Load Summary by Owner	- Reporting An	gle Mode: Lo	ad - Reporting	Angle: 267.9	0					
	Shear Load* (lbs)	Applied Load (%)	Bending Moment (ft-lb)	Applied Moment (%)	Pole Capacity (%)	Bending Stress (+/- psi)	Vertical Load (lbs)	Vertical Stress (psi)	Total Stress (psi)	Pole Capacity (%)
<undefined></undefined>	608	40.0	22,790	55.3	24.5	1,663	1,339	12	1,675	24.6
FPL	634	41.7	12,879	31.3	13.8	940	2,589	23	963	14.2
CATV	76	5.0	1,606	3.9	1.7	117	114	1	118	1.7
AT&T	202	13.3	3,905	9.5	4.2	285	228	2	287	4.2
Totals:	1,520	100.0	41,180	100.0	44.2	3,004	4,270	39	3,043	44.7

**Detailed Load Components:** 

Power	·	Owner	Height (ft)	Horiz. Offset (in)	Cable Diameter (in)	Sag at Max Temp (ft)	Cable Weight (lbs/ft)	Lead/Span Length (ft)	Span Angle (deg)	Wire Length (ft)	Tension (lbs)	Tension Moment* (ft-lb)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Primary	ACSR 1/0 AWG 6/1 RAVEN		39.10	44.33	0.3980	0.23	0.145	150.0	0.0	150.0	2,628	-5,005	-76	1,532	-3,550
Primary	ACSR 1/0 AWG 6/1 RAVEN		39.10	44.33	0.3980	0.23	0.145	150.0	180.0	150.0	2,628	5,005	-76	1,532	6,461
Primary	ACSR 1/0 AWG 6/1 RAVEN		39.10	44.33	0.3980	0.23	0.145	150.0	0.0	150.0	2,628	-5,005	75	1,532	-3,398
Primary	ACSR 1/0 AWG 6/1 RAVEN		39.10	44.33	0.3980	0.23	0.145	150.0	180.0	150.0	2,628	5,005	75	1,532	6,612
Primary	ACSR 1/0 AWG 6/1 RAVEN		39.10	5.41	0.3980	0.23	0.145	150.0	0.0	150.0	2,628	-5,005	0	1,532	-3,474
Primary	ACSR 1/0 AWG 6/1 RAVEN		39.10	5.41	0.3980	0.23	0.145	150.0	180.0	150.0	2,628	5,005	0	1,532	6,536

Primary   ACSR 1/0 AWG 6/1   RAVEN												Totals:	0	-124	21,963	21,839
RAVEN   Primary   ACSR 1/0 AWG 6/1   RAVEN   S1.60   60.26   0.3980   0.23   0.145   150.0   180.0   150.0   2,628   4,557   -104   1,395	Secondary	FPL	FPL	26.97	6.34	0.5700	1.19	0.600	100.0	180.0	100.0	1,200	1,576	-30	1,008	2,554
Primary   ACSR 1/0 AWG 6/1   35.60   60.26   0.3980   0.23   0.145   150.0   180.0   150.0   2,628   4,557   -104   1,395	Secondary	FPL	FPL	26.97	6.34	0.5700	1.19	0.600	100.0	0.0	100.0	1,200	-1,576	-30	1,008	-598
RAVEN	Secondary	FPL	FPL	26.97	6.34	0.5700	1.19	0.600	100.0	270.0	100.0	1,200	42,041	-1	0	42,040
RAVEN Primary ACSR 1/0 AWG 6/1	Secondary	FPL	FPL	26.97	6.34	0.5700	1.19	0.600	100.0	90.0	100.0	1,200	-42,041	-1	0	-42,042
RAVEN  Primary ACSR 1/0 AWG 6/1 RAVEN  Primary RAVEN  Primary ACSR 1/0 AWG 6/1 RAVEN  Primary RAVEN  Primary ACSR 1/0 AWG 6/1 RAVEN  Primary RAVEN  PRIMA	Secondary	FPL	FPL	31.97	6.05	0.5700	1.19	0.600	100.0	180.0	100.0	1,200	1,868	-29	1,195	3,034
RAVEN Primary ACSR 1/0 AWG 6/1 RAVEN PRIMARY RAVEN	Secondary	FPL	FPL	31.97	6.05	0.5700	1.19	0.600	100.0	0.0	100.0	1,200	-1,868	-29	1,195	-701
RAVEN Primary ACSR 1/0 AWG 6/1 RAVEN PRIMARY RAV	Primary			35.60	5.62	0.3980	0.23	0.145	150.0	180.0	150.0	2,628	4,557	0	1,395	5,952
RAVEN Primary ACSR 1/0 AWG 6/1 35.60 60.26 0.3980 0.23 0.145 150.0 180.0 150.0 2,628 4,557 -104 1,395 RAVEN Primary ACSR 1/0 AWG 6/1 35.60 60.26 0.3980 0.23 0.145 150.0 0.0 150.0 2,628 -4,557 103 1,395 RAVEN Primary ACSR 1/0 AWG 6/1 35.60 60.26 0.3980 0.23 0.145 150.0 180.0 150.0 2,628 4,557 103 1,395	Primary			35.60	5.62	0.3980	0.23	0.145	150.0	0.0	150.0	2,628	-4,557	0	1,395	-3,163
RAVEN Primary ACSR 1/0 AWG 6/1 35.60 60.26 0.3980 0.23 0.145 150.0 180.0 150.0 2,628 4,557 -104 1,395 RAVEN Primary ACSR 1/0 AWG 6/1 35.60 60.26 0.3980 0.23 0.145 150.0 0.0 150.0 2,628 -4,557 103 1,395	Primary			35.60	60.26	0.3980	0.23	0.145	150.0	180.0	150.0	2,628	4,557	103	1,395	6,055
RAVEN Primary ACSR 1/0 AWG 6/1 35.60 60.26 0.3980 0.23 0.145 150.0 180.0 150.0 2,628 4,557 -104 1,395	Primary			35.60	60.26	0.3980	0.23	0.145	150.0	0.0	150.0	2,628	-4,557	103	1,395	-3,060
	Primary			35.60	60.26	0.3980	0.23	0.145	150.0	180.0	150.0	2,628	4,557	-104	1,395	5,848
	Primary			35.60	60.26	0.3980	0.23	0.145	150.0	0.0	150.0	2,628	-4,557	-104	1,395	-3,267

Comm		Owner	Height (ft)	Horiz. Offset (in)	Cable Diameter (in)	Sag at Max Temp (ft)	Cable Weight (lbs/ft)	Lead/Span Length (ft)	Span Angle (deg)	Wire Length (ft)	Tension (lbs)	Tension Moment* (ft-lb)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
CATV	CATV	CATV	21.97	6.64	0.5700	1.19	0.600	100.0	0.0	100.0	1,200	-1,283	-32	848	-467
CATV	CATV	CATV	21.97	6.64	0.5700	1.19	0.600	100.0	180.0	100.0	1,200	1,283	-32	821	2,073
Telco	AT&T	AT&T	19.97	6.76	0.5700	1.19	0.600	100.0	0.0	100.0	1,200	-1,167	-32	1,008	-190
Telco	AT&T	AT&T	19.97	6.76	0.5700	1.19	0.600	100.0	180.0	100.0	1,200	1,167	-32	1,074	2,208
Telco	AT&T	AT&T	19.97	6.76	0.5700	1.19	0.600	100.0	0.0	100.0	1,200	-1,167	-32	1,205	6
Telco	AT&T	AT&T	19.97	6.76	0.5700	1.19	0.600	100.0	180.0	100.0	1,200	1,167	-32	746	1,881
											Totals:	0	-191	5,703	5,511

PowerEquipme	nt	Owner	Height (ft)	Horiz. Offset (in)	Offset Angle (deg)	Rotate Angle (deg)	Unit Weight (lbs)	Unit Height (in)	Unit Depth (in)	Unit Diameter (in)	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Transformer	1PH-15KVA		29.00	21.22	270.0	270.0	335.00	34.00		22.00		1,125	2,371	3,496
											Totals:	1,125	2,371	3,496

Crossarm		Owner	Height (ft)	Horiz. Offset (in)	Offset Angle (deg)	Rotate Angle (deg)	Unit Weight (lbs)	Unit Height (in)	Unit Depth (in)	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
Normal	8' x 3.5" x 4.5" SP - 3 Pin		38.50	5.41	0.0	0.0	50.00	4.50	3.50	96.00	-2	106	104
Normal	8' x 3.5" x 4.5" SP - 3 Pin		35.00	5.62	0.0	0.0	50.00	4.50	3.50	120.00	-2	96	95
									ſ	Totals:	-3	202	199

Insulator		Owner	Height (ft)	Horiz. Offset (in)	Offset Angle	Rotate Angle (deg)	Unit Weight	Unit Diameter	Unit Length (in)	Offset Moment* (ft-lb)	Wind Moment* (ft-lb)	Moment at GL* (ft-lb)
				(111)	(deg)	(ueg)	(lbs)	(in)	(111)	(11-10)	(11-10)	(11-10)
Pin	15kV Pin Insulator		38.69	44.00	83.0	0.0	8.99	6.00	5.00	-63	127	64

								Totals:	-17	1,212	1,195
Bolt	Deadend 12.75"	20.00	0.00	90.0	90.0	3.00	2.00	15.00	-3	66	62
Bolt	Deadend 12.75"	20.00	0.00	90.0	90.0	3.00	2.00	15.00	-3	66	62
Bolt	Deadend 12.75"	22.00	0.00	90.0	90.0	3.00	2.00	15.00	-3	72	69
Bolt	Deadend 12.75"	27.00	0.00	90.0	90.0	3.00	2.00	15.00	-3	89	86
Bolt	Deadend 12.75"	27.00	0.00	0.0	0.0	3.00	2.00	15.00	0	89	88
Bolt	Deadend 12.75"	32.00	0.00	90.0	90.0	3.00	2.00	15.00	-3	105	102
Pin	15kV Pin Insulator	35.19	0.00	0.0	0.0	8.99	6.00	5.00	0	115	115
Pin	15kV Pin Insulator	35.19	-60.00	275.3	0.0	8.99	6.00	5.00	85	115	200
Pin	15kV Pin Insulator	35.19	60.00	84.7	0.0	8.99	6.00	5.00	-86	115	30
Pin	15kV Pin Insulator	38.69	0.00	0.0	0.0	8.99	6.00	5.00	0	127	127
Pin	15kV Pin Insulator	38.69	-44.00	277.0	0.0	8.99	6.00	5.00	62	127	189

Guy Wire and Brad	ce	Owner	Attach Height (ft)	End Height (ft)	Lead/Span Length (ft)	Wire Diameter (in)	Percent Solid (%)	Lead Angle (deg)	Incline Angle (deg)	Wire Weight (lbs/ft)	Rest Length (ft)	Stretch Length (in)
EHS 3/8	Down	•	30.00	0.00	23.00	0.375	75.00	180.0	52.4	0.273	36.09	0.02

Guy Wire and Bra (Loads and React		Elastic Modulus (psi)	Rated Tensile Strength (lbs)	Guy Strength Factor	Allowable Tension (lbs)	Initial Tension (lbs)	Loaded Tension* <sup>2</sup> (lbs)	Maximum Tension <sup>2</sup> (lbs)	Applied Tension <sup>3</sup> (lbs)	Vertical Load (lbs)	Shear Load In Guy Dir (lbs)	Shear Load At Report Angle (Ibs)	Moment at GL³ (ft-lb)
EHS 3/8	Down	2.30e+7	15,400	0.90	13,860	700	1,139	1,035	101	80	62	2	347
									Totals:	80	62	2	347

Anchor/Rod Load Summary	Owner	Rod Length AGL (in)	Lead Length (ft)	Lead Angle (deg)	Strength of Assembly (lbs)	Anchor/Rod Strength Factor	Allowable Load (lbs)	Max Load² (lbs)	Load at Pole MCU <sup>3</sup> (lbs)	Max Required Capacity <sup>2</sup> (%)
Single Helix Anchor		18.00	23.00	180.0	20,000	1.00	20,000	1,035	101	5.2

Pole Buckli	ing												
Buckling Constant	Buckling Column Height* (ft)	Buckling Section Height (% Buckling Col. Hgt.)	Buckling Section Diameter (in)	Minimum Buckling Diameter at GL (in)	Diameter at Tip (in)	Diameter at GL (in)	Modulus of Elasticity (psi)	Pole Density (pcf)	Ice Density (pcf)	Pole Tip Height (ft)	Buckling Load Capacity at Height (lbs)	Buckling Load Applied at Height (lbs)	Buckling Load Factor of Safety
0.71	23.90	33.57	10.93	9.67	7.32	11.88	1.60e+6	60.00	57.00	38.50	228,500	2247.52	52.63

Notes									
Date	Author	Description							
1/27/2021		Power Company Request							
Power company load	Power company load data has been requested. Email sent to Elmer Pole								
1/27/2021		General Description							

General Statement: Non-AT&T facilities may not be accurately identified pending attachment information from attaching party.