Annual Electrical/Mechanical Inspection

Muscogee Nation - Tribal Construction Inspections | P.O. Box 580 Okmulgee, OK 74447
jstrickland@muscogeenation.com | 918.758.6244

Facility Name & Address | County

Inspector Name & Title | Facility Contact Information

Building Use: _____

Date

PASS ☐ NEEDS WORK ☐ FAIL ☐

Section 1: Electrical Inspection Checklist

OK	Needs Work	N/A	
			GENERAL OVERVIEW
			SITE ACCESS CLEAR & SAFE
			NO VISIBLE ELECTRICAL HAZARDS
			ADDRESS CLEARLY VISIBLE FROM THE STREET
			ELECTRICAL PANELS
			CONDITION OF PANELS – NO RUST / CORROSION
			LABELS CLEAR & ACCURATE
			ADEQUATE SPACE AROUND PANELS
			WIRING
			PROPERLY SECURED & ROUTED
			NO DAMAGED OR FRAYED INSULATION
			ADEQUATE SEPARATION FROM OTHER SYSTEMS
			OUTLETS & RECEPTACLES
			FUNCTIONALITY TESTED
			GFCI OUTLETS IN WET AREAS
			TAMPER-RESISTANT OUTLETS AS REQUIRED
			LIGHTING SYSTEMS
			ALL FIXTURES OPERATIONAL
			EMERGENCY EXIT LIGHTS FUNCTIONING
			ADEQUATE ILLUMINATION LEVELS MAINTAINED

Annual Electrical/Mechanical Inspection

OK	Needs Work	N/A	
			GROUNDING & BONDING
			PROPER GROUNDING CONNECTIONS
			NO VISIBLE CORROSION
			GROUNDING ELECTRODE SYSTEM FUNCTIONAL
			SURGE PROTECTION
			SURGE PROTECTORS IN PLACE FOR SENSITIVE EQUIPMENT
			FUNCTIONALITY VERIFIED
			COMPLIANCE
			MEETS LOCAL & NATIONAL ELECTRICAL CODES
			UPDATED SAFETY SIGNAGE POSTED
			RECENT INSPECTION OR MAINTENANCE RECORDS REVIEWED

Section 2: Mechanical Inspection Checklist

OK	Needs Work	N/A	
			HVAC SYSTEMS
			UNITS CLEAN & FREE OF DEBRIS
			FILTERS CHANGED / CLEANED
			THERMOSTAT FUNCTIONING PROPERLY
			DUCTWORK
			NO VISIBLE LEAKS OR DAMAGE
			PROPER INSULATION IN PLACE
			CLEAR OF OBSTRUCTIONS
			PIPING SYSTEMS
			NO LEAKS OBSERVED IN PIPES
			PROPER INSULATION ON HOT & COLD LINES
			VALVES ACCESSIBLE & OPRATIONAL
			EQUIPMENT CONDITION
			ALL MECHANICAL EQUIPMENT OPERATIONAL
			REGULAR MAINTENANCE DOCUMENTED
			SAFETY GUARDS IN PLACE ON MOVING PARTS

Annual Electrical/Mechanical Inspection

OK	Needs Work	N/A	**VENTILATION**
			ADEQUATE AIRFLOW IN ALL AREAS
			EXHAUST SYSTEMS FUNCTIONING CORRECTLY
			AIR QUALITY MEETS SAFETY STANDARDS

			COMPLIANCE
			MEETS LOCAL AND NATIONAL MECHANICAL CODES
			SAFETY SIGNAGE POSTED & VISIBLE
			MAINTENANCE LOGS REVIEWED

Corrective Action / Comments: