Annual Fire Safety Inspection

Muscogee Nation - Tribal Construction Inspections | P.O. Box 580 Okmulgee, OK 74447
scrow@muscogeenation.com | 918.752.8597

Facility Name & Address | County

Inspector Name & Title | Facility Contact Information

PASS ☐ NEEDS WORK ☐ FAIL ☐

Date

OK	Needs Work	N/A	DOCUMENTATION
			FIRE ALARM - tested annually by licensed contractor
			FIRE SPRINKLERS - 5 yr test completed by licensed contractor
			FIRE SPRINKLERS - tested annually by licensed contractor
			EMERGENCY POWER - tested annually for 90 min & documented
			EMERGENCY LIGHTING
			KITCHEN HOOD SYSTEMS - serviced annually
			GENERATOR – tested weekly/monthly
			ANNUAL EVACUATION DRILL
			FIRE DEPARTMENT ACCESS
			Address clearly visible from the street
			Fire apparatus access roads, fire hydrants, FDC's, etc not obstructed
			Appropriate access keys provided in approved key box
			Fire hydrant & OS&Y valves are operational & have a 3 ft clearance
			EGRESS
			Exits & paths not obstructed in any manner
			Where required, exit signs properly mounted, illuminated & not obstructed
			Fire rated doors close & latch without assistance
			Do not prop open fire rated doors
			Egress doors can be used for egress without use of a key or special knowledge Exit doors open toward the direction of travel
			Evacuation procedures posted in plain view
			No storage in stairwells

Annual Fire Safety Inspection

OK	Needs Work	N/A	**STORAGE**
			Housekeeping
			Cylinders - marked & secured
			Keep storage 18" below fire sprinklers & 24" below ceilings without sprinklers
			Remove combustible storage from mechanical equipment rooms
			Oily rags stored in closed metal containers
			Food products stored separately from cleaning products

			ELECTRICAL
			Approved covers provided for all switch & electrical outlet boxes. Open junction boxes & open-wiring splices prohibited
			Electrical panels clearly labeled
			Working clearance provided in front of electrical service equipment 30" wide x 36" deep x 78" high
			Ampacity of extension cords & relocatable power taps not exceeded
			NO extension cord
			Appliances plugged directly into a permanent receptacle
			Multiplug adapters - cube adapters & unfused plug strips or other devices are prohibited
			GFI at wet location
			No space heater

			HAZMAT
			Does not exceed allowable quantities
			Flammable & combustible liquids stored & used appropriately
			Shelving braced & anchored
			Empty tanks free of residual material & vapor
			Tanks out of service over 90 days
			SDS updated & accessible
			704 placard matches to the product

			FUEL STATIONS (or N/A ___)
			Emergency shutoff valves & leak detectors checked & tested annually
			Approved portable fire extinguisher within 75 ft of fuel pumps & storage
			Warning signs posted
			Combustible materials (incl. vegetation) kept 10 ft away from fueling equipment

			VENT HOODS (or N/A ___)
			Nozzle caps in place & in proper position
			Manual pull station in proper location
			Exhaust fan & lights operational
			Check gas shut-off valve
			Pressure gauge in proper range
			Hydro test date
			Manufacturer's date & brand
			Check fusible links & cleanliness
			Proper extinguishers
			Service date on tag

Annual Fire Safety Inspection

OK	Needs Work	N/A	**FIRE EXTINGUISHERS**
			Documented monthly inspection of extinguishers
			Extinguishers mounted properly & not obstructed
			Collar tag intact with current annual servicing
			Fire alarm systems, fire detection systems, automatic sprinkler system or extinguishing systems & communications systems maintained in operable condition

YEAR, BRAND, TYPE, MAINTENANCE DUE, HYDRO DUE, ...

Annual Fire Safety Inspection

RISERS (or N/A ___)
Last Inspected _____
Tagged _____
Sprinkler Kit _____
Deficiencies _____
Calc Plate _____
5yr Internals & Gauges _____

SPRINKLER HEAD CONDITION (or N/A)

☐ OK ☐ Painted/Corroded/Wrong Head ☐ Replace ☐ N/A

CEILING TYPE:

TILES
☐ OK ☐ Repair

HARD LID
☐ OK ☐ Repair

OPEN CEILINGS
☐ OK ☐ Repair

AED (or N/A)

☐ OK ☐ Repair AED Expiration _____

CORRECTIVE ACTION / COMMENTS:

Annual Fire Safety Inspection

CORRECTIVE ACTION / COMMENTS (cont):