The Journal of Open Source Software

cd2es: Converting climate data to energy system input data

Leonie Sara Plaga [1,¶] **and Valentin Bertsch** [1,]

1 Ruhr-Universität Bochum, Universitätsstr. 150, 44801 Bochum, Germany ¶ Corresponding author

DOI: 10.xxxxxx/draft

Software

- Review
- Repository
- Archive

Editor:

Submitted: 10 September 2024
Published: unpublished

License
Authors of papers retain copyright and release the work under a Creative Commons Attribution 4.0 International License (CC BY 4.0).

DRAFT

Summary

The tool *cd2es* converts climate projections from cordex (WCRP, 2024) to energy system model input data. The tool is written in python and uses snakemake for workflow management. *cd2es* can calculate climate change impacts on various energy system components. In contrast to existing tools, *cd2es* can use a variety of different climate models instead of historic weather data. Optionally, a bias-adaption with era5-reanalysis data can be performed. *cd2es* can automatically download both cordex and era5 data. The outputs are time series for renewable capacity factors, demand and the availability of thermal power plants aggregated to user specific geometries with an hourly resolution for easy implementation into different energy system models.

Statement of need

Global Circulation Models (GCMs) modelling the properties of the atmosphere and oceans project future climate developments (Jacob et al., 2014). Those GCMs project a significant change in climate variables such as temperature and precipitation under climate change (Dosio & Fischer, 2018). As many components of the energy system depend on climate variables, climate change should be considered when planning future energy systems. It is therefore important to convert climate projections into input data for energy system models, which are commonly used for energy systems planning (DeCarolis et al., 2017; Plaga & Bertsch, 2023).

There is only a limited number of tools available which convert climate variables into energy system model inputs. renewables.ninja calculates solar and wind capacity factors from historical reanalysis data (Pfenninger & Staffell, 2016; Staffell & Pfenninger, 2016), but neither the underlying data nor the methods are exposed, making it impossible to use climate projections as input. The python library pvlib (Holmgren et al., 2018) allows for a detailed calculation of solar capacity factors, yet is limited to historic data and solar capacity factors. Pypsa/atlite (Hofmann et al., 2021) converts historic reanalysis data to energy system input data. Yet, it cannot account for climate projections and does not calculate climate influences on thermal power plants. Formayer et al. (2023) provide a data set for temperature, radiation, wind power and hydro power based on future climate projections. However, they only provide results for one climate model and the continent Europe and no ready to use code to enlarge the findings to other climate models or other continents. In summary, there is a lack of open source tools to include climate projections into energy system planning in a comprehensive matter.

cd2es provides a tool for automatically downloading climate projections and the converting them to energy system input data. It supports the calculation of wind and solar photovoltaic capacity factors, concentrated solar power, availability of thermal power plants, hydro power and electricity demand based on cordex climate data (WCRP, 2024). The tool can process a variety of different climate models hosted on cordex for a wide geographical scope. It allows for an optional bias correction of the climate data based on era5-reanalysis data (Muñoz Sabater,

2019). The output of *cd2es* are csv files with time series in hourly resolution for a user-chosen geography. Therefore, they can be easily included in different energy system optimization models. The *cd2es* tool was used in (Plaga & Bertsch, 2022) and is currently in use in two research projects, StEAM and REWARDS (Härtel, 2024).

Software dependencies

The software is written in python and uses the workflow management tool snakemake (Mölder et al., 2021). For processing climate data, the open-source tool *cdo* (Schulzweida, 2020) is used. On Windows, the open-source tool *wsl* is necessary to run *cdo* on Windows (microsoft, 2024).

Methods for converting climate variables to energy system input data

Most conversion methods are based on Plaga & Bertsch (2023) and described in detail in the documentation of the tool *cd2es*. However, we will also include a short overview here.

Bias adaption

The climate data is bias adapted using a quantile delta mapping approach (Cannon et al., 2015).

Wind power

The wind speed is first interpolated from the height reported in the data to turbine height. Then capacity factors can be derived via a standardized production curve:

$$cf_{\text{wind, single}}(v) = \begin{cases} 0, & v < v_{\text{in}}, \\ \frac{v^3 - v_{\text{in}}^3}{v_{\text{r}}^3 - v_{\text{in}}^3}, & v_{\text{in}} \leq v < v_{\text{r}}, \\ 1, & v_{\text{r}} \leq v < v_{\text{out}}, \\ 0, & v \geq v_{\text{out}}, \end{cases}$$

with cut-in velocity v_{in}, rated velocity v_{r} and cut-out velocity v_{out} (van der Wiel et al., 2019). We smooth the production curve with a gaussian filter to account for multiple turbines (Staffell & Pfenninger, 2016).

Solar photovoltaics

Photovoltaic cells are influenced by climate variables in two ways: the solar irradiance G influences the available incoming energy, while the temperature T influences the cell's efficiency. The *cd2es* tools supports three different models for calculating photovoltaic time series, see (Jerez et al., 2015).

Availability of thermal power plants

As thermal power plants need cooling, their availability decreases with rising temperatures. *cd2es* distinguishes between once-through cooled plants and closed-loop cooled plants. For once-through plants, not only the temperature but also available water is considered. The availability of the plants follows piecewise linear equations, which were implemented as described in (Abdin et al., 2019).

DRAFT

Hydropower

To calculate hydro power output, historic runoff at the hydro power plants' locations are evaluated. It is assumed, that power plants reach their installed capacity P_0 at the average historic runoff $\bar{Q}_{\text{hist}}$ at their location (optionally multiplied by factor a). Then, future hydro power of one power plant $P(t)$ can be calculated with

$$P(t) = Q(t) \cdot \frac{P_0}{a \cdot \bar{Q}_{\text{hist}}}$$

using the linear relation between runoff and hydro power production and the future runoff $Q(t)$ (Schlott et al., 2018).

Demand

To calculate future demand, a quadratic regression is performed between historic temperatures and historic demand data as in (Zhang & Ayyub, 2020). The parameters derived here are then used to scale future demand time series.

Acknowledgements

The tool was partly developed in the project StEAM under funding from the German Federal Ministry for Economic Affairs and Climate Action (funding code 03EI1043A).

References

Abdin, I. F., Fang, Y.-P., & Zio, E. (2019). A modeling and optimization framework for power systems design with operational flexibility and resilience against extreme heat waves and drought events. *Renewable and Sustainable Energy Reviews*, *112*, 706–719. https://doi.org/10.1016/j.rser.2019.06.006

Cannon, A. J., Sobie, S. R., & Murdock, T. Q. (2015). Bias Correction of GCM Precipitation by Quantile Mapping: How Well Do Methods Preserve Changes in Quantiles and Extremes? *Journal of Climate*, *28*(17), 6938–6959. https://doi.org/10.1175/JCLI-D-14-00754.1

DeCarolis, J., Daly, H., Dodds, P., Keppo, I., Li, F., McDowall, W., Pye, S., Strachan, N., Trutnevyte, E., Usher, W., Winning, M., Yeh, S., & Zeyringer, M. (2017). Formalizing best practice for energy system optimization modelling. *Applied Energy*, *194*, 184–198. https://doi.org/10.1016/j.apenergy.2017.03.001

Dosio, A., & Fischer, E. M. (2018). Will Half a Degree Make a Difference? Robust Projections of Indices of Mean and Extreme Climate in Europe Under 1.5°C, 2°C, and 3°C Global Warming. *Geophysical Research Letters*, *45*(2), 935–944. https://doi.org/10.1002/2017GL076222

Formayer, H., Nadeem, I., Leidinger, D., Maier, P., Schöniger, F., Suna, D., Resch, G., Totschnig, G., & Lehner, F. (2023). SECURES-Met: A European meteorological data set suitable for electricity modelling applications. *Scientific Data*, *10*(1), 590. https://doi.org/10.1038/s41597-023-02494-4

Härtel, P. (2024). *REWARDS - robuste entwicklung des energiesystems zur wahrung der energiesicherheit*. Fraunhofer IEE. https://www.iee.fraunhofer.de/de/projekte/suche/2024/rewards.html

Hofmann, F., Hampp, J., Neumann, F., Brown, T., & Hörsch, J. (2021). atlite: A Lightweight Python Package for Calculating Renewable Power Potentials and Time Series. *Journal of Open Source Software*, *6*(62), 3294. https://doi.org/10.21105/joss.03294

DRAFT

Holmgren, W., Hansen, C., & Mikofski, M. (2018). Pvlib python: A python package for modeling solar energy systems. *Journal of Open Source Software*, *3*(29), 884. https://doi.org/10.21105/joss.00884

Jacob, D., Petersen, J., Eggert, B., Alias, A., Christensen, O. B., Bouwer, L. M., Braun, A., Colette, A., Déqué, M., Georgievski, G., Georgopoulou, E., Gobiet, A., Menut, L., Nikulin, G., Haensler, A., Hempelmann, N., Jones, C., Keuler, K., Kovats, S., … Yiou, P. (2014). EURO-CORDEX: new high-resolution climate change projections for European impact research. *Regional Environmental Change*, *14*(2), 563–578. https://doi.org/10.1007/s10113-013-0499-2

Jerez, S., Thais, F., Tobin, I., Wild, M., Colette, A., Yiou, P., & Vautard, R. (2015). The CLIMIX model: A tool to create and evaluate spatially-resolved scenarios of photovoltaic and wind power development. *Renewable and Sustainable Energy Reviews*, *42*, 1–15. https://doi.org/10.1016/j.rser.2014.09.041

microsoft. (2024). Wsl. In *GitHub repository*. GitHub. https://github.com/microsoft/WSL

Mölder, F., Jablonski, K. P., Letcher, B., Hall, M. B., Tomkins-Tinch, C. H., Sochat, V., Forster, J., Lee, S., Twardziok, S. O., Kanitz, A., Wilm, A., Holtgrewe, M., Rahmann, S., Nahnsen, S., & Köster, J. (2021). Sustainable data analysis with Snakemake. *F1000Research*, *10*, 33. https://doi.org/10.12688/f1000research.29032.2

Muñoz Sabater, J. (2019). *ERA5-Land hourly data from 1981 to present.* (Copernicus Climate Change Service, Ed.). ECMWF. https://doi.org/10.24381/cds.e2161bac

Pfenninger, S., & Staffell, I. (2016). Long-term patterns of European PV output using 30 years of validated hourly reanalysis and satellite data. *Energy*, *114*, 1251–1265. https://doi.org/10.1016/j.energy.2016.08.060

Plaga, L. S., & Bertsch, V. (2022). Robust planning of a European Electricity System under climate uncertainty. *2022 18th International Conference on the European Energy Market (EEM)*, 1–8. https://doi.org/10.1109/EEM54602.2022.9921057

Plaga, L. S., & Bertsch, V. (2023). Methods for assessing climate uncertainty in energy system models — A systematic literature review. *Applied Energy*, *331*, 120384. https://doi.org/10.1016/j.apenergy.2022.120384

Schlott, M., Kies, A., Brown, T., Schramm, S., & Greiner, M. (2018). The impact of climate change on a cost-optimal highly renewable European electricity network. *Applied Energy*, *230*, 1645–1659. https://doi.org/10.1016/j.apenergy.2018.09.084

Schulzweida, U. (2020). *CDO User Guide*. Zenodo. https://doi.org/10.5281/zenodo.5614769

Staffell, I., & Pfenninger, S. (2016). Using bias-corrected reanalysis to simulate current and future wind power output. *Energy*, *114*, 1224–1239. https://doi.org/10.1016/j.energy.2016.08.068

van der Wiel, K., Stoop, L. P., van Zuijlen, B. R. H., Blackport, R., van den Broek, M. A., & Selten, F. M. (2019). Meteorological conditions leading to extreme low variable renewable energy production and extreme high energy shortfall. *Renewable and Sustainable Energy Reviews*, *111*, 261–275. https://doi.org/10.1016/j.rser.2019.04.065

WCRP. (2024). *CORDEX: Coordinated Regional Climate Downscaling Experiment*. https://cordex.org/

Zhang, Y., & Ayyub, B. M. (2020). Electricity System Assessment and Adaptation to Rising Temperatures in a Changing Climate Using Washington Metro Area as a Case Study. *Journal of Infrastructure Systems*, *26*(2), 04020017. https://doi.org/10.1061/(ASCE)IS.1943-555X.0000550

DRAFT