# Sensor fusion combines measurements according to their uncertainty

**Two noisy measurements of one state**

$$z \sim \mathcal{N}(\mu_z, \Sigma_z)\ x \mid z \sim \mathcal{N}(z, \Sigma_x), \quad y \mid z \sim \mathcal{N}(z, \Sigma_y)$$

**Same two operations**

$$p(z \mid x, y) \quad \rightarrow \quad E[z \mid x, y]$$




Course schematic after Murphy, Book 2 §2.3.2.3, Fig. 2.10; `sensor_fusion_figure.ipynb`

- Equal uncertainty puts the posterior mean between the measurements
- A more precise sensor pulls the posterior mean closer to its measurement
- With anisotropic uncertainty, the weighting can differ by direction