Audit Report for Audit ID - AU00522-4 <u>Water Analysis Report</u>

Audit Score 100/100

Details

Audit	AU00522
Scheduled Audit	AU00522-4
Location	Hyderabad
Hotel	Marigold Hotel
Department	Micro Lab
Checklist	Water Analysis Report
Audit Type	Internal
Auditor	Micro Lab
Start Date	04-06-2019
End Date	04-06-2019
Submitted Date	04-06-2019
Status	Completed
Assigned By	Administrator Account
Non-Compliance	0
Chronic Issues	0

Comparison

MARIGOLD HOTEL WATER ANALYSIS REPORT

WATER ANALYSIS REPORT		Jun 2019	Jun 2019	VARIANCE	% of Increase / Decrease (-/	
S.No	Sections	SCORE OBTAINED	SCORE OBTAINED		+)	
1	Water Analysis	100	100	0	0%	
Aud	dit Score	1 00	1 00	0	0%	

•	80-100 = Green	Good / Excellent
	61-79 = Yellow	Average
-	60 below is Red	Poor / Fair

Non-Compliance

No non-compliances found

Chronic

No chronic issues found

Audit Questionnaire

Section: Water Analysis **Subsection:** Swimming Pool

1: Total Hardness (in ppm) 200-300 PPM

Yes

2: Total Disloved solids (TDS In PPM) <500 PPM

Yes

3: Chlorine (In PPM) 2-3 PPM

Yes

4: PH 6.5-8.5

Yes

Section: Water Analysis **Subsection:** Laundry

1: Total Hardness (In PPM) <100 PPM

Yes

2: Total Disloved Solids (In PPM) <500 PPM

Yes

3: Chlorine (In PPM) NIL

Yes

4: PH 6.5-8.5

Yes

Section: Water Analysis **Subsection:** Dish Wash

1: Total Hardness (In PPM) <100 PPM

Yes

2: Total Disloved Solids (In PPM) <500 PPM

Yes

3: Chlorine (In PPM) NIL

Yes

4: PH 6.5-8.5

Yes

Section: Water Analysis **Subsection:** RO Water

- 1: Total Hardness (In PPM) <20 PPM

 Yes
- 2: Total Disloved Solids (In PPM) <100 PPM
 - Yes
- 3: Chlorine (In PPM) NIL
 - Yes
- 4: PH 6.5-8.5
 - Yes