

Audit Report for Audit ID - AU00556-7

Water Analysis Report

Audit Score

100/100

Details

Audit	AU00556
Scheduled Audit	AU00556-7
Location	Hyderabad
Hotel	Marigold Hotel
Department	Micro Lab
Checklist	Water Analysis Report
Audit Type	Internal
Auditor	Micro Lab
Start Date	08-07-2019
End Date	08-07-2019
Submitted Date	08-07-2019
Status	Completed
Assigned By	Administrator Account
Non-Compliance	0
Chronic Issues	0

Comparison

MARIGOLD HOTEL WATER ANALYSIS REPORT

WATER ANALYSIS REPORT		Jul 2019	Jul 2019	VARIANCE	% of Increase / Decrease (-/+)
S.No	Sections	SCORE OBTAINED	SCORE OBTAINED		
1	Water Analysis	100	100	0	0%
Audit Score		● 100	● 100	0	0%

	80-100 = Green	Good / Excellent
	61-79 = Yellow	Average
	60 below is Red	Poor / Fair

Non-Compliance

No non-compliances found

Chronic

No chronic issues found

Audit Questionnaire

Section: Water Analysis**Subsection:** Swimming Pool

- 1: Total Hardness (in ppm) 200-300 PPM
☒ Yes
- 2: Total Disolved solids (TDS In PPM) <500 PPM
☒ Yes
- 3: Chlorine (In PPM) 2-3 PPM
☒ Yes
- 4: P H 6.5-8.5
☒ Yes

Section: Water Analysis**Subsection:** Laundry

- 1: Total Hardness (In PPM) <100 PPM
☒ Yes
- 2: Total Disolved Solids (In PPM) <500 PPM
☒ Yes
- 3: Chlorine (In PPM) NIL
☒ Yes
- 4: P H 6.5-8.5
☒ Yes

Section: Water Analysis**Subsection:** Dish Wash

- 1: Total Hardness (In PPM) <100 PPM
☒ Yes
- 2: Total Disolved Solids (In PPM) <500 PPM
☒ Yes
- 3: Chlorine (In PPM) NIL
☒ Yes
- 4: P H 6.5-8.5
☒ Yes

Section: Water Analysis**Subsection:** RO Water

1: Total Hardness (In PPM) <20 PPM

☒ Yes

2: Total Disolved Solids (In PPM) <100 PPM

☒ Yes

3: Chlorine (In PPM) NIL

☒ Yes

4: P H 6.5-8.5

☒ Yes