

The Institute of Fire Safety Managers
IFSM
Member

IFE The Institution of Fire Engineers

REGULATORY REFORM (FIRE SAFETY) ORDER 2005 FIRE RISK ASSESSMENT

PAS 79-2 Housing

Annex A England & Wales

Copyright and Acknowledgement

The copyright of this template and the pages and photos contained within is owned by Soldorlet.com Ltd.

Soldorlet.com Ltd would like to thank and acknowledge, Mr. Colin Todd, MBE, Managing Director of C.S. Todd & Associates, for providing permission to duplicate his template.

Soldorlet.com Ltd is authorised and regulated by IFSM member 2394 and the IFE member 75107 for carrying out Fire risk assessments referred to as FRA's for short purposes.

Our offices are located at the following locations;

Unit 29 Highcroft Industrial Estate, Enterprise Road, Waterlooville, Hampshire, PO8 0BT

and

21 Oxford Street, Mountain Ash, Rhondda Cynon Taff, CF45 3PL

Inspector details for completion of this report are as follows;

Date of report: 1st April 2026

Gareth Jones - Fire risk assessor IFSM/IFE (oversight)

Ian Jones - Trainee

Address for report with front picture:

The Barn Hotel, West End Road, Ruislip, HA4 6JB





REGULATORY REFORM (FIRE SAFETY) ORDER 2005
FIRE RISK ASSESSMENT

Responsible person (e.g. employer) or person having control of the premises:	Biju Ramakrishnan
Address of premises:	The Barn Hotel, West End Road, Ruislip, HA4
Person(s) consulted:	Responsible Person and staff on site
Assessor: :	Gareth Jones - Assessor Ian Jones - Assessor
Date of fire risk assessment:	1st April 2026
Date of previous fire risk assessment:	26th March 2025
Suggested date for review:	1st April 2027

This report is intended to assist you in compliance with Article 9 of the Regulatory Reform (Fire Safety) Order 2005 (the “Fire Safety Order”), which requires that a risk assessment be carried out.

1st April 2026 [Date]

GENERAL INFORMATION

1. THE PREMISES (*Clause 12)*

1.1	Number of floors at ground level and above:	2
	Number of floors entirely below ground level:	0
	Floors on which car parking is provided:	0
1.2	Number of flats:	74 units sleeping accommodation

1.3 Brief details of construction and approximate age of building:

built in 1528, renovated throughout in 2011- standard construction including modern buildings to the rear

1.4 Occupancy:

temporary accommodation - 74 units mainly double/twin. (sleeps 148)

2. THE OCCUPANTS *(Clause 12)*

2.1	Approximate maximum number of employees at any one time:	5
2.2	Approximate maximum number of residents and visitors at any one time:	17

3. OCCUPANTS ESPECIALLY AT RISK FROM FIRE *(Clause 12)*

3.1	Sleeping occupants:	150 approx
3.2	Occupants in remote areas and lone workers:	2
3.3	Others:	2

4. FIRE LOSS EXPERIENCE

None noted

5. OTHER RELEVANT INFORMATION

Temporary accommodation, sleeping visitors who will be familiar with grounds and multiple buildings contained within ths site set up.

Overhead plan contained below.



6. RELEVANT FIRE SAFETY LEGISLATION

6.1 The following fire safety legislation applies to these premises:

The Building Act 1984	Building Safety Act 2022
Building regulations 2010	Fire Safety Act 2021
Fire Safety Order 2005	LACORS

6.2 The above legislation is enforced by:

London Fire Brigade -
Ruislip Fire Station, 8 Reservoir Road, HA4 7TT

6.3 Other legislation that makes significant requirements for fire precautions in these premises [other than the Building Regulations 2010 (as amended)]:

Temporary accommodation team

6.4 The other legislation referred to above is enforced by:

Hillingdon Local authority / Council

6.5 Is there an alterations notice in force? Yes [ ] No [X]

Relevant information and deficiencies observed:

FIRE HAZARDS AND THEIR ELIMINATION OR CONTROL

7. ELECTRICAL SOURCES OF IGNITION *(Clause 13 and Annex B)*

7.1 Are reasonable measures taken to prevent fires of electrical origin? Yes [X] No [ ]

7.2 More specifically:

a) Are fixed installations periodically inspected and tested? N/A [ ] Yes [X] No [ ]

b) Is portable appliance testing carried out? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

A Master Log is held on site and holds dates and times of testing carried out on site.

8. SMOKING *(Clause 13 and Annex B)*

8.1 Are reasonable measures taken to prevent fires as a result of smoking? Yes [X] No [ ]

8.2 More specifically:

a) Is smoking prohibited in appropriate areas? N/A [ ] Yes [X] No [ ]

b) Are there suitable arrangements for those who wish to smoke? N/A [ ] Yes [X] No [ ]

c) Did the smoking policy appear to be observed at time of inspection? N/A [ ] Yes [X] No [ ]

d) Are “No smoking” signs provided in the common areas? Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

No smoking policy in place and all buildings contained signs with no smoking. smoking bins provided.

9. ARSON *(Clause 13 and Annex B)*

9.1 Does basic security against arson by outsiders appear reasonable[1)]? Yes [X] No [ ]

9.2 Is there an absence of unnecessary fire load in close proximity to the premises or available for ignition by outsiders? Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

All store cupboards locked and contained no flammables

10. PORTABLE HEATERS AND HEATING AND VENTILATION INSTALLATIONS *(Clause 13 and Annex B)*

10.1 Is there satisfactory control over the use of portable heaters? N/A [ ] Yes [X] No [ ]

10.2 Are fixed heating and ventilation installations subject to regular maintenance? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

11. COOKING *(Clause 13 and Annex B)*

11.1 Are reasonable measures taken to prevent fires as a result of cooking? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

[1)] Reasonable only in the context of this fire risk assessment. If specific advice on security (including security against arson) is required, this should be obtained from a security specialist.

12. LIGHTNING *(Clause 13 and Annex B)*

12.1 Does the building have a lightning protection system? Yes [ ] No [X]

Relevant information and deficiencies observed:

Buildings too small to have lightning protection.

13. HOUSEKEEPING *(Clause 13 and Annex B)*

13.1 Is the overall standard of housekeeping adequate? Yes [X] No [ ]

13.2 More specifically:

a) Do combustible materials appear to be separated from ignition sources? Yes [X] No [ ]

b) Is unnecessary accumulation or inappropriate storage of combustible materials or waste avoided? Yes [X] No [ ]

c) Are gas and electricity intake/meter cupboards adequately secured and kept clear of combustible materials? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Meter intake cupboards secure under lock and key

14. HAZARDS INTRODUCED BY OUTSIDE CONTRACTORS AND BUILDING WORKS *(Clause 13 and Annex B)*

14.1 Is there satisfactory control over works carried out in the building by contractors? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Sign in log book seen and completed when maintenance on site.

15. DANGEROUS SUBSTANCES[2] *(Clause 13)*

15.1 Are the general fire precautions adequate to address the hazards associated with dangerous substances used or stored within the premises[3]?

N/A [ ] Yes [X] No [ ]

Relevant information and deficiencies observed:

Cleaners lockable cupboard seen on site.

16. OTHER SIGNIFICANT FIRE HAZARDS THAT WARRANT CONSIDERATION

16.1 Hazards:

None

Relevant information and deficiencies observed:

[2] For the purpose of this risk assessment and the Fire Safety Order, dangerous substances are primarily explosive, highly flammable or flammable substances and oxidizing agents.

[3] Small quantities with negligible impact on the appropriate fire precautions need not be taken into account.

FIRE PROTECTION MEASURES

17. MEANS OF ESCAPE *[Clause 15c) and Annex C]*

17.1 Is the design and maintenance of the means of escape considered adequate? Yes [X] No [ ]

17.2 More specifically:

a) Are there reasonable distances of travel:

- where there is escape in a single direction? N/A [ ] Yes [X] No [ ]
- where there are alternative means of escape? N/A [ ] Yes [X] No [ ]

b) Is there adequate provision of exits? N/A [ ] Yes [X] No [ ]

c) Do fire exits open in the direction of escape, where necessary? N/A [ ] Yes [X] No [ ]

d) Are the arrangements provided for securing exits satisfactory? N/A [ ] Yes [X] No [ ]

e) Is the fire-resisting construction (including any glazing) protecting escape routes and staircases of a suitable standard and maintained in sound condition? N/A [ ] Yes [X] No [ ]

f) Is the fire resistance of doors to staircases and the common areas considered adequate, and are the doors maintained in sound condition? N/A [ ] Yes [X] No [ ]

g) Are suitable self-closing devices fitted to doors in the common areas? N/A [ ] Yes [X] No [ ]

h) Is the fire resistance of doors to meter cupboards/store rooms/plant rooms in the common areas considered adequate, and are they adequately secured and/or fitted with suitable self-closing devices? N/A [ ] Yes [X] No [ ]

i) Is the fire resistance of flat entrance doors considered adequate, and are doors maintained in sound condition? N/A [ ] Yes [X] No [ ]

j) Are suitable self-closing devices fitted to flat entrance doors and, where fitted, maintained in good working order? N/A [ ] Yes [X] No [ ]

k) Are there adequate smoke control provisions to protect the common escape routes, where necessary? N/A [ ] Yes [X] No [ ]

l) Are all escape routes clear of obstructions? N/A [ ] Yes [X] No [ ]

m) Are all fire exits easily and immediately openable? N/A [ ] Yes [X] No [ ]

n) Is it considered that the premises are provided with reasonable arrangements for means of escape for disabled people? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

18. MEASURES TO LIMIT FIRE SPREAD AND DEVELOPMENT *[Clause 15g)]*

18.1 Is it considered that there is/are:

a) adequate levels of compartmentation between floors and between flats and the common escape routes? Yes [X] No [ ]

b) reasonable limitation of linings to escape routes that might promote fire spread? Yes [X] No [ ]

c) as far as can reasonably be ascertained, reasonable fire separation within any roof space? N/A [ ] Yes [X] No [ ]

d) adequately fire protected service risers and/or ducts in common areas, that will restrict the spread of fire and smoke? N/A [ ] Yes [X] No [ ]

18.2 As far as can reasonably be ascertained, are fire dampers provided as necessary to protect critical means of escape against passage of fire, smoke and products of combustion in the early stages of a fire[4), 5)]? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

We have accessed all areas and checked compartmentation thoroughly.

19. EMERGENCY ESCAPE LIGHTING *[Clause 15e)]*

19.1 Has a reasonable standard of emergency escape lighting been provided[6)]? N/A ☐ Yes ☒ No ☐

Relevant information (including description of arrangements and deficiencies observed):

20. FIRE SAFETY SIGNS AND NOTICES *[Clause 15d)]*

20.1 Is there a reasonable standard of fire safety signs and notices? N/A ☐ Yes ☒ No ☐

Relevant information (including description of arrangements and deficiencies observed):

21. MEANS OF GIVING WARNING IN CASE OF FIRE *[Clause 15b)]*

21.1 Is a reasonable fire detection and fire alarm system provided in the common areas, where necessary[7)]? N/A ☐ Yes ☒ No ☐

21.2 If there is a communal fire detection and fire alarm system, does it extend into the dwellings? N/A ☐ Yes ☒ No ☐

[6)] Based on visual inspection, but no test of illuminance levels or verification of full compliance with relevant British Standards carried out.

[7)] Based on visual inspection, but no audibility tests or verification of full compliance with relevant British Standard carried out.

21.3 Where appropriate, has a fire alarm zone plan been provided? N/A [ ] Yes [X] No [ ]

21.4 Where appropriate, are there adequate arrangements for silencing and resetting an alarm condition? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Relevant information on false alarm experience (if known):

None reported.

22. MANUAL FIRE EXTINGUISHING APPLIANCES *[Clause 15f)]*

22.1 Is there reasonable provision of manual fire extinguishing appliances? N/A [ ] Yes [X] No [ ]

22.2 Are all fire extinguishing appliances readily accessible? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Please note extinguishers provided for trained use only and not for residents to use. (unless residents have been trained on safe use and operation)

23. RELEVANT AUTOMATIC FIRE EXTINGUISHING SYSTEMS[8)] *[Clause 15h)]*

23.1 Type of fixed system:

N/A

Relevant information and deficiencies observed:

N/A

24. OTHER RELEVANT FIXED SYSTEMS AND EQUIPMENT[9)] *[Clause 15i)]*

24.1 Type of fixed system:

N/A

Relevant information and deficiencies observed:

N/A

24.2 Are there appropriately sited facilities for electrical isolation of any photovoltaic (PV) cells, with appropriate signage, to assist the fire and rescue service?

N/A [X] Yes [ ] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

[8)] Relevant to life safety and this risk assessment (as opposed to property protection).

[9)] Relevant to life safety and this risk assessment (as opposed to property protection).

MANAGEMENT OF FIRE SAFETY

25. PROCEDURES AND ARRANGEMENTS *(Clause 16)*

25.1 Safety assistance:

The competent person(s) appointed under Article 18 of the Fire Safety Order to assist the responsible person in undertaking the preventive and protective measures (i.e. relevant general fire precautions) is:

Gareth Jones - IFSM

25.2 Fire safety at the premises is managed by[10)]:

Responsible Person / Site Manager / Staff on site.

25.3 Is there a suitable record of the fire safety arrangements? Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

25.4 Evacuation strategy

- [ ] Stay put
- [X] Simultaneous evacuation
- [ ] Other (please specify below)

Comment:

Evacuation per block on site.

[10)] This is not intended to represent a legal interpretation of responsibility, but merely reflects the managerial arrangement in place at the time of this risk assessment.

25.5 Are procedures in the event of fire appropriate and properly documented, where appropriate[11)]? Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Fire strategy in place

25.6 Are routine in-house inspections of fire precautions undertaken (e.g. in the course of health and safety inspections)? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Monthly Checks in place.

26. TRAINING AND DRILLS *[Clause 16h)]*

26.1 Are all staff given adequate fire safety instruction and training? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

26.2 When the employees of another employer work in the premises, is appropriate information on fire risks and fire safety measures provided? N/A [ ] Yes [X] No [ ]

[11)] Based on brief review of procedures at the time of this fire risk assessment. In-depth review of documentation is outside the scope of this fire risk assessment, unless otherwise stated.

Relevant information (including description of arrangements and deficiencies observed):

27. TESTING AND MAINTENANCE *[Clause 16j)]*

27.1 Is there adequate maintenance of the premises? Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

27.2 Is weekly testing and periodic servicing of the fire detection and fire alarm system undertaken? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

27.3 Are monthly and annual testing routines in place for the emergency escape lighting? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

27.4 Is annual maintenance of fire extinguishing appliances undertaken? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

27.5 Are six-monthly inspection and annual testing of rising mains undertaken? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

27.6 Are weekly and monthly testing, six-monthly inspection, and annual inspection and testing undertaken of lift(s) provided for use by firefighters or evacuation of disabled people (evacuation lifts)? N/A [ ] Yes [X] No [ ]

Relevant information (including description of arrangements and deficiencies observed):

Lifts in rear modern building not in use and turned off/isolated

27.7 Other relevant inspections or tests:

N/A

Relevant information (including description of arrangements and deficiencies observed):

N/A

28. RECORDS *[Clause 16k)]*

28.1 Are there appropriate records of:

a) Fire alarm tests (where relevant)? N/A ☐ Yes ☒ No ☐

b) Emergency escape lighting tests? N/A ☐ Yes ☒ No ☐

c) Maintenance and testing of other fire protection systems and equipment? N/A ☐ Yes ☒ No ☐

Relevant information (including description of arrangements and deficiencies observed):

29. PREMISES INFORMATION BOX *[Clause 15c)]*

29.1 Is there a suitably located premises information box for the fire and rescue service?[12)] N/A ☐ Yes ☒ No ☐

29.2 Are there arrangements to keep the premises information box up to date?[12)] N/A ☐ Yes ☒ No ☐

Relevant information (including description of arrangements and deficiencies observed):

[12)] Normally applicable only to sheltered and extra care housing.

30. ENGAGEMENT WITH RESIDENTS *[Clause 16l)]*

30.1	Has information on fire procedures been disseminated to residents?	N/A		Yes	X	No	
30.2	Is fire safety information disseminated to residents?	N/A		Yes	X	No	

Relevant information (including description of arrangements and deficiencies observed):

FIRE RISK ASSESSMENT

The following simple risk level estimator is based on a commonly used risk level estimator:

Potential consequences of fire ➔ **Likelihood of fire ➔**	**Slight harm**	**Moderate harm**	**Extreme harm**
Low	**Trivial risk**	**Tolerable risk**	**Moderate risk**
Medium	**Tolerable risk**	**Moderate risk**	**Substantial risk**
High	**Moderate risk**	**Substantial risk**	**Intolerable risk**

Taking into account the fire prevention measures observed at the time of this risk assessment, it is considered that the hazard from fire (likelihood of fire) at these premises is:

Low [X] **Medium** [ ] **High** [ ]

In this context, a definition of the above terms is as follows:

Low: Unusually low likelihood of fire as a result of negligible potential sources of ignition.

Medium: Normal fire hazards (e.g. potential ignition sources) for this type of occupancy, with fire hazards generally subject to appropriate controls (other than minor shortcomings).

High: Lack of adequate controls applied to one or more significant fire hazards, such as to result in significant increase in likelihood of fire.

Taking into account the nature of the premises and the occupants, as well as the fire protection and procedural arrangements observed at the time of this fire risk assessment, it is considered that the consequences for life safety in the event of fire would be:

Slight harm [X] **Moderate harm** [ ] **Extreme harm** [ ]

In this context, a definition of the above terms is as follows:

Slight harm: Outbreak of fire unlikely to result in serious injury or death of any occupant.

Moderate harm: Outbreak of fire could foreseeably result in injury (including serious injury) of one or more occupants, but is unlikely to result in multiple fatalities.

Extreme harm: Significant potential for serious injury or death of one or more occupants.

Accordingly, it is considered that the risk to life from fire at these premises is:

Trivial [ ] **Tolerable** [X] **Moderate** [ ] **Substantial** [ ] **Intolerable** [ ]

Comments:

The buildings will have sleeping residents who will be always be made aware of the site and procedures by staff on induction into the accommodation.

Most guests will stay short term, but will change regularly.

A suitable risk-based control plan should involve effort and urgency that are proportional to risk. The following risk-based control plan is based on one advocated for general health and safety risks:

Risk level	Action and timescale
Trivial	No action is required, and no detailed records need be kept.
Tolerable	No major additional controls required. However, there might be a need for improvements that involve minor or limited cost.
Moderate	It is essential that efforts are made to reduce the risk. Risk reduction measures should be implemented within a defined time period. Where moderate risk is associated with consequences that constitute extreme harm, further assessment might be required to establish more precisely the likelihood of harm as a basis for determining the priority for improved control measures.
Substantial	Considerable resources might have to be allocated to reduce the risk. If the building is unoccupied, it should not be occupied until the risk has been reduced. If the building is occupied, urgent action should be taken.
Intolerable	Building (or relevant area) should not be occupied until the risk is reduced.

Note that, although the purpose of this section is to place the fire risk in context, the above approach to risk assessment is subjective and for guidance only. All hazards and deficiencies identified in this report should be addressed by implementing all recommendations contained in the following action plan. The fire risk assessment should be repeated regularly.

ACTION PLAN

It is considered that the following actions should be implemented in order to reduce fire risk to, or maintain it at, the following level:

Trivial [X] **Tolerable** [ ]

Definition of priorities (where applicable):

Staff on site 24 hours a day.
Sleeping residents but a very good early warning system in place
Fire doors and fire stopping / compartmentation in place is very good.

Item	Recommendation	Priority	Timescale
1.	personal items stored in hallways / trip hazard	non urgent	1 month
2.			
Interim measures (where appropriate)			
3.			