

LEGIONELLA RISK ASSESSMENT

for residential property

☑ Landlord copy
☐ Tenant copy

Ref Barn Hotel 001499

Completed on 01-Apr-2026 by Gareth Jones

Disclaimer

The assessors believe the information contained within this risk assessment report to be correct at the time of printing. The assessors do not accept responsibility for any consequences arising from the use of the information herein. The report is based on matters which were observed or came to the attention of the assessors during the day of the assessment and should not be relied upon as an exhaustive record of all possible risks or hazards that may exist or potential improvements that can be made.

Further information could be found in www.hse.gov.uk/pubns/indg458.pdf and always refer to the latest publication.

Confidentiality Statement

In order to maintain the integrity and credibility of the risk assessment processes and to protect the parties involved, it is understood that the assessors will not divulge to unauthorized persons any information obtained during this risk assessment unless legally obligated to do so.



Legionella Risk Assessment

for residential property

Property and Assessment Info

Property address:	The Barn Hotel West End Road Ruislip HA4 6JB	**Assessment date:** **Reference:** **Assessor name:**	01-Apr-2026 Barn Hotel 001499 Gareth Jones
Tenant name:	Multiple Units	**Property type:**	Other Hotel Accommodation

Management Responsibilities

Duty holder name:	Catherine Virdee	**Contact details:**	The Barn Hotel
Responsible person:	Landlord Manager	**Contact details:**	07717168282

Legionella Awareness

Assessed - OK

Has the tenant read and understand the potential risk of exposure of Legionnaire's diseases and its consequences?	☐
Has the tenant been advised the risks and responsibilities to minimise the risk of Legionnaire's diseases?	☐
Is there any tenant, resident or regular visitor particularly prone to Legionella due to age, health or lifestyle?	☐

Water System and Storage

Assessed - OK

Hot water system:	Via boiler	**Cold water system:**	Mains
Boiler location:	Storage Cupboard	Hot water temperature between 55°C and 60°C	☐
Water tank location:	Ceiling Space	Cold water tank temperature below 20°C	☐

Hot / Cold Water Outlet Temperature

Assessed - OK

Basin(s):	Clean	☐	Cold temperature below 20°C	☐	Hot temperature above 50°C	☐
Bath(s):	Clean	☐	Cold temperature below 20°C	☐	Hot temperature above 50°C	☐
Shower(s):	Clean	☐	Cold temperature below 20°C	☐	Hot temperature above 50°C	☐
Kitchen sink(s):	Clean	☐	Cold temperature below 20°C	☐	Hot temperature above 50°C	☐
Other(s):	Clean	☐	Cold temperature below 20°C	☐	Hot temperature above 50°C	☐

Legionella Risk Assessment

for residential property

Little Used Outlets (outlets used lesser than once per week)

Assessed - OK

Outlet(s) location:	All units		**Pool / Hot tub**	☐	**Spa / Jacuzzi**	☐
Has little use outlet flushed through weekly by running water for 5 mins?				☐	by Landlord Duty Manager	
Little used outlet:	Clean	☐	Cold temperature below 20ºC	☐	Hot temperature above 50ºC	☐

Dead Legs and Redundant Pipework

Assessed - OK

Pipe location:	None (now removed)	If dead legs exist in the pipework, are they to be removed or system to be altered for regular water flows through pipework?	☐

Unoccupied Properties (unoccupied for periods of time, e.g. short let, holidays)

Assessed - OK

Has little use outlet flushed through weekly by running water for 5 mins?				☐	by Landlord	
All outlets:	Clean	☐	Cold temperature below 20ºC	☐	Hot temperature above 50ºC	☐

Defects / Risk (any of the above)

None noted, tests proceeded and supplied on accompanying document. All vacant units to be flushed on all faucets and water outlets prior to occupation. Cleaning - Deep cleaning was undertaken on site throughout	**Responsible person:** Catherine Virdee

Actions / Recommendations (in response to the defects / risks)

All vacant units to be flushed on all faucets and water outlets prior to occupation. Cleaning - Deep cleaning was undertaken on site throughout	**Responsible person:** Catherine Virdee

The assessment should be reviewed at least once a year and specifically when there is reason to suspect it is no longer valid. Both the landlord and tenant should ensure the recommendations above are implemented and any existing controls maintained.

Assessor Signature

Signature:	**Printed name:**	**Date:**
Digitally signed by Gareth Jones Date: 2026.04.01	Gareth Jones	01-Apr-2026

Information leaflet for the control of legionella in hot and cold water systems for occupiers of residential property

The landlord is committed to protecting the health and safety of the tenants and recognise that the risks from legionella bacteria may arise within the residential property.

Legionnaires' disease is a form of pneumonia caused by the legionella bacterial and can kill. Legionella are bacteria common in natural rivers, lakes and artificial water systems such as hot and cold water systems, storage tanks, pipe work, taps and showers.

Other possible sources of legionella include spa and whirlpool bath, humidifiers, drinking water systems, water features, garden hoses and sprinklers.

Legionella bacteria can survive in low temperatures but thrive between 20°C and 45°C. Temperatures above 50°C will kill the bacteria. The infection is caused by the inhalation of water droplets or spray-mists which have been contaminated by the bacteria. Those most at risk include elderly people, smokers, heavy drinkers and those suffering from long term illness. **It is not contacted through drinking contaminated water and cannot be passed from person to person.**

The risk is very small but to ensure legionella remains under control, always ensure you do the following:

- Ensure the temperature of the hot water setting on the boiler is set to at least 55°C (up to 60°C)
- Before you move in and if you go away for more than a week, heat the water to 60°C for at least one hour and then run all taps on full heat for 5 minutes.
- Shower heads should be disinfected, dismantled, descaled and cleaned by the occupier quarterly or as indicated by the rate of fouling. If occupants have long term illness, smoker, heavy drinker or elderly, cleaning should be more regular
- Inform the landlord if the hot water does not heat up properly or your cold water becomes too warm
- If there are any unused taps for example an outside garden tap or unused second toilet with hand basin, these must be run weekly throughout the tenancy
- If there a spa pool (hot tub, whirlpool bath, spa bath, etc.) this MUST be disinfected AFTER EVERY USE according to the manufacturer's instructions

Keep it clean, keep it moving, keep the hot, hot and the cold, cold.



IMPORTANT NOTICE

Raising the temperature of warm water is one way to control legionella growth but could also increase the risk of burns and scalding. Please take care especially if you have children.

