STRUCTURAL SAFETY

- 3.1 Introduction
- 3.2 Concept of Structural Safety
- 3.3 Modern Approach to Structural Safety
- 3.4 Structural Safety and Cost
- 3.5 Limit State Design
- 3.6 Safety Provisions in TS-500
- 3.7 Quality Control

Safety cannot be accomplished solely in the design stage. A close supervision of the construction is as important as the design itself. As a matter of fact, construction faults and poor material quality have been the cause of most of the failures reported.

According to TS-500, concrete quality should be controlled by taking samples from the concrete used on the site.

- At least 3 cylinder samples should be taken for each 50 m³ of concrete placed (or 3 samples from every floor).
- For concrete grades higher than C25, the number of samples taken should be doubled.
- A detailed description how the samples should be taken, placed, compacted and cured are given in the related Turkish Standards (TS-2940, TS-3068 and TS-3351). Testing procedure is described in TS-3114.

For the acceptance of concrete the following inequalities should be satisfied (TS-500):

$$\bar{f}_{cm} \ge f_{ck} + 1.0 \, MPa$$
 and $f_{cmin} \ge f_{ck} - 3 \, MPa$

In these equations f_{cm} is the average of strengths obtained from three cylinders. f_{cmin} is the minimum strength obtained from the three samples tested

If these equations are not satisfied, then the member capacities should be recalculated using the actual concrete strength, which is lower than the specified value. If it is concluded that the capacity of some members have decreased significantly, then necessary precautions should be taken.

The variation in strength of concrete can be expressed in terms of "coefficient of variation" in place of the standard deviation.

$$\upsilon = \frac{\overline{\sigma}}{f_{cm}}$$
 or $f_{cm} = \frac{f_{ck}}{(1 - u\upsilon)}$

Supervision	Very good	Good	Average	Unsatisfactory
Coefficient of	< 0.10	0.10-0.15	0.15-0.20	> 0.20
variation				

The design of building is based on a concrete grade of C20 (cast in place). Using the TS-500 provisions compute the design strength, f_{cd} and the mean strength, f_{cm} to be specified to the contractor.

- a) If the standard deviation is estimated to be 4 MPa
- b) If the standard deviation cannot be estimated

Solution:

a) $f_{ck}=20 \text{ MPa}$

$$f_{cm} = f_{ck} + 1.28 \,\overline{\sigma}$$

$$f_{cm} = 20 + 1.28 \times 4 = 25 \text{ MPa}$$

$$f_{cd} = \frac{f_{ck}}{\gamma_{mc}} = \frac{20}{1.5} = 13.3 \text{ MPa}$$

$$f_{cm} = f_{ck} + \Delta f$$

$$f_{cm} = 20 + 6 = 26 \text{ MPa}$$

$$f_{cd} = 13.3 \text{ MPa}$$

The cracking strength of a reinforced concrete beam (C25, f_{ck} = 25 MPa) with a rectangular cross-section having a width of "b_w" and depth of "h" can be expressed by;

$$M_{cr} = \frac{f_{ctf} I}{y} = \frac{f_{ctf} \frac{1}{12} b_w h^3}{\frac{h}{2}} = \frac{f_{ctf} b_w h^2}{6}$$

A simply supported beam with a span of 6 meters carries a uniformly distributed load of g = 4 kN/m (dead load) and q = 2 kN/m (live load). The beam has a rectangular cross-section (250 mm x 600 mm). Will the beam crack under the given loads?

- a) Use TS-500-2000, $f_{ctf}=2x0.35\sqrt{f_{ck}}$, to make a ULS check.
- b) Use TS-500-2000, $f_{ctf} = 2x0.35\sqrt{f_{ck}}$, to make a SLS check.

Solution:

a) TS500-2000: Ultimate Limit State Check

Factored Load
$$P_d = 1.4 (g) + 1.6 (q) = 1.4 (4) + 1.6 (2) = 8.8 \text{ kN/m}$$

Design Moment
$$M_d = \frac{1}{8} P_d \ell^2 = \frac{1}{8} (8.8)(6)^2 = 39.6 \text{ kN-m} = 39.6 \times 10^6 \text{ N-mm}$$

Cracking Moment (the resistance of the beam)

$$M_{cr} = M_{cr} > M_d$$
 beam cracks. ULS is violated. Increase the size of the beam.

$$M_{cr} = \frac{f_{ctf}}{\gamma_{mc}} b_{w} \frac{h^{2}}{6}$$

$$= \frac{0.7 \times \sqrt{25}}{1.5} \times \frac{250 \times 600^{2}}{6}$$

$$= 35 \times 10^{6} N \cdot mm$$

TS-500-2000: Serviceability Limit State Check b)

Factored Load $P_d = 1.0(g) + 1.0(q) = 6.0 \text{ kN/m}$

Design Moment

$$M_{d} = \frac{1}{8} P_{d} \ell^{2} = \frac{1}{8} (6.0)(6)^{2}$$
$$= 27.0 \text{kN} - \text{m}$$
$$= 27.0 \text{x} 10^{6} \text{ N} - \text{mm}$$

Cracking Moment

$$M_{cr} = \frac{1}{\gamma_{mc}} 0.35x2\sqrt{f_{ck}}b_{w}h^{2}\frac{1}{6}$$

$$= \frac{1}{1.5}(0.70)\sqrt{25}(250)(600)^{2}\frac{1}{6}$$

$$= 35x10^{6}N - mm$$

$$M_{cr} = \frac{1}{6}M_{cr} = \frac{1}{6}M$$

Samples from a RC building reveal that the strength distribution is normal with $f_{cm} = 30$ MPa and $\sigma = 2.5$ MPa.

What is the probability of having a concrete with $f_{ci} \le 20$ MPa?

Solution:

$$f_{cm} - f_{ci} = 30 - 20 = 10 \text{ MPa};$$

$$u\overline{\sigma} = f_{cm} - f_{ci} = 10$$

$$u = \frac{10}{\overline{\sigma}} = \frac{10}{2.5} = 4$$

From the table in Figure 3.1 for u = 4.0, $(1-F) = 3.17 \times 10^{-5}$. Then the probability of having $f_{ci} \le 20$ MPa is 3.17×10^{-5} .