Curtailment instruction CPL-CI-2026-018

Planned network outage

Field	Value
Issued	2026-07-02 10:15
To	Contoso Renewables, Quellmoor Ridge Wind Farm
Connection point	Skelvane 132 kV substation, circuit 2
Reason	Planned maintenance of Skelvane 132 kV circuit 1; the network runs on a single circuit

Instruction

Limit the active power export at the connection point to 20 MW on 14, 15 and 16 July 2026, each day from 08:00 to 18:00 local time.

Date	From	To	Export limit
2026-07-14	08:00	18:00	20 MW
2026-07-15	08:00	18:00	20 MW
2026-07-16	08:00	18:00	20 MW

- When the limit ends, restore the export with a ramp rate of at most 5 MW per minute.
- Acknowledge this instruction within 48 hours.
- Export above the limit by more than 1 MW for more than 5 minutes will be reported.
- Network Control may extend the outage; any extension is confirmed by phone and in writing.

Acknowledgement

Acknowledged for Contoso Renewables by Dario Penwarden, O&M Supervisor, on 2026-07-02 at 14:40.

Network Control duty engineer, City Power & Light (available 24/7).