



RECTIFIED IDEAL SPECIFICATION

Metric	Original Value	Optimized Value	Status
Concrete Grade	M30	M30	Pass
Min Cement Content	320 kg/m ³	320 kg/m ³	Pass
W/C Ratio	0.45	0.45	Pass
Characteristic Strength	30 N/mm ²	30 N/mm ²	Pass
Beams Cover	50mm	50mm	Pass
Columns Cover	50mm	50mm	Pass
Slabs Cover	50mm	50mm	Pass
Mixing Time	2 mins	2 mins	Pass
Compaction Method	mechanical vibrator	mechanical vibrator	Pass
Curing Days	10 days	10 days	Pass
Aggregate Size	20mm	20mm	Pass
Sampling Sets	Not Provided	Not Provided	Warning