



MONITORING

- Dashboard
- Greenhouses
- Devices
- Thresholds
- Alerts 4
- Control Panel
- Schedules
- Reports

Control Panel

Manual overrides & automation ·
last synced 12 sec ago

GH-01 ·
 Main
Hall

Systems
Online

1 device offline
Humidity Sensor · GH-02 North Wing
stopped responding 6 min ago —
automation rules depending on it
are paused.

Inspect device

Manual Control

Override relays directly — changes log against your
operator account

2 of 4 relays
active

Irrigation Pump

Running

RUNNING FOR 00:04:33

LAST RUN Today 14:21 Manual

Ventilation Fan

Off

LAST RUN Today 11:05 Auto

Valve 1 —

Open

LAST RUN Today 14:18

Automation Status

Rules evaluate every 30 seconds against live sensor readings

Rule Engine: Active
3 of 4 rules enabled · evaluated 11 sec ago

Healthy

RULE NAME	CONDITION	ACTION	LAST TRIGGERED
Low Moisture Alert	Soil moisture < 35%	→ Irrigation Pump → ON	14 min ago
High Temp Vent	Temperature > 35 °C	→ Ventilation Fan → ON	2 hr ago
Night Humidity Hold	Humidity < 55% · 22:00–06:00	→ Mist Line → ON	Yesterday 23:4