



# HYDERABAD METROPOLITAN WATER SUPPLY & SEWERAGE BOARD

OFFICE OF THE GENERAL MANAGER (ENGG)

PRINT DATE : 26/07/2021

## **INTIMATION FOR PAYMENT** (In Committee No , Sl.No , Dt. )

To

**Sri Cheruku Vijay Reddy and Others,**  
1-11 PLOT NO 1 SY.NO-13, MACHABOLLARAM, FATHER  
BALAIAHNAGAR (FATHER BALAIAHNAGAR - Div13)

**File No : 2020-1-283**

Circle : Circle - 5  
Division : Division 13 (ALWAL N MALKAJGIRI)  
Category : MULTI STORIED BUILDING  
Revenue Category : M1-MSAC-DOMESTIC  
Applied For : New  
Feasibility Receipt File.No.:

Sir/Madam ,

**Sub :- Your Application for Sanction of Water And Sewerage connection -Reg.**

Adverting to the subject cited, it is to inform that 20mm Water Supply Connection and corresponding Sewerage Connection to the premises bearing 1-11 PLOT NO 1 SY.NO-13, MACHABOLLARAM, FATHER BALAIAHNAGAR (FATHER BALAIAHNAGAR - Div13) is under consideration for sanction (the Connection may be released if the water supply main is within 35 rmt or after laying of pipeline otherwise the connection charges may be refunded). It is hereby requested to make the payment of the following charges with in **38** days (by **24/08/2021**) otherwise your application will become Inactive. Intimation For Payment Generated Date: **17/07/2021**.

**The Following is the breakup:**

Water Supply Connection Charges	(633) SqMtrs	:	Rs.	264900.00
Charges For Augmenting Source		:	Rs.	0.00
60 Days Water Consumption Charges		:	Rs.	6125.00
Meter Cost 20 mm		:	Rs.	0.00
Green Brigade Charges ( DCW )		:	Rs.	8000.00
RWHS Consultancy Charges ( DCW )		:	Rs.	6000.00
Water Supply Connection Improvement ( DCW )		:	Rs.	0.00
Sewerage Improvement Charges ( DCW )		:	Rs.	0.00
Main Infrastructure Development Charges		:	Rs.	0.00
Road Restoration Charges		:	Rs.	0.00
Revalidation Charges		:	Rs.	5000.00
Total Amount			Rs.	290025.00
Total Deduction			Rs.	( - ) 150000.00
Tentative Amount			Rs.	140025.00

**Amount In Words : Rupees One Lakh Forty Thousand Twenty-Five And Zero Paise Only**

***The Payment to be made in full (no part payment ) through NEFT/RTGS***

**NEFT/RTGS account details For Axis Bank:**

Account No: **18151202001283**  
Bank & Branch: **Axis Bank, Mumbai**  
Account Name: **HMWSSB**  
IFSC Code: **UTIB0CCH274**

**NEFT/RTGS account details For ICICI Bank:**

Account No: **HMWS1202001283**  
Bank & Branch: **ICICI Bank Ltd. & CMS HUB**  
Account Name: **HMWSSB**  
IFSC Code: **ICIC0000104**



Digitally Signed By  
**DAMODAR REDDY GAYAM**



**NOTE :**

1. The applicant should purchase and hand over to GB agency a water meter conforming to ISO-4064, Class-B for releasing Connection.
2. Water Connection will be released only after constructing Meter Chamber of size 0.45m X 0.45m (1.5ft X 1.5 ft) for 15mm dia and 0.75m X 0.75m (2.5ft X 2.5ft) for 20mm to 40mm dia and fixing of Meter at applicants cost. The applicant has to safe guard the water meter from theft or any tampering.
3. Connection will be released only after constructing Meter Chamber and fixing of AMR Meter.
4. Connections sanctioned under Bulk Category, upto the agreed quantity the rate per KL is \_\_\_\_\_ and above agreed quantity will be charged at \_\_\_\_\_ per KL.
5. The additional length of connection from meter chamber to sump has to be taken up at the cost of the applicant.
6. Connection will be released only after laying the proposed Main, if lines are not existing and water supply and sewerage improvement charges are levied.
7. Construction of Rain Water Harvesting structure in the premises where plot area is more than 200 Sq.mts is mandatory.
8. Occupancy Certificate is mandatory for all buildings, however in respect of individual buildings in plots upto 100 Sq.mtrs with height upto 7mtrs obtaining OC is optional.
9. Connection will be released only after submission of Occupancy Certificate from GHMC or else connection will be released duly levying the monthly water bill @ 3 times of normal tariff.
10. Obtaining the Sewerage connection is the responsibility of the applicant duly consulting the HMWSSB & GHMC field officers. If road cutting permission is required for obtaining the sewerage connections, the applicant shall obtain the same from GHMC by paying requisite charges.
11. Silt chambers are mandatory for all commercial buildings and for all connections under Category-II & III.
12. Any other supplemental works inside the applicant's premises relating to release of water supply & sewerage connection such as dismantling and restoration of ramps, CRS masonry, drilling to sump, etc. has to be taken up at the cost of the applicant.
13. HMWSSB reserves the right to revise this order at any time if the field particulars are found to be incorrect.
14. The connection given to the premises does not confer any legal right regarding the property in question.

**Customer Remarks :**

JOIN OUR HAPPY CUSTOMER FAMILY

