FUGRO TECHNICAL SERVICES LIMITED

Fugro Development Centre, 5 Lok Yi Street, Tai Lam, Tuen Mun, N.T., Hong Kong.

: +852 2450 8233 Tel : +852 2450 6138 Fax E-mail : matlab@fugro.com Website: www.fugro.com



Report No.

186527CH190594





Page 1 of 1

Test Report on Chemical Analysis of Hardened Concrete

Information	Supplied	by	Client
-------------	----------	----	--------

Client

C.M. Wong & Associates Ltd.

Client's address

1104, Universal Trade Centre, 3-5A Arbuthnot Road, Hong Kong

Project

Structural Condition Survey at Good Year Industrial Building,

No.119-121 How Ming Street, Kwun Tong

Sample description

One sample of hardened concrete (Powder drilling)

Client sample ID.

C0301

Sampling location

3/F Beam

Depth of sample from concrete surface :

5~80 mm

Date of sampling

16/03/2019

Tests required

Cement content and aggregate/cement ratio (by CaO determination)

Laboratory Information

Laboratory sample ID.

CH190594/1 (SD1901144) (PE190153)

Date of receipt of sample:

20/03/2019

Date test commenced

20/03/2019

Date test completed

09/04/2019

Test methods used

CS1: 2010 Section 21.6.4, 21.6.6 & 21.6.7

Results:

Meanita .		Drocor	st/Not detected
1.	Pulverized fuel ash (PFA) in the sample	FICSCI	#/NOT GETECTE
2.	Testing assumptions: Type of aggregate	Type I 62.0 0.2	% % %
	By assay : CaO content by mass of sample	8.3	%
	Cement content by mass of sample	13.1	%

Supervised by : H.Y. Chan

Certified by

Approved Signatory: AU Kwok Man, Bruce Assistant Manager - Chemical Laboratory

Date

** End of Report *

Note: This report refers only to the sample(s) tested.

The Hong Kong Accreditation Service (HKAS) has accredited Fugro Technical Services Limited (Reg. No. HOKLAS 015) under the Hong Kong Laboratory Accreditation Scheme (HOKLAS) for specific laboratory activities as listed in the HOKLAS Directory of Accredited Laboratories. This report shall not be reproduced except in full with prior written approval from the issuing laboratory.