

# Test Raw Data Report

## Test Details

Test Purpose:	TO DETERMINE THE FLOWRATE AND AIR CHANGES PER HOUR IN A CLEAN ROOM
Test Date:	08.09.2025
Test Workflow ID:	T-1-7-1-1756793223
Equipment:	AHU-01

## Calculations Summary

Room Volume (m³):	4,354.30
Total Supply CFM:	1,254.00
Calculated ACPH:	0.49

## Test Results

Room	Filter Code	R1	R2	R3	R4	R5	Average	Flow Rate	Entered By
Vial Filling Lyo Loading and Unloading Area	AHU-01/THF/0.3µm/01/A	5	5	5	5	5	5	600	Vendor User One I

Vial Filling Lyo Loading and Unloading Area	AHU-01/THF/0.3µm/02/A	67	54	555	43	33	150.4	654	Vendor User One I
---	-----------------------	----	----	-----	----	----	-------	-----	-------------------