


| | | |
|--|---|------------------------|
| Approved By:  | Implementation Date: <u>30 OCT 2021</u> | Issued By: <u>NA</u> |
| Sign & Date: <u>30.10.2021</u> | Sign & Date: <u>30.10.2021</u> | Sign & Date: <u>NA</u> |

Cipla
Goa, Unit-VII

AIR FLOW VISUALIZATION TEST RECORD

Department: * Coe Coating

Type of test: Air flow visualization

Media used for the test Method: Clean viewer/ Dry ice/Clean room fogger/ Fibre tracer thread or Thin film tape /

Glycol fogger Mini colt 4 smoke generator/ FPT 500 flow pattern tester/ Fog machine.

Test condition: At Rest

State of occupancy: At built (At static) In dynamic

Apparatus used: video camera

CD/DVD Number: GOA-09/COAT/AHU-MDL-123/23/VT-11

Differential pressure shall be within limits: found within limit.

Plan for air flow visualization:

Number of supply grills as per layout to be verified: 06 Nos.


Number of return grills as per layout to be verified: 07 Nos.

Number of door openings to be checked: 01 Nos.

Verified by: Sm/ 21.01.23 (Sign/Date)

Verified by: Sm/ 21.01.23 (Sign/Date)

Verified by: Sm/ 21.01.23 (Sign/Date)

| Sr. No. | Name of the area | Room No. | Equipment name | Equipment code | Videography completes all supply/return/door openings (Yes/No) | Reference CD/DVD number with CD/DVD received date | Observation / Remark | Summary of findings of air flow pattern | Area cleaning status | Study reviewed by Engg dept. Name / Sign/Date | Study approved by QA dept. Name / Sign/Date |
|---------|------------------|----------|-------------------|----------------|--|---|----------------------|---|----------------------|---|---|
| 01 | Inpro cess-Tv | 7210 | Air handling unit | MDL-123 | yes | GOA-07/COAT/AHU-MDL-123/23/VT-11 23.01.2023 | found satisfactory | Smoke found diffusing uniformly from supply grill into room and returning from return grill | cleaned | Suraj M Sm/ 16.02.2023 |  12.05.2023 |
| | | | | | na | | | | | | |

Prepared By:
Sign/Date: Sm/ 29.10.2021

Sm/ 16.02.2023

* wrong Endry Connected Sm/ 21.01.2023

* Sm/ 21.01.2023

Date of test: 21.01.2023

Due on: 20.01.2025

| | |
|---------------------------------|---|
| Certificate Reviewed By: | <div data-bbox="1252 802 1435 834">Engg User One</div> <div data-bbox="1167 879 1529 911">Date: 30.06.2025 02:16:48 PM</div> <div data-bbox="1133 956 1559 987">Engg / User Department (Cipla Ltd.)</div> |
|---------------------------------|---|