

# Test Certificate

**Cipla**  
Goa

## Test Details

<b>Test Purpose:</b>	TO DETERMINE THE FLOWRATE AND AIR CHANGES PER HOUR IN A CLEAN ROOM
<b>Test Date:</b>	10.09.2025
<b>Test Workflow ID:</b>	T-1-7-1-1756793223 (part of V-1-7-1744396200-Y)
<b>Equipment:</b>	AHU-01 - Unit VII

## Instrument Details

Instrument Type	Instrument ID	Serial Number	Calibration Status	Calibrated On	Calibration Due	Added Date	Added By
Air Capture Hood	INs234	s222	Valid	02.09.2025	02.09.2026	10.09.2025	Vendor User One I
Air Capture Hood	INs2346777sss	s2228	Valid	02.09.2025	02.09.2026	10.09.2025	Vendor User One I

## Calculations Summary

<b>Room Volume (m³):</b>	<b>4,354.30</b>
<b>Total Supply CFM:</b>	<b>1,099.98</b>
<b>Calculated ACPH:</b>	<b>0.43</b>

# Test Certificate

## Test Results

Room Name	Area Classification	Instrument ID	Filter Code	Avg in fpm	Cell Area (AC)	Flow Rate	Total Flow Rate
Vial Filling Lyo Loading and Unloading Area	ISO 5/Grade B	INs2346777sss	AHU-01/THF/0.3µm/01/A	0.00	7.50	599.98	599.98
Vial Filling Lyo Loading and Unloading Area	ISO 5/Grade B	INs234	AHU-01/THF/0.3µm/02/A	0.00	7.50	500.00	500.00
Total Flow Rate Sum:							1,099.98

## Test Performance and Witness Details

<b>Test Done By:</b>	Vendor User One I
<b>Test Done On:</b>	10.09.2025 19:18
<b>Test Witnessed By:</b>	Engg User One
<b>Test Witnessed On:</b>	10.09.2025 19:35