

Test Raw Data

Test Details

Test Workflow ID:	T-1-7-1-1756793223
Equipment under Test:	AHU-01 - Packing corridor, Production corridor, Compression-Coating corridor, IPQC III, Change room-III
Test Date:	08.09.2025
Room Name:	Vial Filling Lyo Loading and Unloading Area
Room Volume:	4354.30 mÂ³

Filter Code	R1	R2	R3	R4	R5	Average	Flow Rate
AHU-01/THF/0.3mu/01/A	5	5	5	5	5	5.00	600
AHU-01/THF/0.3mu/02/A	67	54	555	43	33	150.40	654

Generated on: 08.09.2025 18:52:43

Generated by: Vendor User One I