PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd Unit - IV

Department: Store
AHU No.: LGA-07
Room Name: Packing Materials

Page No. : 01 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PURGE
11/12/2023 14:57:41
11/12/2023 14:58:41 #1
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	0	0
1.0	0	0
2.0	0	0
5.0	0	0
10.0	0	0
25.0	0	0

00:01:00 0.099992 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:00:01
11/12/2023 15:01:01 #1
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	41366	119648
1.0	23908	78282
2.0	42586	54375
5.0	9239	11789
10.0	2360	2550
25.0	190	190

00:01:00 0.100010 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:03:01
11/12/2023 15:04:01 #3
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	40060	107682
1.0	22554	67623
2.0	37080	45068
5.0	6518	7988
10.0	1360	1470
25.0	110	110

00:01:00 0.100026 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:01:31
11/12/2023 15:02:31 #2
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	41715	119393
1.0	23683	77678
2.0	42805	53996
5.0	9211	11191
10.0	1800	1980
25.0	180	180

00:01:00 0.099989 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:04:31
11/12/2023 15:05:31 #4
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	40634	109354
1.0	23727	68720
2.0	35655	44994
5.0	6919	9339
10.0	2060	2420
25.0	360	360

00:01:00 0.100014 m³/m

11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd Unit - IV

Department: Store
AHU No.: L&A -07
Room Name: Packing Materials

Page No. : 01 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PURGE
11/12/2023 14:57:41	
11/12/2023 14:58:41	#1
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	0	0
1.0	0	0
2.0	0	0
5.0	0	0
10.0	0	0
25.0	0	0

00:01:00 0.099992 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:00:01	
11/12/2023 15:01:01	#1
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	41366	119648
1.0	23908	78282
2.0	42586	54375
5.0	9239	11789
10.0	2360	2550
25.0	190	190

00:01:00 0.100010 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:03:01	
11/12/2023 15:04:01	#3
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	40060	107682
1.0	22554	67623
2.0	37080	45068
5.0	6518	7988
10.0	1360	1470
25.0	110	110

00:01:00 0.100026 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:01:31	
11/12/2023 15:02:31	#2
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	41715	119393
1.0	23683	77678
2.0	42805	53996
5.0	9211	11191
10.0	1800	1980
25.0	180	180

00:01:00 0.099989 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:04:31	
11/12/2023 15:05:31	#4
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	40634	109354
1.0	23727	68720
2.0	35655	44994
5.0	6919	9339
10.0	2060	2420
25.0	360	360

00:01:00 0.100014 m³/m

11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd Unit - IV

Department: Store
AHU No.: LGA - 07
Room Name: Packing Materials

Page No. : 02 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

al Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	PACKING MATERIAS
11/12/2023 15:06:01	
11/12/2023 15:07:01	#5
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	35853	93763
1.0	19666	57909
2.0	31734	38243
5.0	5289	6509
10.0	1030	1220
25.0	190	190

00:01:00 0.100018 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	PACKING MATERIAS
11/12/2023 15:09:01	
11/12/2023 15:10:01	#7
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	41482	105685
1.0	21841	64203
2.0	35182	42362
5.0	6030	7180
10.0	1010	1150
25.0	140	140

00:01:00 0.099996 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	PACKING MATERIAS
11/12/2023 15:12:01	
11/12/2023 15:13:01	#9
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	36563	94749
1.0	19672	58185
2.0	30813	38514
5.0	5741	7701
10.0	1830	1960
25.0	130	130

00:01:00 0.099991 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	PACKING MATERIAS
11/12/2023 15:07:31	
11/12/2023 15:08:31	#6
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	39258	106836
1.0	22309	67577
2.0	37538	45268
5.0	6410	7730
10.0	1210	1320
25.0	110	110

00:01:00 0.100004 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	PACKING MATERIAS
11/12/2023 15:10:31	
11/12/2023 15:11:31	#8
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	48372	121009
1.0	25846	72638
2.0	38303	46792
5.0	6889	8489
10.0	1520	1600
25.0	80	80

00:01:00 0.100017 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	PACKING MATERIAS
11/12/2023 15:13:31	
11/12/2023 15:14:31	#10
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	62768	155075
1.0	33639	92307
2.0	46179	58668
5.0	8380	12490
10.0	3500	4110
25.0	610	610

00:01:00 0.100003 m³/m
11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd Unit - IV

Department: Store
AHU No.: LGA - 07
Room Name: Packing Materials

Page No. : 02 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade D
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:06:01
11/12/2023 15:07:01 #5
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	35853	93763
1.0	19666	57909
2.0	31734	38243
5.0	5289	6509
10.0	1030	1220
25.0	190	190

00:01:00 0.100018 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:09:01
11/12/2023 15:10:01 #7
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	41482	105685
1.0	21841	64203
2.0	35182	42362
5.0	6030	7180
10.0	1010	1150
25.0	140	140

00:01:00 0.099996 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:12:01
11/12/2023 15:13:01 #9
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	36563	94749
1.0	19672	58185
2.0	30813	38514
5.0	5741	7701
10.0	1830	1960
25.0	130	130

00:01:00 0.099991 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:07:31
11/12/2023 15:08:31 #6
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	39258	106836
1.0	22309	67577
2.0	37538	45268
5.0	6410	7730
10.0	1210	1320
25.0	110	110

00:01:00 0.100004 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:10:31
11/12/2023 15:11:31 #8
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	48372	121009
1.0	25846	72638
2.0	38303	46792
5.0	6889	8489
10.0	1520	1600
25.0	80	80

00:01:00 0.100017 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:13:31
11/12/2023 15:14:31 #10
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	62768	155075
1.0	33639	92307
2.0	46179	58668
5.0	8380	12490
10.0	3500	4110
25.0	610	610

00:01:00 0.100003 m³/m
11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit- IV

Department: Stores
AHU No.: LGA-07
Room Name: Packing Materials

Page No. : 03 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8/Grade'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:15:01
11/12/2023 15:16:01 #11
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	53814	130419
1.0	27922	76605
2.0	39633	48683
5.0	6440	9051
10.0	2300	2610
25.0	310	310

00:01:00 0.099993 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:16:31
11/12/2023 15:17:31 #12
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	54344	137701
1.0	30592	83356
2.0	41203	52764
5.0	7581	11561
10.0	3550	3980
25.0	430	430

00:01:00 0.099992 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:18:01
11/12/2023 15:19:01 #13
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	57322	138565
1.0	29791	81243
2.0	42312	51452
5.0	6820	9140
10.0	2150	2320
25.0	170	170

00:01:00 0.099996 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:19:31
11/12/2023 15:20:31 #14
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	39724	93750
1.0	19582	54026
2.0	28243	34444
5.0	4791	6201
10.0	1340	1410
25.0	70	70

00:01:00 0.099989 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATE
11/12/2023 15:21:01
11/12/2023 15:22:01 #15
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	29549	69919
1.0	15020	40369
2.0	21330	25350
5.0	3140	4020
10.0	810	880
25.0	70	70

00:01:00 0.100002 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:22:31
11/12/2023 15:23:31 #16
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	40031	95212
1.0	20050	55181
2.0	27781	35131
5.0	5100	7350
10.0	2030	2250
25.0	220	220

00:01:00 0.099998 m³/m
11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd Unit- IV

Department: Store
AHU No.: LGA-07
Room Name: Packing Materials

Page No. : 03 of 04
Date of Test: 11.12.2023
Class/Grade: Iso 8/Grade D
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:15:01
11/12/2023 15:16:01 #11
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	53814	130419
1.0	27922	76605
2.0	39633	48683
5.0	6440	9051
10.0	2300	2610
25.0	310	310

00:01:00 0.099993 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:16:31
11/12/2023 15:17:31 #12
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	54344	137701
1.0	30592	83356
2.0	41203	52764
5.0	7581	11561
10.0	3550	3980
25.0	430	430

00:01:00 0.099992 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:18:01
11/12/2023 15:19:01 #13
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	57322	138565
1.0	29791	81243
2.0	42312	51452
5.0	6820	9140
10.0	2150	2320
25.0	170	170

00:01:00 0.099996 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:19:31
11/12/2023 15:20:31 #14
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	39724	93750
1.0	19582	54026
2.0	28243	34444
5.0	4791	6201
10.0	1340	1410
25.0	70	70

00:01:00 0.099989 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:21:01
11/12/2023 15:22:01 #15
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	29549	69919
1.0	15020	40369
2.0	21330	25350
5.0	3140	4020
10.0	810	880
25.0	70	70

00:01:00 0.100002 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: PACKING MATERIAS
11/12/2023 15:22:31
11/12/2023 15:23:31 #16
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	40031	95212
1.0	20050	55181
2.0	27781	35131
5.0	5100	7350
10.0	2030	2250
25.0	220	220

00:01:00 0.099998 m³/m
11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit-IV

Department: Store
AHU No.: LGA-07
Room Name: Packing Materials

Page No. : 04 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8/ Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:24:01	
11/12/2023 15:25:01	#17
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	22784	66491
1.0	11432	43707
2.0	17743	32275
5.0	4891	14532
10.0	7571	9642
25.0	2070	2070

00:01:00 0.099983 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:27:01	
11/12/2023 15:28:01	#19
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	26348	62876
1.0	13909	36528
2.0	16579	22619
5.0	2980	6040
10.0	2500	3060
25.0	560	560

00:01:00 0.100006 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	PACKING MATERIAS
11/12/2023 15:25:31	
11/12/2023 15:26:31	#18
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	33823	74896
1.0	16147	41072
2.0	18906	24925
5.0	3119	6019
10.0	2180	2899
25.0	720	720

00:01:00 0.100019 m³/m

11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit-IV

Department: Store
AHU No.: LGA-07
Room Name: Packing Materials

Page No. : 04 of 04
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:24:01
11/12/2023 15:25:01 #17
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	22784	66491
1.0	11432	43707
2.0	17743	32275
5.0	4891	14532
10.0	7571	9642
25.0	2070	2070

00:01:00 0.099983 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:27:01
11/12/2023 15:28:01 #19
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	26348	62876
1.0	13909	36528
2.0	16579	22619
5.0	2980	6040
10.0	2500	3060
25.0	560	560

00:01:00 0.100006 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A
Location: PACKING MATERIAS
11/12/2023 15:25:31
11/12/2023 15:26:31 #18
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	33823	74896
1.0	16147	41072
2.0	18906	24925
5.0	3119	6019
10.0	2180	2899
25.0	720	720

00:01:00 0.100019 m³/m

11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit - IV

Department: Store
AHU No.: LGA - 07
Room Name: Staircase Airlock

Page No. : 01 **of** 01
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:35:03
11/12/2023 15:36:03 #1
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	22302	60596
1.0	13631	38294
2.0	18182	24662
5.0	3620	6481
10.0	2210	2860
25.0	650	650

00:01:00 0.099990 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:36:33
11/12/2023 15:37:33 #2
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	44466	93552
1.0	21493	49086
2.0	22523	27594
5.0	3220	5071
10.0	1700	1850
25.0	150	150

00:01:00 0.099987 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:38:03
11/12/2023 15:39:03 #3
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	21572	62168
1.0	17902	47625
2.0	22262	29723
5.0	3850	7461
10.0	2970	3610
25.0	640	640

00:01:00 0.099990 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:39:33
11/12/2023 15:40:33 #4
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	28762	73636
1.0	15081	44874
2.0	21552	29792
5.0	5060	8241
10.0	2940	3180
25.0	240	240

00:01:00 0.099992 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:41:03
11/12/2023 15:42:03 #5
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	29827	78176
1.0	15363	48349
2.0	21911	32986
5.0	5428	11075
10.0	3978	5648
25.0	1669	1669

00:01:00 0.100043 m³/m

11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit - IV

Department: Store
AHU No.: LGA - 07
Room Name: Staircase Airlock

Page No. : 01 of 01
Date of Test: 11.12.2023
Class/Grade: ISO 8 / Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:35:03
11/12/2023 15:36:03 #1
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	22302	60596
1.0	13631	38294
2.0	18182	24662
5.0	3620	6481
10.0	2210	2860
25.0	650	650

00:01:00 0.099990 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:36:33
11/12/2023 15:37:33 #2
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	44466	93552
1.0	21493	49086
2.0	22523	27594
5.0	3220	5071
10.0	1700	1850
25.0	150	150

00:01:00 0.099987 m³/m
11.12.2023
11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:38:03
11/12/2023 15:39:03 #3
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	34543	82168
1.0	17902	47625
2.0	22262	29723
5.0	3850	7461
10.0	2970	3610
25.0	640	640

00:01:00 0.099990 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:39:33
11/12/2023 15:40:33 #4
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	28762	73636
1.0	15081	44874
2.0	21552	29792
5.0	5060	8241
10.0	2940	3180
25.0	240	240

00:01:00 0.099992 m³/m
11.12.2023
11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: STAIRCAS AIRLOCK
11/12/2023 15:41:03
11/12/2023 15:42:03 #5
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	29827	78176
1.0	15363	48349
2.0	21911	32986
5.0	5428	11075
10.0	3978	5648
25.0	1669	1669

00:01:00 0.100043 m³/m
11.12.2023
11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit - IV

Department: Store
AHU No.: LGA-07
Room Name: Retention Sample Room-I

Page No. : 01 **of** 02
Date of Test: 11.12.2023
Class/Grade: Iso 8/Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I

11/12/2023 15:50:09
11/12/2023 15:51:09 #1

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	28571	63091
1.0	12650	34521
2.0	15260	21870
5.0	3170	6610
10.0	2900	3440
25.0	540	540

00:01:00 0.099998 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I

11/12/2023 15:53:09
11/12/2023 15:54:09 #3

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	20749	45217
1.0	8769	24468
2.0	11839	15699
5.0	2170	3860
10.0	1510	1690
25.0	180	180

00:01:00 0.100007 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I

11/12/2023 15:56:09
11/12/2023 15:57:09 #5

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	30023	75363
1.0	14487	45340
2.0	21475	30853
5.0	5279	9378
10.0	3669	4099
25.0	430	430

00:01:00 0.100023 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I

11/12/2023 15:51:39
11/12/2023 15:52:39 #2

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	29051	63373
1.0	13151	34322
2.0	16271	21171
5.0	2830	4900
10.0	1810	2070
25.0	260	260

00:01:00 0.099995 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I

11/12/2023 15:54:39
11/12/2023 15:55:39 #4

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	25315	60881
1.0	12682	35566
2.0	16423	22884
5.0	3561	6461
10.0	2400	2901
25.0	500	500

00:01:00 0.099982 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I

11/12/2023 15:57:39
11/12/2023 15:58:39 #6

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	23690	55219
1.0	11280	31529
2.0	15380	20250
5.0	3110	4870
10.0	1610	1760
25.0	150	150

00:01:00 0.100002 m³/m
11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit - IV

Department: Store
AHU No.: LGA-07
Room Name: Retention Sample Room-I

Date of Test: 11.12.2023
Class/Grade: ISO 8/Grade 'D'
Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: RETENT SAMP RM-I
11/12/2023 15:50:09
11/12/2023 15:51:09 #1
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	28571	63091
1.0	12650	34521
2.0	15260	21870
5.0	3170	6610
10.0	2900	3440
25.0	540	540

00:01:00 0.099998 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: RETENT SAMP RM-I
11/12/2023 15:51:39
11/12/2023 15:52:39 #2
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	29051	63373
1.0	13151	34322
2.0	16271	21171
5.0	2830	4900
10.0	1810	2070
25.0	260	260

00:01:00 0.099995 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: RETENT SAMP RM-I
11/12/2023 15:53:09
11/12/2023 15:54:09 #3
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	20749	45217
1.0	8769	24468
2.0	11839	15699
5.0	2170	3860
10.0	1510	1690
25.0	180	180

00:01:00 0.100007 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: RETENT SAMP RM-I
11/12/2023 15:54:39
11/12/2023 15:55:39 #4
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	25315	60881
1.0	12682	35566
2.0	16423	22884
5.0	3561	6461
10.0	2400	2901
25.0	500	500

00:01:00 0.099982 m³/m
11.12.2023 11.12.2023

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: RETENT SAMP RM-I
11/12/2023 15:56:09
11/12/2023 15:57:09 #5
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	30023	75363
1.0	14487	45340
2.0	21475	30853
5.0	5279	9378
10.0	3669	4099
25.0	430	430

00:01:00 0.100023 m³/m

Final Sample Report

Instrument ID: Lasair III
Serial Number: 159157
Calibrated: 15/12/2022
Operator: RUPESH A.
Location: RETENT SAMP RM-I
11/12/2023 15:57:39
11/12/2023 15:58:39 #6
Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	23690	55219
1.0	11280	31529
2.0	15380	20250
5.0	3110	4870
10.0	1610	1760
25.0	150	150

00:01:00 0.100002 m³/m
11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd unit - IV

Department: Store
AHU No.: LGA- 07
Room Name: Retention Sample Room - I

Page No. : 02 of 02
Date of Test: 11.12.2023
Class/Grade: ISO 8/Grade 'D'
Occupancy State: At Rest

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	RETENT SAMP RM-I

11/12/2023 15:59:09
11/12/2023 16:00:09 #7

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	20934	56790
1.0	12002	35857
2.0	16673	23854
5.0	3661	7181
10.0	3101	3521
25.0	420	420

00:01:00 0.099982 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	RETENT SAMP RM-I

11/12/2023 16:00:39
11/12/2023 16:01:39 #8

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	25135	57829
1.0	11568	32694
2.0	14987	21126
5.0	3249	6139
10.0	2500	2889
25.0	390	390

00:01:00 0.100019 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	RETENT SAMP RM-I

11/12/2023 16:02:09
11/12/2023 16:03:09 #9

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	26488	65469
1.0	13814	38981
2.0	18936	25167
5.0	3561	6232
10.0	2271	2671
25.0	400	400

00:01:00 0.099971 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A
Location:	RETENT SAMP RM-I

11/12/2023 16:03:39
11/12/2023 16:04:39 #10

Sample Status: Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	20253	43316
1.0	8647	23062
2.0	11266	14415
5.0	1819	3149
10.0	1170	1330
25.0	160	160

00:01:00 0.100033 m³/m

11.12.2023 11.12.2023

PARTICLE COUNT RAW DATA

Customer Name : Cipla Ltd Unit - IV

Department: Store	**Page No. :** 02 of 02
AHU No.: LGA- 07	**Date of Test:** 11.12.2023
Room Name: Retention Sample Room - I	**Class/Grade:** ISO 8/Grade 'D'
	Occupancy State: At Rest

For (Quality Technical Solutions)

QTS/HVAC/RD/GOA/PC-01

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I
11/12/2023 15:59:09	
11/12/2023 16:00:09	#7
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	20934	56790
1.0	12002	35857
2.0	16673	23854
5.0	3661	7181
10.0	3101	3521
25.0	420	420

00:01:00 0.099982 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I
11/12/2023 16:00:39	
11/12/2023 16:01:39	#8
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	25135	57829
1.0	11568	32694
2.0	14987	21126
5.0	3249	6139
10.0	2500	2889
25.0	390	390

00:01:00 0.100019 m³/m

11.12.2023 11.12.2023

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I
11/12/2023 16:02:09	
11/12/2023 16:03:09	#9
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	26488	65469
1.0	13814	38981
2.0	18936	25167
5.0	3561	6232
10.0	2271	2671
25.0	400	400

00:01:00 0.099971 m³/m

Final Sample Report

Instrument ID:	Lasair III
Serial Number:	159157
Calibrated:	15/12/2022
Operator:	RUPESH A.
Location:	RETENT SAMP RM-I
11/12/2023 16:03:39	
11/12/2023 16:04:39	#10
Sample Status:	Valid

µm	Δ (N/m³)	Σ (N/m³)
0.5	20253	43316
1.0	8647	23062
2.0	11266	14415
5.0	1819	3149
10.0	1170	1330
25.0	160	160

00:01:00 0.100033 m³/m

11.12.2023 11.12.2023

Certificate Issued By:	Vendor User One Date: 30.06.2025 10:21:00 AM