**Unit VII**

| SR. NO. | EQUIPMENT CODE | EQUIPMENT NAME | TEST ID | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | | | | | | | | | | | | |
| 1 | AHU-01 | AHU | 6 | | 20 | | | | | | | | | | |
| 2 | AHU-01 | AHU | 6 | | | | | 19 | | | | | | | |
| 3 | AHU-01 | AHU | 6 | | | | | | | | 18 | | | | |
| 4 | AHU-01 | AHU | 6 | | | | | | | | | | | 17 | |
| 5 | AHU-02 | AHU | 6 | | | | | | | 13 | | | | | |
| 6 | AHU-03 | ACD | 1 | | 20 | | | | | | | | | | |
| 7 | AHU-03 | ACD | 1 | | | | | 19 | | | | | | | |
| 8 | AHU-03 | ACD | 1 | | | | | | | | 18 | | | | |
| 9 | AHU-03 | ACD | 1 | | | | | | | | | | | 17 | |

*HVAC ROUTINE TEST SCHEDULE FOR THE YEAR 2025*

**LEGENDS :-**

| Test ID | Test Description |
|---------|------------------|
| 1 | Air changes Per Hour |
| 2 | Fresh air CFM |
| 3 | Return air CFM |
| 4 | Relief air CFM |
| 6 | Filter integrity test |
| 7 | Dust collector/Scrubber/Point exhaust CFM |
| 11 | Particle matter count at rest condition |
| 12 | Particle matter count in operation condition |
| 13 | Containment leakage test |
| 14 | Area recovery/clean-up period study |
| 17 | Air Velocity study |
| 18 | Lead time study |

Goa

| **Schedule Requested By:** | Engg User One<br><br>Engineering (Cipla Ltd.)<br><br>Date: 10.08.2025 11:15:56 |
|---|---|
| **Schedule Reviewed By:** | Engg Head One<br><br>Engg / User Department (Cipla Ltd.)<br><br>Date: 10.08.2025 11:16:18 |
| **Schedule Approved By:** | QA Head One<br><br>Quality Assurance (Cipla Ltd.)<br><br>Date: 10.08.2025 11:17:26 |