

# Test Certificate



## Test Details

Test Purpose:	TO DETERMINE THE FLOWRATE AND AIR CHANGES PER HOUR IN A CLEAN ROOM
Test Date:	08.10.2025
Test Workflow ID:	T-3-7-1-1759911286 (part of V-3-7-1759903625-Y)
Equipment:	AHU-03 - Unit VII

## Instrument Details

Instrument Type	Instrument ID	Serial Number	Calibration Status	Calibrated On	Calibration Due	Added Date	Added By
Air Capture Hood	INs234	s222	Valid	02.09.2025	02.09.2026	08.10.2025	Vendor User One I

## Calculations Summary

Room Volume (m³):	4,354.30
Total Supply CFM:	5.00
Calculated ACPH:	N/A

# Test Certificate



## Test Results

Room Name	Area Classification	Instrument ID	Filter Code	Avg in fpm	Cell Area (AC)	Flow Rate	Total Flow Rate
Vial Filling Lyo Loading and Unloading Area	ISO5/Grade B	INs234	AHU-01/THF/0.3µm/01/A	5.00	5.00	5.00	5.00
Total Flow Rate Sum:							5.00

## Test Performance and Witness Details

Test Done By:	Vendor User One I
Test Done On:	08.10.2025 15:51
Test Witnessed By:	Engg User One
Test Witnessed On:	08.10.2025 15:55

## Test Approval Details

Test Approved By:	QA User One
Test Approved On:	08.10.2025 16:20:49