



RAW DATA DETAILS FOR NON-VIABLE PARTICLE CONCENTRATION

Customer Name: - <u>Cipla Ltd, Unit-II</u>	Date of Test: <u>02.06.2025</u>
Test: <u>(Non-Viable Particle Count) / Recovery-Clean up Study / Lead Time Study</u>	
Room Name: <u>Airlock B Microbiology Testing-I</u>	Equipment Name: <u>AHU</u>
<u>Classification of Area</u> / Equipment: <u>ISO7/Grade 'C'</u>	Equipment ID: <u>AH-23</u>
Particle Counter Serial No.: <u>140385</u>	Particle Counter Calibration Due date: <u>01.08.2025</u>
Condition: At Rest / <u>(In-operation)</u>	No. of person: <u>03</u>
Description of activity: <u>Particle Count Inoperation Study</u>	

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: AIRLOCK B

02/06/2025 11:05:17
02/06/2025 11:06:17

Sample Status: #1

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	0	0	0
1.0	0	0	0
2.0	0	0	0
5.0	0	0	0
10.0	0	0	0
25.0	0	0	0

00:01:00 0.100012 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: AIRLOCK B

02/06/2025 11:07:53
02/06/2025 11:08:53

Sample Status: #1

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	12170	25640	
1.0	3220	13470	
2.0	4210	10250	
5.0	1910	6040	
10.0	3640	4130	
25.0	490	490	

00:01:00 0.100001 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: AIRLOCK B

02/06/2025 11:09:23
02/06/2025 11:10:23

Sample Status: #2

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	14856	29363	
1.0	3889	14506	
2.0	5129	10617	
5.0	2339	5489	
10.0	2749	3149	
25.0	400	400	

00:01:00 0.100025 m³/m

02.06.2025 02.06.2025

Performed by: 02.06.2025
(Quality Technical Solutions)

nitored by: 02.06.2025
(User Dept. / Engineering)



RAW DATA DETAILS FOR NON-VIABLE PARTICLE CONCENTRATION

Customer Name: - <i>Cipla Ltd, Unit II</i>	Date of Test: <i>02.06.2025</i>
Test: <u>(Non-Viable Particle Count)</u> / Recovery-Clean up Study / Lead Time Study	
Room Name: <i>Airlock B Microbiology Testing-I</i>	Equipment Name: <i>AHU</i>
<u>Classification of Area</u> / Equipment: <i>ISO 7 / Grade 'C'</i>	Equipment ID: <i>AH-23</i>
Particle Counter Serial No.: <i>140385</i>	Particle Counter Calibration Due date: <i>01.08.2025</i>
Condition: At Rest / <u>(In-operation)</u>	No. of person: <i>03</i>
Description of activity: <i>Particle Count Inoperation Study</i>	

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: PURGE
 02/06/2025 11:05:17
 02/06/2025 11:06:17
 Sample Status: #1

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	0	0	0
1.0	0	0	0
2.0	0	0	0
5.0	0	0	0
10.0	0	0	0
25.0	0	0	0

 00:01:00 0.100012 m³/m
02.06.2025 *02.06.2025*

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: AIRLOCK B
 02/06/2025 11:07:53
 02/06/2025 11:08:53
 Sample Status: #1

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	12170	25640	
1.0	3220	13470	
2.0	4210	10250	
5.0	1910	6040	
10.0	3640	4130	
25.0	490	490	

 00:01:00 0.100001 m³/m
02.06.2025 *02.06.2025*

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: AIRLOCK B
 02/06/2025 11:09:23
 02/06/2025 11:10:23
 Sample Status: #2

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	14856	29363	
1.0	3889	14506	
2.0	5129	10617	
5.0	2339	5489	
10.0	2749	3149	
25.0	400	400	

 00:01:00 0.100025 m³/m
02.06.2025 *02.06.2025*

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: AIRLOCK B
 02/06/2025 11:10:53
 02/06/2025 11:11:53
 Sample Status: #3

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$	Valid
0.5	10861	20473	
1.0	2790	9611	
2.0	3120	6821	
5.0	1570	3701	
10.0	1900	2130	
25.0	230	230	

 00:01:00 0.099986 m³/m
02.06.2025 *02.06.2025*

Performed by: *02.06.2025*
 (Quality Technical Solutions)

nitored by: *02.06.2025*
 (User Dept. (Engineering))



RAW DATA DETAILS FOR NON-VIABLE PARTICLE CONCENTRATION

Customer Name: - <u>Cepla Ltd, Unit-II</u>	Date of Test: <u>02.06.2025</u>
Test: <u>(Non-Viable Particle Count) Recovery-Clean up Study / Lead Time Study</u>	
Room Name: <u>Microbiology Testing-I</u>	Equipment Name: <u>AHU</u>
Classification of Area/ Equipment: <u>ISO 7/Grade 'C'</u>	Equipment ID: <u>AH-23</u>
Particle Counter Serial No.: <u>140385</u>	Particle Counter Calibration Due date <u>01.08.2025</u>
Condition: At Rest <u>(In-operation)</u>	No. of person: <u>04</u>
Description of activity: <u>Particle Count Inoperation Study</u>	

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: MICRO TESTING-I

02/06/2025 11:18:57

02/06/2025 11:19:57 #1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	9021	17021
1.0	2740	8001
2.0	1960	5260
5.0	960	3300
10.0	1770	2340
25.0	570	570

00:01:00 0.099994 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: MICRO TESTING-I

02/06/2025 11:20:27

02/06/2025 11:21:27 #2

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	3590	8240
1.0	1110	4650
2.0	1080	3540
5.0	850	2460
10.0	1090	1610
25.0	520	520

00:01:00 0.099999 m³/m

02.06.2025 02.06.2025

Performed by: 02.06.2025
 (Quality Technical Solutions)

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: MICRO TESTING-I

02/06/2025 11:21:57

02/06/2025 11:22:57 #3

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	2439	6528
1.0	750	4089
2.0	860	3339
5.0	940	2479
10.0	1240	1540
25.0	300	300

00:01:00 0.100025 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: MICRO TESTING-I

02/06/2025 11:23:27

02/06/2025 11:24:27 #4

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	4540	9550
1.0	880	5010
2.0	1210	4130
5.0	1190	2920
10.0	1490	1730
25.0	240	240

00:01:00 0.100003 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: MICRO TESTING-I

02/06/2025 11:24:57

02/06/2025 11:25:57 #5

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	2470	4830
1.0	540	2360
2.0	620	1820
5.0	460	1200
10.0	580	740
25.0	160	160

00:01:00 0.099999 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
 Serial Number: 140385
 Calibrated: 01/08/2024
 Operator: GOUTAM M
 Location: MICRO TESTING-I

02/06/2025 11:26:27

02/06/2025 11:27:27 #6

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	1570	5559
1.0	400	3990
2.0	820	3590
5.0	1130	2770
10.0	1260	1640
25.0	380	380

00:01:00 0.100009 m³/m

02.06.2025 02.06.2025

Monitored by: 02.06.2025
 (User Dept. Engineering)



RAW DATA DETAILS FOR NON-VIABLE PARTICLE CONCENTRATION

Customer Name: - <u>Cepla Ltd, Unit-II</u>	Date of Test: <u>02.06.2025</u>
Test: <u>(Non-Viable Particle Count) Recovery-Clean up Study / Lead Time Study</u>	
Room Name: <u>Microbiology Testing-I</u>	Equipment Name: <u>AHU</u>
Classification of Area/ Equipment: <u>ISO 7/Grade 'C'</u>	Equipment ID: <u>AH-23</u>
Particle Counter Serial No.: <u>140385</u>	Particle Counter Calibration Due date: <u>01.08.2025</u>
Condition: At Rest <u>(In-operation)</u>	No. of person: <u>04</u>
Description of activity: <u>Particle Count Inoperation Study</u>	

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: MICRO TESTING-I

02/06/2025 11:18:57

02/06/2025 11:19:57

#1

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	9021	17021
1.0	2740	8001
2.0	1960	5260
5.0	960	3300
10.0	1770	2340
25.0	570	570

00:01:00

0.099994 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: MICRO TESTING-I

02/06/2025 11:20:27

02/06/2025 11:21:27

#2

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	3590	8240
1.0	1110	4650
2.0	1080	3540
5.0	850	2460
10.0	1090	1610
25.0	520	520

00:01:00

0.099999 m³/m

02.06.2025 02.06.2025

Performed by: 02.06.2025
(Quality Technical Solutions)

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: MICRO TESTING-I

02/06/2025 11:21:57

02/06/2025 11:22:57

#3

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	2439	6528
1.0	750	4089
2.0	860	3339
5.0	940	2479
10.0	1240	1540
25.0	300	300

00:01:00

0.100025 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: MICRO TESTING-I

02/06/2025 11:23:27

02/06/2025 11:24:27

#4

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	4540	9550
1.0	880	5010
2.0	1210	4130
5.0	1190	2920
10.0	1490	1730
25.0	240	240

00:01:00

0.100003 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: MICRO TESTING-I

02/06/2025 11:24:57

02/06/2025 11:25:57

#5

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	2470	4830
1.0	540	2360
2.0	620	1820
5.0	460	1200
10.0	580	740
25.0	160	160

00:01:00

0.099999 m³/m

02.06.2025 02.06.2025

Final Sample Report

Instrument ID: Lasair III
Serial Number: 140385
Calibrated: 01/08/2024
Operator: GOUTAM M
Location: MICRO TESTING-I

02/06/2025 11:26:27

02/06/2025 11:27:27

#6

Sample Status: Valid

μm	$\Delta (\text{N/m}^3)$	$\Sigma (\text{N/m}^3)$
0.5	1570	5559
1.0	400	3990
2.0	820	3590
5.0	1130	2770
10.0	1260	1640
25.0	380	380

00:01:00

0.100009 m³/m

02.06.2025 02.06.2025

Monitored by: 02.06.2025
(User Dept. (Engineering))