

TEST REPORT

Issued to: Maya international exports,
Gat No. 407/1/B, Tanda, gondiya-441614.

J.O. No. : W20260122-003-048
ULR Code : TC5503 02 5 0003012 F
Report Date : 28-01-2026
Sample Receipt Date : 22-01-2026
Account Manager : BD Team 22
Credit Manager : Septesh Kumar

Customer Provided Information:#

Name of the Sample/Product Name
Source of water
Manufacturing Date
Expiry Date

: **Borewell Water**
: Borewell Water
: NM
: NM

Laboratory Provided Information:


Sample Quantity & Packaging
Date of Performance of Test
Method of sampling
Sample Done By
Condition of Sample

: 2 lit
: 22NDJAN - 28TH JAN,2026
: FL/SOP/B/D-3 & 20-01-2026
: Mr. Navnath Naik (Lab Representative)
: Good & Sealed



Analysis Report

S. No	Test Parameters	Units	Results	Requirement (IS: 10500:2012)	Method of Testing
Chemical Parameters:					
Organoleptic and Physical Parameters:					
1	Colour	HU	<1	2 max	IS:3025(P-4)
2	Odour	--	Agreeable	Agreeable	IS:3025(P-5)
3	Taste	--	Agreeable	Agreeable	IS:3025(P-7&8)
4	Turbidity	NTU	<1.0	2 max	IS:3025(P-10)
5	Total Dissolved Solids (TDS)	mg/l	42.25	500 max	IS:3025(P-16)
6	pH value	--	7.28	6.5-8.5	IS:3025(P-11)
General Parameters concerning Substances undesirable in excessive amounts :					
1	Sulphate(as SO ₄)	mg/l	BDL(0.05)	200 max	IS:3025(P-24)
2	Total Alkalinity (as HCO ₃)	mg/l	5.5	200 max	IS:3025(P-23)
3	Iron(as Fe)	mg/l	BDL(0.05)	0.1 max	IS:3025(Pt-53)
4	Magnesium (as Mg)	mg/l	BDL	30 max	IS:3025(P-46)
5	Nitrate(as NO ₃)	mg/l	BDL(0.05)	45 Max	IS:3025(P-34)
6	Nitrite(as NO ₂)	mg/l	BDL(0.05)	0.02 Max	IS:3025(P-34)
7	Flouride(as F)	mg/l	ND	1 max	APHA 23 Ed. 4500F
8	Calcium(as Ca)	mg/l	BDL	75 max	IS:3025(P-40)
10	Sodium (as Na)	mg/l	BDL	200 max	IS:3025(P-45)-
11	Chloride (as Cl)	mg/l	BDL	200 max	IS:3025(P-32)-1
12	Free Residual Chlorine(as Cl ₂)	mg/l	BDL, (LOQ-0.1)	0.2 max	IS:3025(P-26)
13	Phenolic compounds(as C ₆ H ₅ OH)	mg/l	Absent	Absent	IS:3025(P-43)
General Parameters Concerning Substances Undesirable in Excessive Amount (Monthly)					
14	Anionic Surface Active Agent	mg/l	BDL, (LOQ-0.1)	0.2 max	IS:3025(P-68)


Authorised Signatory
D Mathur, Director

Page 1 of 4

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report related only to the sample tested. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance and not for legal purpose or for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

TEST REPORT

Issued to : Maya international exports,
 Gat No. 407/1/B, Tanda, gondiya-441614.

J.O. No. : W20260122-003-048
 ULR Code : TC5503 02 5 0003012 F
 Report Date : 28-01-2026
 Sample Receipt Date : 22-01-2026
 Account Manager : BD Team 22
 Credit Manager : Satesh Kumar

Customer Provided Information:#

Name of the Sample/Product Name
 Source of water
 Manufacturing Date
 Expiry Date

: Borewell Water
 : Borewell Water
 : NM
 : NM

Laboratory Provided Information:

Sample Quantity & Packaging
 Date of Performance of Test
 Method of sampling
 Sample Done By
 Condition of Sample

: 2 lit
 : 22NDJAN - 28TH JAN,2026
 : FL/SOP/B/D-3 & 20-01-2026
 : Mr. Navnath Naik (Lab Representative)
 : Good & Sealed



Analysis Report

S. No	Test Parameters	Units	Results	Requirement (IS: 10500:2012)	Method of Testing
General Parameters Concerning Substances Undesirable in Excessive Amounts:					
15	Manganese (as Mn)	mg/l	ND, (LOQ-0.005)	0.1 Max	IS: 3025 (Pt-59)
16	Zinc (as Zn)	mg/l	ND, (LOQ-0.05)	5.0 Max	IS: 3025 (Pt-49)
17	Silver (as Ag)	mg/l	ND, (LOQ-0.05)	0.01 Max	Annex J of IS: 13428
18	Aluminium (as Al)	mg/l	ND, (LOQ-0.01)	0.03 Max	IS: 3025 (Pt-55)
19	Selenium (as Se)	mg/l	ND, (LOQ-0.005)	0.01 Max	IS: 3025 (Pt-56)
20	Mineral Oil	-	BDL, (LOQ-0.01)	Absent	IS: 3025 (Pt-39)
21	Anionic surface active agents (as MBAS)	mg/l	BDL, (LOQ-0.01)	0.2 Max	Annex K of IS: 13428
22	Antimony (as Sb)	mg/l	BDL, (LOQ-0.01)	0.005 Max	Annex G of IS: 13428
23	Borates (as B)	mg/l	BDL, (LOQ-0.01)	5.0 Max	Annex H of IS: 13428
24	Bromates (as BrO3)	mg/l	BDL, (LOQ-0.01)	0.01 Max	ISO 15061:2001
Toxic Parameters:					
25	Lead (as Pb)	mg/l	ND, (LOQ-0.002)	0.01 max	IS: 3025 (Pt- 47)
26	Chromium (as Cr)	mg/l	ND, (LOQ-0.005)	0.05 max	Annex J of IS: 13428
27	Mercury (Hg)	mg/l	ND, (LOQ-0.0005)	0.001 Max	IS: 3025 (Pt-48)-2003
28	Cadmium (as Cd)	mg/l	ND, (LOQ-0.001)	0.003 Max	IS: 3025 (Pt-41)
29	Arsenic (as As)	mg/l	ND, (LOQ-0.002)	0.01 Max	IS: 3025 (Pt-37)
30	Cynide (as CN)	mg/l	Absent	Absent	IS: 3025 (Pt-27)
31	Nickel (as Ni)	mg/l	ND, (LOQ-0.002)	0.02 Max	Annex L of IS: 13428
Pesticides and Residues:					
32	DDT(o,p & p,p-isomers of DDT,DDE & DDD)	mg/l	ND, (LOQ-0.01)	NMT 0.0005	508 of USEPA
33	y-HCH(Lindane)	mg/l	ND, (LOQ-0.01)	NMT 0.0005	508 of USEPA
34	α,β and γ-HCH	mg/l	ND, (LOQ-0.01)	NMT 0.0005	508 of USEPA


Authorised Signatory
 D Mathur, Director

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report related only to the sample tested. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance and not for legal purpose or for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.

TEST REPORT

Issued to : Maya international exports,
 Gat No. 407/1/B, Tanda, gondiya-441614.

J.O. No. : W20260122-003-048
 ULR Code : TC5503 02 5 0003012 F
 Report Date : 28-01-2026
 Sample Receipt Date : 22-01-2026
 Account Manager : BD Team 22
 Credit Manager : Septesh Kumar

Customer Provided Information:#

Name of the Sample/Product Name
 Source of water
 Manufacturing Date
 Expiry Date

: **Borewell Water**
 : Borewell Water
 : NM
 : NM

Laboratory Provided Information:

Sample Quantity & Packaging
 Date of Performance of Test
 Method of sampling
 Sample Done By
 Condition of Sample

: 2 lit
 : 22NDJAN - 28TH JAN,2026
 : FL/SOP/B/D-3 & 20-01-2026
 : Mr. Navnath Naik (Lab Representative)
 : Good & Sealed



Analysis Report

S. No	Test Parameters	Units	Results	Requirement (IS: 10500:2012)	Method of Testing
35	Endosulphan(α,β and Sulphate)	mg/l	ND, (LOQ-0.01)	NMT 0.0005	508 of USEPA
36	Monocrotophos	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
37	Ethion	mg/l	ND, (LOQ-0.01)	NMT 0.0005	1657A of USEPA
38	Chlorpyrifos	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
39	Phorate(Phorate and its oxygm analogue that is phorate sulphoxide and phorate sulphone)	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
40	2,4-D	mg/l	ND, (LOQ-0.01)	NMT 0.0005	515.1 of USEPA
41	Butachlor	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
42	Isoproturon	mg/l	ND, (LOQ-0.01)	NMT 0.0005	532 of USEPA
43	Alachlor	mg/l	ND, (LOQ-0.01)	NMT 0.0005	507 of USEPA
44	Atrazine	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
45	Methyl parathion(Methyl parathion and its oxygen analogue that is methyl-paraxon)	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
46	Malathion(Malathion and its oxygen analogue that is malaaxon)	mg/l	ND, (LOQ-0.01)	NMT 0.0005	8141A of USEPA
47	Aldrin and dieldrin	mg/l	ND, (LOQ-0.01)	NMT 0.0005	525.2 of USEPA
48	Polychlorinated biphenyle (PCB)	mg/l	ND, (LOQ-0.01)	Not detectable	Annex M of IS: 13428
49	Polynuclear aromatic hydrocarbons	mg/l	ND, (LOQ-0.01)	Not detectable	APHA 6440
50	Uranium	mg/l	ND, (LOQ-0.01)	NMT 0.03	IS 15303:2003
Radioactivity Analysis:					
51	Gross Alpha Activity	Bq/l	<0.02	Max 0.1	IS 14194
52	Gross Beta Activity	Bq/l	<0.10	Max 1.0	IS 14194

TEST REPORT

Issued to: Maya international exports,
 Gat No. 407/1/B, Tanda, gondiya-441614.

J.O. No. : W20260122-003-048
 ULR Code : TC5503 02 5 0003012 F
 Report Date : 28-01-2026
 Sample Receipt Date : 22-01-2026
 Account Manager : BD Team 22
 Credit Manager : Septesh Kumar

Customer Provided Information:#

Name of the Sample/Product Name
 Source of water
 Manufacturing Date
 Expiry Date

: Borewell Water
 : Borewell Water
 : NM
 : NM

Laboratory Provided Information:

Sample Quantity & Packaging
 Date of Performance of Test
 Method of sampling
 Sample Done By
 Condition of Sample

: 2 lit
 : 22NDJAN - 28TH JAN,2026
 : FL/SOP/B/D-3 & 20-01-2026
 : Mr. Navnath Naik (Lab Representative)
 : Good & Sealed



TC - 5503

Analysis Report

S. No	Test Parameters	Units	Results	Requirement (IS: 10500:2012)	Method of Testing
1	Coliform Bacteria	cfu/ 250 ml	Absent	Absent	IS:5401(Part-1)
2	Faecal streptococci	cfu/ 250 ml	Absent	Absent	IS:5887(Part-2)
3	Sulphite reducing anaerobes	cfu/ 250 ml	Absent	Absent	Annex C of IS:13428
4	Pseudomonas aeruginosa	cfu/ 250 ml	Absent	Absent	Annex D of IS:13428
5	Aerobic Microbial count:				
(i)	at 20-22° C in 72 hours	cfu/ml	42	100 max	IS:5402 -2012
(ii)	at 37 ± 1° C in 24 hours	cfu/ml	<1	20 max	IS:5402 -2012]
6	Yeast and mould	Cfu / 250 ml	Absent	Absent	IS:5403 -1999
7	Salmonella	cfu/ 250 ml	Absent	Absent	IS:15187
8	Vibrio cholera	cfu/ 250 ml	Absent	Absent	IS:5887(Part-5)
9	V.parahaemolyticus	cfu/ 250 ml	Absent	Absent	IS:15187:2002
10	Shigella	cfu/ 250 ml	Absent	Absent	IS:5887(Part-7)
11	E. coli	cfu/ 250 ml	Absent	Absent	IS:15185 :
12	S. aureus	cfu/ 250 ml	Absent	Absent	IS:5887(Part-2)

BLQ=Below Limit of Quantification; LOQ=Limit of Quantification; NMT=Not More Than; NLT=Not Less Than

Note: The Water sample confirms to Limit of IS 10500 : 2012 for tested parameters as given above water sample in question may be used as Borewell Water .

Interference: The tested sample conforms as per 10500:2012 Standard for the Test Parameters.

Meenakshi Bakshi
Authorized Signatory
 Ms. Meenakshi Bakshi, Scientist B

Page 4 of 4
 *****End of Test Report*****

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report related only to the sample tested. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance and not for legal purpose or for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9599221227.