

=====

ACME PETROCHEMICAL DEMO COMPLEX - UNIT 2300

PROCESS DATA SHEET: CONTROL VALVES & SIS AUTOMATED SHUTDOWN VALVES

Document Code: DS-PS-0010 | Revision: Z1 | Status: Issued for Construction

Process Unit: Unit 2300 (Decomposition & Recovery Section)

1. MODULATING CONTROL VALVES SCHEDULE

Tag	Service	Line / Stream	Body Size / Rating	Cv Rated	Fail Position	Controlled By	
LV-1301	D-2304	Cleavage Product Level Control	4"-P-2306 (Stream S384 to D-2310)	3 in / 300#	RF 316L		48.
TV-1302	E-2307	Reactor Cooler CW Outlet Control	8"-CW-2312 (E-2307 Shell Outlet)	6 in / 150#	RF CS		310.
PV-0401	V-2301	Overhead Vacuum Control Valve	4"-P-2305 (X-2301 Recycle)	3 in / 150#	RF 316L		62.0 Fail

=====

DS-PS-0010 PAGE 2 OF 3 - SAFETY INSTRUMENTED SYSTEM (SIS) FINAL ELEMENTS

Tag	Service	Line / Stream	Valve Type	SIL Rating	Actuation Time	Fail Position	Interlock
XV-1305	D-2304	Sulfuric Acid Catalyst Isolation Valve	1"-P-2311 (Stream S310)	Ball Valve 316L	Fire-Safe		
XV-1309	D-2304	Emergency Cumene Quench Injection Valve	4"-P-2315 (Stream S387)	Full-Bore Ball Valve 316L			

=====

DS-PS-0010 PAGE 3 OF 3 - FUGITIVE EMISSIONS & SEAT LEAKAGE REQUIREMENTS

- All valves in Cumene Hydroperoxide (CHP) and Phenol service require ISO 15848-1 Class BH low-emission bellows o
- SIS valves XV-1305 and XV-1309 require ANSI/FCI 70-2 Class VI tight shutoff and quarterly partial-stroke testin