

=====

ACME PETROCHEMICAL DEMO COMPLEX - UNIT 2300

PROCESS DATA SHEET: FIELD INSTRUMENTS (FLOW, PRESSURE, LEVEL & TEMPERATURE)

Document Code: DS-PS-0031 | Revision: Z1 | Status: Issued for Construction

Process Unit: Unit 2300 (Decomposition & Recovery Section)

1. TEMPERATURE INSTRUMENTS SCHEDULE

Tag	Equipment	Type	Calibrated Range	Normal	Alarm (TAH)	Trip Setpoint (TXSHH)	Voting / SIL
TXSHH-1301	D-2304 Decomposer Reactor	Dual Pt100 RTD + SIL-2 Transmitter	0 to 250 degC	82.0 degC	92.0 degC		
TIC-1302	D-2304 / E-2307 Loop	Pt100 RTD Transmitter	0 to 200 degC	82.0 degC	90.0 degC		Modulates TV-
TAHH-0402	V-2301 Preflash Sump	Pt100 RTD Transmitter	0 to 200 degC	92.0 degC	98.0 degC	105.0 degC	

=====									
DS-PS-0031 PAGE 2 OF 4 - LEVEL INSTRUMENTS SCHEDULE									
Tag	Equipment	Type	Calibrated Range	Normal	Low-Low (LSLL)	High-High (LSHH)	Output Action		
LT-1301	D-2304 Decomposer Reactor	Guided-Wave Radar (316L Coaxial Probe)	0 to 4500 mm (0-100%)				55.0%		
LT-0401	V-2301 Preflash Column	Differential Pressure w/ Capillary Seal	0 to 2500 mm	42.0%	15.0%				(Trip

=====

DS-PS-0031 PAGE 3 OF 4 - PRESSURE INSTRUMENTS SCHEDULE

Tag	Equipment	Type	Calibrated Range	Normal	High Alarm (PAH)	High-High Trip (PAHH)	Notes
PT-1301	D-2304 Decomposer Reactor	Smart Diaphragm Seal Pressure Transmitter	0 to 15.0 kg/cm2g	1.8 kg/cm2g			
PT-0401	V-2301 Preflash Column	Absolute Vacuum Pressure Transmitter	0 to 100 mmHgA	35.0 mmHgA	55.0 mmHgA		

=====

DS-PS-0031 PAGE 4 OF 4 - FLOW INSTRUMENTS SCHEDULE

Tag	Line / Stream	Type	Calibrated Range	Normal Flow	Low-Low Trip (FSLL)	Wetted Material	
FT-0401	Stream S210 (V-2301 Feed)	Coriolis Mass Flow Meter	0 to 60,000 kg/hr	42,500 kg/hr	-	-	316L ST
FT-1304	Stream S379 (D-2304 Recycle)	Vortex Shedding Flow Meter	0 to 250,000 kg/hr	185,000 kg/hr	110,		